

**YUKON
ENERGY**



YUKON ENERGY 20-YEAR RESOURCE PLAN: 2011-2030

DECEMBER 2011

OUTLINE OF RESOURCE PLAN REPORT & SUPPORTING DOCUMENTS

Yukon Energy's 2011 Resource Plan ("2011 Resource Plan" or "Plan") addresses updated generation and transmission priorities in Yukon for the 20-year planning period, from 2011 to 2030. It focuses on resource planning options for the next five years (2011-2015) to meet supply requirements out to 2017 and to protect the ability to proceed with longer-term legacy development options with potential construction start in 2021 or thereafter.

The Plan is divided into seven sections: Resource Planning Principles (Section 1), Forecast Load Requirements (Section 2), Resource Planning Options (Section 3), Default Diesel Portfolio (Section 4), Minimum Greenhouse Gas Emissions Portfolio Options (Section 5), LNG Transition Portfolio Options (Section 6) and Resource Plan Summary and Conclusions (Section 7).

This Plan updates for the 2006-2025 planning period, Yukon Energy's previous 20-Year Resource Plan that was submitted to the Yukon Utilities Board for public review in mid-2006. It provides overall planning guidance for the next five years, and (as with the 2006 Resource Plan) remains subject to ongoing adjustment as new information and priorities emerge. The following are specifically noted in this regard:

- The updated load forecasts used to prepare the 2011 Resource Plan were mainly developed in the first quarter of 2011, and reflect information available at that time.
- Information on specific supply options reflect technical papers presented at Yukon Energy's March 2011 Charrette as well as information available from ongoing Yukon Energy resource planning studies.
- The 2011 Resource Plan has been prepared before a detailed energy conservation potential review now being carried out by Yukon Energy, Yukon Electrical and the Yukon Government is completed. This review will determine what Demand Side Management (DSM) programs are feasible along with an estimate of the cost implications if those programs were implemented¹.

Yukon Energy is committed to continue engaging Yukoners in resource planning, including by providing stakeholders the opportunity to comment on the draft 2011 Resource Plan before it is finalized.

¹ It is assumed in the 2011 Resource Plan that DSM programs will be implemented concurrent with any other resource supply options. A range of potential DSM program impacts is provided when each resource supply option is assessed.

PREFACE – POLICY & PUBLIC ENGAGEMENT CONTEXT

Yukon Energy is the primary generator and transmitter of electrical energy in the Yukon. Established in 1987, Yukon Energy operates as a regulated utility at arm's length from the Yukon government. Its mandate is to plan, generate, transmit and distribute a continuing and adequate supply of cost-effective, sustainable and reliable electricity for customers in the Yukon.

BACKGROUND

The 2011 Resource Plan reflects a continuation of a long standing corporate policy of economically developing sustainable local resources to reduce and avoid, where possible, the need to generate power with diesel. Further, given current realities added attention is directed at securing options that can assist in reducing the high greenhouse gas (GHG) emissions² associated with diesel generation no matter where it occurs in Yukon.

- **In Yukon, traditional energy policy objectives have focused on development, where economically feasible, of local resources instead of importing diesel fuel** - Prior to Yukon Energy's acquisition of the Northern Canada Power Commission (NCPC) assets in Yukon, NCPC utilized major industrial mine developments at Keno and Faro to develop hydro and transmission assets to displace imported diesel fuel. Subsequently, Yukon Energy (with the help of its parent Yukon Development Corporation (YDC)) has studied and assessed various supply options which can be used to avoid the use of diesel generation including enhancing existing infrastructure, potential wind , new hydro and geothermal supply options. Specifically within the last decade, Yukon Energy has enhanced existing assets by developing the Mayo-Dawson and Carmacks-Stewart transmission lines and by enhancing both the Mayo and Aishihik hydro facilities. Yukon resource planning, however, must still reflect the lack of connection to an external grid - a factor that prevents external sale of surplus renewable generation as well as import of external market-priced energy supplies.
- **Reliability of electricity supply remains a fundamental requirement for resource planning** - Notwithstanding the ongoing objective to displace imported diesel fuel required to meet ongoing energy requirements, reliance on diesel generation has continued to play a major

² GHG emissions refer to gas emissions that absorb and emit radiation at specific wavelengths within the spectrum of infrared radiation emitted by the Earth's surface, the atmosphere and clouds (see Environment Canada web site - climate change).The 2011 Resource Plan estimates of GHG emissions from various resource options primarily reflect available estimates of combined carbon dioxide, methane and nitrous oxide emissions.

part in resource planning for reliability and peaking. Capacity reliability planning for the grids must provide sufficient reserve capacity not to exceed a Loss of Load Expectation of 2 hours/year and to protect customers against the largest single contingency (N-1), which for the Whitehorse Aishihik Faro (WAF) grid is loss of the Aishihik-Whitehorse transmission line³.

- **New realities and new resource supply development opportunities** - The hydro surplus in existence in 2006 is no longer available, reflecting faster than expected non-industrial growth combined with new grid-connected industrial loads. Further, most of the hydro enhancement opportunities identified in the 2006 Resource Plan (or subsequent studies in 2007/08) have now been either developed or are currently under active consideration. As a result, in order to displace future diesel energy generation, consideration is now required for new resource supply options that will minimize near-term reliance on diesel and transition toward longer-term development of preferred new renewable generation resources.
- **Over the past several years Yukon Government has pursued economic development policies that support development of the mining sector**⁴ - Support for mining development in Yukon has been ongoing with exploration activity increasing from \$8 million in 2002 to over \$80 million in 2006⁵. In 2010, a record 83,863 claims were staked and over \$150 million was spent in mineral exploration⁶. In 2011, mineral exploration expenditures are expected to exceed \$250 million⁷, a record high⁸. Rapid mining development creates a wide range of related development activities throughout Yukon, including the potential for major increases in Yukon electricity generation within the next 10 to 20 years. In the same way that Yukon's current

³ These concepts are explained in detail in Section 2.3 and Appendix D.

⁴ The former premier noted at the 2011 Round Up, "Yukon's economy is one of the best in Canada, and the minerals industry is a cornerstone of that growth," Fentie said. "We are seeing the industry create many opportunities and benefits for Yukon residents, businesses and communities." "Yukon is one of the top jurisdictions in the world for mining and exploration and we are optimistic about the growth potential for this very important industry". See also <http://www.gov.yk.ca/news/11-013.html>.

⁵ Press releases from 2007 note YG intention to focus on assisting the advanced exploration projects become operating mines. See <http://www.gov.yk.ca/news/2007/07-014.html>.

⁶ Energy Mines and Resources Minister Patrick Rouble noted at the 2011 Round up that Yukon had experienced "a banner year with new mines commencing operation and unprecedented levels of exploration," and "In addition to celebrating our success, we are working to ensure long-term industry growth that will continue to provide important jobs and business opportunities for Yukoners." See <http://www.gov.yk.ca/news/11-013.html>.

⁷ YG Economic Development – Yukon Economic Outlook 2011. See (<http://economics.gov.yk.ca/Files/Economic%20Outlook/Outlook2011.pdf>).

⁸ Recent initiatives to support and foster mining development in Yukon include 2008 amendments to the Quartz Mining Act and Miners Lien Act to provide clarity and certainty for mine development in Yukon. Yukon's then Minister of Energy, Mines and Resources noted, "Yukon's mining sector is a significant contributor to Yukon's economy" and "the Yukon government is committed to encouraging and supporting a sustainable mineral industrial while ensuring that Yukoners receive maximum benefits from our resources". In this regard the Quartz Mining Act was amended to lower exploration costs (while also ensuring royalty rates for mine development are competitive with other Canadian mining jurisdictions. See <http://www.gov.yk.ca/news/2008/08-299.html>.

renewable hydro generation and grid infrastructure reflects the impact of past major mine developments, future electricity supply development in response to new mine developments could shape Yukon electricity infrastructure for decades to come.

POLICY OBJECTIVES & REALITIES GUIDING RESOURCE PLANNING IN YUKON

When considering potential supply options, most jurisdictions in Canada are guided by a set of broad policy objectives set by governments and regulators. The 2006 Resource Plan reflects all relevant government policies including those by way of directions provided under the *Public Utilities Act* or other relevant legislation that comprise the regulatory context in which Yukon Energy operated at that time.

In addition to the above, Yukon Energy is preparing its 2011 Resource Plan within a new industry and government policy environment that was not present in 2006. This, coupled with a new corporate approach to stakeholder engagement, has created a complex planning environment in which future energy projects and planning processes are assessed.

GOVERNMENT OF YUKON ENERGY POLICY AND CLIMATE CHANGE ACTION PLAN

The 2011 Resource Plan is influenced by the *Energy Strategy for Yukon* (2009) and the *Yukon Climate Change Action Plan* (2009). These policies were developed after extensive public consultation and are intended to work together to “address the reduction of greenhouse gas emissions” (*Energy Strategy for Yukon*, page 14).

The most recent Shareholder’s Letter of Expectation from the Government of Yukon to the Yukon Development Corporation (YDC) and Yukon Energy Corporation provides Yukon Energy and its parent corporation (YDC) with direction to work with the Yukon government and other stakeholders on the implementation of the *Energy Strategy for Yukon* and the *Climate Change Action Plan*⁹.

(i) YG Energy Strategy

The Energy Strategy for Yukon focuses on four priorities¹⁰:

- Conserving energy and using it more efficiently;
- Increasing the supply of energy and using it more efficiently;

⁹ Full text of this letter can be found in Appendix B.

¹⁰ Ibid. Pg 2.

- Meeting Yukon's current and future electricity needs; and
- Managing responsible oil and gas development in Yukon.

Within these priorities, a number of strategies and related actions for energy conservation and the development of renewable energy resources are identified. There is also a specific focus on electricity and future energy choices, and Yukon Energy Corporation role in the implementation of electricity-related initiatives.

Energy efficiency and conservation is recognized as the starting point for the Energy Strategy¹¹ both broadly and as it relates to electricity. The Government of Yukon has committed to increasing energy efficiency in the Yukon by 20% by the year 2020¹². The Energy Strategy also identifies as a priority increasing the renewable energy supply by 20% by the year 2020 to reduce fossil fuel use and related greenhouse gas emissions¹³.

¹¹ Ibid. pg. 6.

¹²This objective will be met by reducing the energy consumption in buildings and the transportation sector, promoting the use of energy efficient products and improving the energy efficiency for Yukon government buildings and operations (Energy Strategy pg. 7).

¹³ Ibid, pg 11.

The following chart summarizes the Energy Strategy commitments of most relevance to Yukon Energy's 2011 Resource Plan.

Goal	Strategies
<p>Energy efficiency and conservation will be a priority to reduce energy consumption, energy costs and emissions.</p>	<ul style="list-style-type: none"> • Developing policies that will support energy efficiency and conservation. • Delivering programs to support and demonstrate energy efficiency initiatives that have the potential to reduce greenhouse base emissions and save Yukoners money. • Incorporating long-term energy costs and environmental benefits in capital investment decisions. • Working with other jurisdictions on enhancing the Model Energy Codes for Buildings and for Houses, as well as adding an energy efficiency objective to the National Building Code. • Encouraging the planning and development of energy efficient communities. • Partnering with First Nations and municipalities to improve energy efficiency and conservation in Yukon Communities.
<p>Energy production from renewable sources will be increased to reduce fossil fuel use and greenhouse gas emissions.</p>	<ul style="list-style-type: none"> • Replacing fossil fuels with cleaner, renewable energy sources where possible. • Demonstrating leadership in developing renewable energy infrastructure. • Investing in research and development of renewable energy technology. • Identifying strategic opportunities to develop new renewable energy sources. • Developing a wood based bio-energy industry in Yukon by building a local market for wood energy technologies and wood fuel products. • Encouraging cost-effective, small-scale renewable energy production to foster innovation and diversify Yukon's supply of electricity resources. • Building partnerships with others to leverage funding and share expertise for renewable energy.
<p>Electricity supply will be increased and demand will be managed to meet current and future electricity needs.</p>	<ul style="list-style-type: none"> • Enhancing the supply of electricity and managing demand to ensure access to a secure, reliable and cost competitive source of electricity. • Maximizing the use and efficiency of existing hydroelectric infrastructure. • Increasing and diversifying Yukon's supply of electricity from renewable sources to decrease diesel use and minimize greenhouse gas and air emissions. • Considering renewable energy and cleaner sources such as natural gas for all new electricity generation projects. • Leveraging territorial, federal and private funds in infrastructure investments to meet growing electricity demand and promote economic development. • Informing the public about the true costs of electricity and promoting

Goal	Strategies
	<p>incentives and initiatives to encourage energy efficiency and conservation.</p> <ul style="list-style-type: none"> • Managing electricity demand to reduce energy requirements at peak times. • Working with Yukon Development Corporation, Yukon Energy Corporation and Yukon Electrical Company Limited to develop an improved approach to managing electricity generation and distribution, with the objectives of improving reliability, providing downward pressure on rates, and expanding the system to meet the needs of a growing Yukon economy.
<p>Oil and Gas resources will be developed responsibly for local use within Yukon and export.</p>	<ul style="list-style-type: none"> • Developing an oil and gas sector in a way that will deliver the greatest benefits to Yukon. • Promoting efficiency and conservation for the use of oil and gas resources. • Reducing Yukon’s reliance on imported fossil fuels.
<p>The Energy Strategy for Yukon will set long-term direction and define short term priorities for the Yukon government.</p>	<ul style="list-style-type: none"> • Evaluating potential energy sources to make choices that will provide the greatest benefits for the least costs. • Setting policy direction for energy development, conservation and use. • Incorporating the Strategy’s principles on decision making. • Building partnerships to develop and manage Yukon’s energy resources. • Allocating sufficient resources to implement the Strategy. • Coordinating implementation with the Climate Change Action Plan wherever possible. • Reviewing the Strategy to ensure it remains relevant and current. • Demonstrating progress on priority actions.

(ii) YG Climate Action Plan

The *Climate Change Action Plan* builds on the four goals outlined in the *Climate Change Strategy* and reflects the Yukon government’s belief that “climate change is happening, that human behaviour is a major contributor, and that a coordinated response is needed¹⁴” recognizing that the Yukon is a small jurisdiction and it is important to focus on priority actions that provide the most benefit to the Yukon.

¹⁴ Government of Yukon (2010). Climate Change Action Plan. pg. 6.

The following chart summarizes the *Climate Change Action Plan* commitments of most relevance to Yukon Energy's 2011 Resource Plan.

Goal	Strategies
Enhance Knowledge and understanding of climate change.	<ul style="list-style-type: none"> • Establish a Yukon Research Centre of Excellence. • Establish climate change research study areas. • Develop climate scenarios.
Adapt to climate change.	<ul style="list-style-type: none"> • Complete a Yukon infrastructure risk and vulnerability assessment and determine adaptation strategies in response. • Develop an inventory of permafrost information for use in decision making. • Complete a Yukon water resources risk and vulnerability assessment. • Create a tool to facilitate the connection and distribution of water quantity and quality data. • Conduct a Yukon forest health risk assessment. • Conduct treatments to reduce forest fuel load and protect communities. • Conduct a Yukon forest tree species and vulnerability assessment.
Reduce greenhouse gas (GHG) emissions.	<ul style="list-style-type: none"> • Yukon government's internal operations: cap GHG emissions in 2010, reduce GHG emission by 20% by 2015 and become carbon neutral by 2020. • Report to Yukon government operations through 'The Climate Registry'. • Develop a carbon offset policy for internal operations. • Incorporate environmental performance considerations in the government's procurement decisions. • Government-funded new residential construction will meet GreenHome energy efficiency standards. • Government-funded commercial and institutional, construction and renovation will meet or exceed the LEED Certified Standard for energy efficiency. • Improve energy efficiency and reduce the greenhouse gas emissions of the government's light vehicle fleet. • Implement an environmental stewardship initiative for the Department of Education and Yukon schools. • Establish 'green action committees' in all departments. • Conduct an energy analysis of all Yukon government buildings and complete energy saving retrofits. • Develop best management practices for industry to reduce GHG emissions. • Develop pilot projects to demonstrate home and commercial energy efficiency and heating technology. • Improve access to home energy evaluations by providing evaluator training.

Goal	Strategies
	<ul style="list-style-type: none"> • Develop wood energy opportunities for residential and institutional heating.
Lead Yukon action in response to climate change.	<ul style="list-style-type: none"> • Forecast potential future GHG emissions for Yukon. • Work with federal partners to ensure national GHG inventory is accurate and consistent for Yukon. • Set a Yukon-wide emissions target within two years. • Create a Climate Change Secretariat. • Determine the potential of a Yukon carbon economy. • Incorporate climate change considerations into government decision making. • Create a community engagement forum for taking action on climate change.

CANADIAN ELECTRICAL INDUSTRY LEVEL POLICY INFLUENCES

Yukon Energy is a member of the Canadian Electricity Association (CEA) and as such it agrees to comply with the CEA’s Sustainable Electricity Program as a condition of membership¹⁵. This program is an industry wide initiative and each member utility is responsible for program implementation within their organizations. For the purposes of this program, the CEA has defined sustainability as “pursuing innovative business strategies and activities that meet the needs of members, stakeholders and the communities in which we operate today, while protecting and enhancing the human and natural resources that will be needed in the future.” A three-pillar approach (social- environmental – economic) has been adopted to provide a more holistic approach to sustainability.

The 10 guiding principles of the CEA’s program intended to help member utilities improve their overall sustainable development performance are:

- 1. Environment:** Minimize the adverse environmental impacts of our facilities, operations and businesses.
- 2. Stewardship and Biodiversity:** Manage the environmental resources and ecosystems that we affect to prevent or minimize loss and support recovery.
- 3. Climate Change:** Manage greenhouse gas emissions to mitigate the impact of operations on climate change, while adapting to its effects.

¹⁵ Full details about this program can be found on the CEA website (<http://www.sustainableelectricity.ca>).

- 4. Health and Safety:** Provide a safe and healthy workplace for our employees and contractors.
- 5. Workplace:** Support a fair, respectful and diverse workplace for our employees and contractors.
- 6. Communications and Engagement:** Communicate with and engage our stakeholders in a transparent and timely manner.
- 7. Aboriginal Relations:** Communicate with and engage Aboriginal people in a manner that respects their culture and traditions.
- 8. Economic Value:** Provide economic benefits to shareholders, communities and regions in which we operate.
- 9. Energy Efficiency:** Produce, deliver and use electricity in an efficient manner while promoting conservation and demand side management.
- 10. Security of Supply:** Provide electricity to customers in a safe, reliable and cost effective manner to meet current and future needs.

This program is supported by a set of environmental, social and economic performance indicators that member utilities report on annually to CEA¹⁶.

YUKON ENERGY CORPORATE PRIORITIES

Yukon Government policies that along with the Industry Level Policy Influences have impacted in a material way Yukon Energy's strategic priorities¹⁷ include:

- Optimizing existing infrastructure to improve system reliability and efficiency;
- Developing clean energy solutions to meet growing demand; and
- Engaging Yukoners to better meet future energy needs.

YUKON PUBLIC ENGAGEMENT IN ENERGY PLANNING

As part of Yukon Energy's multi-year public awareness campaign, the corporation completed two public and stakeholder opinion surveys in June 2010 and in early 2011.

¹⁶ A public advisory panel exists to provide an independent opinion to the CEA Board of Directors on the implementation of the program and program implementation will be verified by an external verifier.

¹⁷ Yukon Energy Corporation (2011). 2010 Annual Report. Available at <http://www.yukonenergy.ca>.

The 2010 surveys were designed to understand what Yukoners and the business community knew about the Corporation¹⁸. Over 600 people took part in the 2010 surveys and the following trends emerged:

- Yukoners understand that hydro-generated electricity is the mainstay of power generation in the Yukon, but strongly support the development of alternative energy sources to supplement hydro.
- Yukoners are looking to Yukon Energy to bring forward creative ideas in meeting future energy needs.
- Yukoners strongly support the need for energy conservation and see this as a shared responsibility among the public, the business community and industry.
- While Yukoners have confidence in Yukon Energy's ability to plan, develop and manage the territory's energy needs, there is concern that politicians and vested interest groups can be detrimental to effective, strategic, long-term planning.
- Yukoners want to remain engaged in the discussion around the territory's energy issues and the Yukon Energy's objectives for a clean energy future.

The findings from the first surveys helped Yukon Energy design a public awareness campaign to give Yukoners a better understanding about who Yukon Energy is, what the Corporation is trying to achieve, and why.

The 2011 survey consisted of telephone and online surveys and "pulse polls"¹⁹ targeting the general public and the business community. Many of the questions paralleled questions asked during Phase I to identify changes in knowledge, awareness and views of Yukoners concerning energy related issues. High response rates for the surveys indicate that Yukoners are significantly engaged and interested in energy related issues.

Although there are varying levels of awareness regarding the different resource development projects being considered, there is a general recognition that strategies are needed to increase energy production to meet future demand and that the industrial sector will be the big energy consumer.

¹⁸ The Phase I survey was designed to establish benchmark indicators among target audiences to assess and evaluate knowledge of Yukon Energy and awareness of energy related issues. The research model was built in a knowledge, awareness, and behaviour (KAB) evaluation design. This design begins by testing current knowledge levels, assessing any change in awareness levels over time (e.g., as a result of educational or communications intervention) and determining whether there are any increases in knowledge or changes in beliefs or expectations.

¹⁹ Pulse polls are online questions designed to gather quick "top of mind" responses to a few key issues. These polls were published in the online edition of the Yukon News and on the Yukon Energy website.

Other trends identified include:

- A strong preference for alternative energy and increased energy conservation measures;
- The majority of respondents indicated that expanding alternative energy or a mix of alternative and hydro generation were preferred;
- Only two percent of respondents preferred to expand diesel generation capacity; and
- The issue of paying for alternative energy received a mixed response. While a majority of survey respondents were willing to pay more for alternative energy the majority of “pulse poll” respondents were not willing to pay more than they are currently²⁰.

2011 RESOURCE PLAN & MARCH 2011 ENERGY CHARRETTE

To enhance public understanding of resource planning issues, Yukon Energy engaged Yukoners (along with national and international recognized energy experts) in a three day Charrette planning process in Whitehorse in March, where Yukon’s energy demand situation and potential opportunities, both near-term and long-term, were reviewed. A cross-section of Yukoners representing various interests was invited to participate in the three day process.

Prior to the Charrette, community meetings were held in three Yukon communities (Mayo, Dawson City and Haines Junction) to learn about electrical energy concerns at the community level. In addition, stakeholder interviews were carried out involving approximately 50 individuals and representatives from a broad array of organizations, agencies and government departments²¹.

The Charrette resulted in the development of four energy planning principles²²:

- Reliability;
- Affordability;
- Flexibility; and

²⁰ The results of the business surveys indicated increased confidence in Yukon Energy’s ability to assess future energy needs. Business/ community leaders also expect the availability of power to get worse within the next five years. There was some willingness to pay more for renewable energy with 10 percent saying they would pay one to two percent more and 42 percent willing to pay up to five percent more.

²¹ The Charrette’s expert background reports, presentations, summaries of community and stakeholder consultations and summaries of the Charrette are all available on Yukon Energy’s web site.

²² A more complete discussion of these principles can be found in Section 1.

- Environmental Responsibility.

Yukon Energy has committed to continue engaging Yukoners in resource planning, including an opportunity to comment on the draft 2011 Resource Plan. To this end, a draft 2011 Resource Plan has been prepared for public comment.

In addition to the principles, the participants talked about energy ideas discussed with experts and each other. They learned about the Yukon's planning realities, the resource planning options and the risks and uncertainties which make planning for Yukon's energy future challenging.

From the beginning Yukon Energy set out to engage Yukoners to find the answers together. Outcomes of the Charrette include:

- Yukoners are talking about energy;
- Yukoners have a better understanding of Yukon Energy planning realities and future resource options;
- Yukon Energy has energy resource background papers specifically prepared considering the Yukon context for hydro, demand side management, biomass, wind, natural gas, diesel, coal and thermal, waste to energy, storage and transmission, nuclear, geothermal and solar;
- Yukoners learned that the obligation to serve is a risk and uncertainty that other utilities across Canada share and plan for;
- Yukoners want energy decisions to consider more than just cost;
- Future energy options must be affordable, reliable, flexible and environmentally responsible;
- Energy conservation must be considered as the key resource planning option in the short-term;
- Along with exploring new hydro, hydro enhancements, wind at Ferry Hill, geothermal and waste to energy, Yukon Energy should also investigate possible options such as biomass, wind, solar and liquefied natural gas;
- Yukon Energy should explore the local beetle kill forest as fuel for biomass;
- Yukon ratepayers may need to pay more for their electricity if the rates are to better reflect the true cost;
- The next 20-Year Resource Plan must reflect what was heard at the Charrette;

- Yukon's youth (as represented by Experiential Science 11) want to be engaged and part of Yukon's energy solution; and
- Yukon Energy must continue to work with Yukoners to find the answers together.

TABLE OF CONTENTS

1.0	RESOURCE PLANNING PRINCIPLES, CONTEXT & CHALLENGES	1
1.1	RESOURCE PLANNING PRINCIPLES FOR YUKON	1
1.2	CAPACITY AND ENERGY PLANNING CONTEXT	3
1.3	CHARACTERISTICS OF EXISTING YUKON GRID	4
1.4	CURRENT RESOURCE PLANNING CHALLENGES & OPPORTUNITIES IN YUKON	9
2.0	FORECAST LOAD REQUIREMENTS & CHALLENGES.....	14
2.1	BACKGROUND AND CONTEXT	15
2.2	OVERVIEW OF POTENTIAL YUKON LOADS: 2011-2050	19
2.3	2011 RESOURCE PLAN GRID LOAD SCENARIOS: 2011-2030	29
2.3.1	FORECAST GRID ENERGY REQUIREMENTS 2011-2030	30
2.3.2	FORECAST GRID CAPACITY REQUIREMENTS: 2011-2030	38
2.4	CAPACITY & ENERGY RELATED CHALLENGES FOR EXISTING GRID UNDER FORECAST LOADS.....	45
3.0	RESOURCE PLANNING OPTIONS – OVERVIEW AND SCREENING	57
3.1	INTRODUCTION	57
3.2	SCREENING OF CURRENT RESOURCE OPTIONS	58
3.2.1	“NEAR-TERM”, “LONG-TERM HYDRO” AND “LONG-TERM OTHER” RESOURCE OPTIONS	58
3.2.2	KEY PLANNING PRINCIPLE CHARACTERIZATION OF RESOURCE OPTIONS	66
3.3	OVERVIEW OF SUBSEQUENT SECTIONS	70
4.0	DEFAULT DIESEL PORTFOLIO	74
4.1	DEFINING THE PORTFOLIO	74
4.2	GRID ECONOMIC IMPACTS.....	79
4.3	YUKON GREENHOUSE GAS EMISSIONS IMPACT	84
4.4	LONG-TERM DEVELOPMENT CONSIDERATIONS	88
5.0	MINIMUM GREENHOUSE GAS EMISSIONS PORTFOLIO OPTIONS.....	91
5.1	DEFINING THE PORTFOLIO OPTIONS.....	91
5.1.1	AVAILABLE NEAR-TERM RESOURCE OPTIONS	91
5.1.2	AVAILABLE LONGER-TERM RESOURCE OPTIONS	94
5.1.3	NEAR-TERM PORTFOLIO OPTIONS	97
5.2	GRID ECONOMIC IMPACTS.....	121
5.3	YUKON GREENHOUSE GAS EMISSIONS IMPACT	129
5.4	LONG-TERM DEVELOPMENT CONSIDERATIONS	134
5.5	CONCLUSIONS	146
6.0	LNG TRANSITION PORTFOLIO OPTIONS	149
6.1	DEFINING THE PORTFOLIO OPTIONS.....	149
6.1.1	BACKGROUND ON CURRENT LNG SUPPLY OPPORTUNITIES FOR YUKON	149
6.1.2	BACKGROUND ON LNG OPPORTUNITIES IN YUKON	152
6.1.3	ASSUMED NEAR-TERM RESOURCE OPTIONS	158
6.1.4	NEAR-TERM PORTFOLIO OPTIONS	164
6.2	GRID ECONOMIC IMPACTS.....	168

6.3	YUKON GREENHOUSE GAS EMISSIONS IMPACT	170
6.4	LONG-TERM DEVELOPMENT CONSIDERATIONS	173
6.5	CONCLUSIONS	175
7.0	RESOURCE PLAN SUMMARY CONCLUSIONS	179
7.1	CHALLENGES AND OPPORTUNITIES	179
7.2	FORECAST YUKON REQUIREMENTS – DEFAULT DIESEL PORTFOLIO OPTION	180
7.3	PORTFOLIO OPTIONS TO DEFAULT DIESEL	186
7.4	SUMMARY CONCLUSIONS & NEXT STEPS.....	198

LIST OF TABLES

Table 2-1:	Yukon Industrial Development Opportunities.....	34
Table 2-2:	Forecast Hydro Generation and Diesel Generation under Forecast Grid Loads: Base Case, Scenario A and Scenario B	38
Table 2-3:	Current Integrated Grid Generating Complement.....	42
Table 3-1:	Range of Resource Supply Options & Initial High Level Characterization	72
Table 4-1:	Forecast Grid DSM/SSE & Diesel Generation by Load Scenario – 2011-2030 (GW.h/year).....	77
Table 4-2:	Default Diesel Portfolio Option Present Value Grid Costs (2010\$million): 2011-2030	83
Table 5-1:	Summary of Potential Hydro Sites.....	96
Table 5-2A:	Minimum GHG Emissions Portfolio Option BC #1 - Forecast Grid Diesel Generation Displaced by Load Scenario DSM/SSE, Marsh Lake Storage and Gladstone: 2011 -2030 (GW.h/year).....	100
Table 5-2B:	Minimum GHG Emissions Portfolio Option BC #1 Present Value Costs: 2011-2030 (2010\$million).....	101
Table 5-3A:	Minimum GHG Emissions Portfolio Option BC #2 - Forecast Grid Diesel Generation Displaced by Load Scenario DSM/SSE, Marsh Lake Storage and 10.5 MW Wind: 2011 - 2030 (GW.h/year)	102
Table 5-3B:	Minimum GHG Emissions Portfolio Option BC #2 Present Value Costs: 2011-2030 (2010\$million).....	103
Table 5-4A:	Minimum GHG Emissions Portfolio Option BC #3 – Forecast Grid Diesel Generation Displaced by Load Scenario DSM/SSE, Marsh Lake Storage and 2.2 MW WTE: 2011 -2030 (GW.h/year).....	104
Table 5-4B:	Minimum GHG Emissions Portfolio Option BC #3 Present Value Costs: 2011-2030 (2010\$million).....	105
Table 5-5:	Diesel Displaced by Renewable Resource Option - 2015-2019 Percent of Potential Annual Diesel Displacement (%).....	106
Table 5-6A:	Minimum GHG Emissions Portfolio Option A/B #1 Forecast Grid Diesel Generation Displaced by Load Scenario DSM/SSE, Marsh Lake Storage & 15 MW Biomass: 2011-2030 (GW.h/year).....	117
Table 5-6B:	Minimum GHG Emissions Portfolio Option A/B #1 Present Value Costs: 2011-2030 (2010\$million).....	117
Table 5-7A:	Minimum GHG Emissions Portfolio Option A/B #2 Forecast Grid Diesel Generation Displaced by Load Scenario DSM/SSE, Marsh Lake Storage & 21 MW Wind and 2.2 MW WTE: 2011-2030 (GW.h/year).....	118
Table 5-7B:	Minimum GHG Emissions Portfolio Option A/B #2 Present Value Costs: 2011-2030 (2010\$million).....	118
Table 5-8A:	Minimum GHG Emissions Portfolio Option A/B # 3 Forecast Grid Diesel Generation Displaced by Load Scenario DSM/SSE, Marsh Lake Storage & Gladstone Diversion, 21 MW Wind: 2011-2030 (GW.h/year)	119
Table 5-8B:	Minimum GHG Emissions Portfolio Option A/B # 3 Present Value Costs: 2011-2030 (2010\$million).....	119
Table 5-9A:	Minimum GHG Emissions Portfolio Option A/B #4 Forecast Grid Diesel Generation Displaced by Load Scenario DSM/SSE, Marsh Lake Storage & Gladstone Diversion & 21 MW Wind and 2.2 MW WTE: 2011-2030 (GW.h/year).....	120

Table 5-9B:	Minimum GHG Emissions Portfolio Option A/B # 4 Present Value Costs: 2011-2030 (2010\$million).....	120
Table 5-10:	Forecast LCOE (cents/kW.h in 2010\$) for Minimum GHG Emissions Non-Diesel Portfolio Options (excludes diesel costs) – Base Case Load Options	121
Table 5-11:	Forecast LCOE (2010\$) for Minimum GHG Emissions Non-Diesel Portfolio Options (excludes diesel costs) – Scenario A and B Load Options.....	122
Table 5-12:	Present Value Costs (2010\$million) - Minimum GHG Portfolio Options & Diesel Base Case Load	125
Table 5-13:	Present Value Costs (2010\$million) - Minimum GHG Portfolio Options & Diesel Scenario A and B Loads	128
Table 5-14:	Yukon Industrial Load Opportunities and Potential Hydro Sites	138
Table 6-1:	LNG (2015) LNG Transition Portfolio Option #1 (LNG on its own) Present Value Costs: 2011-2030 (2010\$million)	167
Table 6-2:	LNG (2015) LNG Transition Portfolio Option #2 (LNG & Marsh Lake) Present Value Costs: 2011-2030 (2010\$million)	167
Table 6-3:	LNG (2015) LNG Transition Portfolio Option #3 (LNG and Marsh & Gladstone) Present Value Costs: 2011-2030 (2010\$million).....	168
Table 6-4:	Present Value Costs (2010\$million) - LNG Transition Portfolio Options & Diesel	169
Table 7-1	Forecast Yukon Diesel Energy Generation Requirements: 2011-2030 (Potential Off-Grid Mine Generation includes LNG & Diesel)	181
Table 7-2:	Overview of Resource Portfolio Near-Term Options Scenario A with DSM/SSE: 2011-2030.....	191

LIST OF FIGURES

Figure 1-1:	Illustrative Seasonal Electricity Demand and Hydroelectric Supply	7
Figure 1-2:	Existing Yukon Power Infrastructure, Potential Supply Options, and Active & Potential Mine Loads	13
Figure 2-1:	Historical Grid Non-Industrial and Industrial Sales – 1994-2010 (GW.h/year)	15
Figure 2-2:	Yukon Grid Generation – 1994-2010 (GW.h/year).....	16
Figure 2-3:	Yukon Grid & Off-Grid Diesel Generation – 1994-2010 (GW.h/year).....	18
Figure 2-4:	Existing System Capability to Supply Potential Grid Load & Potential Off-Grid Mine Loads: 2011-2050	21
Figure 2-5:	Potential Off-Grid Mine Loads – 2010-2030 (GW.h).....	24
Figure 2-6:	Yukon Exploration Projects 2010	35
Figure 2-7:	Forecast Grid Loads: Base Case, Scenario A and Scenario B	36
Figure 2-8:	Scenario B Forecast Grid load/Hydro Supply Gap: 2011-2030	37
Figure 2-9:	Grid Capacity Capability & N-1 Capacity Requirements – 2011-2030 (MW)	41
Figure 2-10:	Grid Capacity Capability Requirements – 2011-2030 (MW)	44
Figure 2-11:	YEC Grid Electricity Seasonal Generation by Source: Mean Flows (average of all water years) at 545 GW.h/year Grid load net of Fish Lake and Wind	48
Figure 2-12:	YEC Grid Electricity Seasonal Generation by Source: Mean Flows (average of all water years) with 21 MW Wind Project Displacing Diesel and Displacing Hydro at 545 GW.h/year Grid Load (Scenario A 2015-16 load).....	50
Figure 2-13:	YEC Grid Electricity Seasonal Generation by Source: Mean Flows (average of all water years) with 25 MW Wood Biomass Project Displacing Diesel and Displacing Hydro at 545 GW.h/year Grid Load (Scenario A 2015-16 load).....	52
Figure 2-14:	YEC Annual Grid Diesel Generation Variability at Different Grid Loads (GW.h/yr)	54
Figure 3-1:	Location of Existing Grid, Potential Hydro Sites, and Various Existing & Potential Mines ..	73
Figure 4-1:	Diesel Energy Requirements (Grid & Off-Grid Utility) for Resource Plan Scenarios: 2011-30	76
Figure 4-2:	New Diesel Grid Capacity Requirements for Resource Plan Scenarios: 2011-30.....	78
Figure 4-3:	Grid & Off-Grid Diesel Community Power Generation GHG Emissions (tonnes/year) 2012-2030 with assumed DSM/SSE	85
Figure 4-4:	Total Yukon Non-Renewable Generation (Grid & Off-Grid): 2011-2030	88
Figure 5-1:	Wood Biomass 25 MW Thermal Project Displacing Diesel & Hydro at Scenario A Load with DSM/SSE (current forecast mine life, no mine loads after 2021)	110
Figure 5-2:	Summary LCOE (2010\$) for Thermal Wood Biomass Plant Options at Scenario A Load with DSM/SSE	111
Figure 5-3:	Forecast LCOE (2010\$) - 15 MW Wood Biomass, 21 MW Wind, 10.5 MW Wind, 2.2 MW WTE and Marsh Lake & Gladstone - Scenario A Load with DSM/SSE	115
Figure 5-4:	Wind Project: Displacing Diesel and Hydro at Scenario A Load with DSM/SSE (current forecast mine life, no mine loads after 2021).....	116
Figure 5-5:	Change in PV Costs (%) Minimum GHG Portfolio Options Compared to Default Diesel Portfolio – Base Case Load	124
Figure 5-6:	Change in PV Costs (%) Minimum GHG Portfolio Options Compared to Default Diesel Portfolio – Scenario A and B Loads	127
Figure 5-7:	Grid GHG Reductions: Minimum GHG Emissions Portfolio Options – Base Case Load 2012-2030.....	130

Figure 5-8:	Grid GHG Reductions: Minimum GHG Emissions Portfolio Options – Scenario A Load 2012-2030	131
Figure 5-9:	Grid GHG Reductions: Minimum GHG Emissions Portfolio Options – Scenario B Load 2012-2030	132
Figure 5-10:	GHG Reductions – Minimum GHG Portfolio Options (Scenario A with DSM/SSE) Relative to Total Yukon GHGs for Power Generation (grid and off-grid).....	133
Figure 5-11:	Overview of Planning Activities for Greenfield Hydro Supply Option Development - 2011-2021	145
Figure 6-1:	Comparison of LNG Supply Options (Kitimat & Fort Nelson) with Diesel	157
Figure 6-2:	Forecast LCOE (2010\$) – Fort Nelson LNG Supply and Kitimat LNG Supply – Scenario A Load with DSM/SSE	163
Figure 6-3:	LNG Thermal Plant vs. Diesel Fuel & O&M Costs per kW.h – 2015-2020.....	164
Figure 6-4:	Forecast LCOE (2010\$) for LNG Resource Option – Various Load Scenarios.....	165
Figure 6-5:	Annual Costs per kW.h for LNG & Other Resource Options – 2015-2020	166
Figure 6-6:	Change in PV Costs (%) LNG Transition Portfolio Options Compared to Default Diesel..	170
Figure 6-7:	Portfolio Option Yukon GHG (tonnes/year) – 2015-2030: Grid Scenario A with DSM/SSE, Off-Grid Diesel Community, & Off-Grid Mines	173
Figure 7-1:	Existing System Capability to Supply Potential Grid Load & Potential Off-Grid Mine Loads: 2011-2050	182
Figure 7-2:	Portfolio Option Yukon GHG (tonnes/year) – 2015-2030 Grid Scenario A with DSM/SSE, Off-Grid Diesel Community, & Off-Grid Mines	193
Figure 7-3:	Overview of Planning Activities for Greenfield Hydro Supply Option Development - 2011- 2021.....	197

1.0 RESOURCE PLANNING PRINCIPLES, CONTEXT & CHALLENGES

1.1 RESOURCE PLANNING PRINCIPLES FOR YUKON

(i) Overarching YG Energy Policy²³

The Yukon Government's *Energy Strategy for Yukon* sets out a vision and principles for Yukon that includes development of a "sustainable and secure energy sector that is environmentally, economically and socially responsible". The *Energy Strategy* recognizes that "investment in electricity infrastructure will leverage economic development for the territory" and renewable energy infrastructure will "enhance the kinds of long-term legacy benefits that are currently enjoyed with the existing hydro system," and serve to "buffer Yukon's energy sector from volatile fossil fuel prices and help to minimize greenhouse gas emissions from diesel generated electricity".

(ii) Key Yukon Electricity Resource Planning Principles

The March 2011 Charrette participants agreed on the fundamental importance of four key principles for electricity resource planning in Yukon:

1. **Reliability²⁴** – Reliable supply for power utility customers today and in the long-term. This includes short-term reliability to keep the lights on, ensure sufficient supply to meet winter peak loads (reliable capacity), and minimize the number and duration of any power outages. When assessing new resource options, reliability includes security of the resource supply and the ability to develop new resource options in a timely manner as needed to meet near-term requirements in a cost effective manner.
2. **Affordability** – Minimize electricity costs for customers today and in the long-term²⁵.
3. **Flexibility** – Flexibility to deal with major and sudden changes in grid loads. In light of ongoing load uncertainties, new resource supply options need to be resilient and robust under various potential load scenarios²⁶.

²³ See Preface for a more detailed review of YG policy context for the Resource Plan.

²⁴Yukon Energy's 2010-12 Strategic Plan notes, "the first strategic priority is to improve system efficiencies and system reliability. New investments and procedural changes are being put in place. In the next two to five years we hope to achieve a seventy-five percent reduction in controllable outages (unplanned and not caused by nature)".

²⁵ The Yukon Utilities Board regulates the costs to be recovered through rates, focusing on need, justification, and the reasonableness of costs incurred – and with a clear objective to minimize the costs required to serve customers today and in the future.

1 **4. Environmental Responsibility** – Responsibility with regard to local and global socio-economic
2 impacts and environmental impacts on land, water, and air. This principle includes, but goes
3 beyond, responsible planning to mitigate and manage socio-economic and environmental impacts
4 as required by various regulatory authorities. Yukon Energy is committed to plan for energy
5 solutions that reduce greenhouse gas emissions (GHGs), and meet Yukon, national and global
6 climate change action plans²⁷, and that follow the Yukon Government’s Energy Strategy. That
7 strategy “supports a shift towards cleaner, renewable sources of energy”, and seeks to increase
8 energy production from renewable resources and reduce fossil fuel use and GHG emissions
9 through replacing fossil fuels with cleaner, renewable energy sources²⁸ where possible²⁹.

10 Additional principles noted at the Charrette included provision for local jobs and energy security – where
11 feasible, there was a preference to utilize resources that were locally available (e.g., wood biomass such
12 as beetle kill timber near Haines Junction) as well as technologies that Yukon is familiar with (e.g.,
13 Hydro).

14 ***(iii) Challenge of Balancing Key Principles***

15 In applying these key principles, no one principle takes precedence or is given greater weight than any
16 other. The objective is to achieve an appropriate balance within the existing Yukon policy framework³⁰
17 using professional judgment based on Yukon realities and reasonably forecast near-term and longer-term
18 requirements.

²⁶ Resource planning must be attentive to the reality that loads will not grow at continuous rates in the future but (as experienced in the past) will likely come on and off the system in lumps to the extent that mine loads are connected to the grid. Because Yukon is not interconnected with grids in other provinces/jurisdictions, surplus energy in Yukon cannot be exported, and Yukon needs also cannot be met through energy imports. This reality means that sudden loss of mine loads can therefore result in major rate increases for the remaining customers to the extent that ongoing fixed generation or transmission costs remain to be funded. Sudden addition of new mine loads can also result in major rate increases for all existing customers to the extent that no surplus renewable resources can be utilized and lower cost new supply options are not readily available.

²⁷Yukon Energy’s Strategic Plan: 2010-2012 notes, “our next priority is to meet demand with clean energy”. Yukon Energy’s 2010-12 Strategic Plan also notes “Renewable sources include hydro, wind, geothermal and solar and some potential clean sources include biomass and natural gas.” “It is essential that Yukoners continue to use oil and gas resources efficiently and replace them with cleaner or renewable energy sources whenever it is practical to do so.”

²⁸ Renewable resources in this respect include: hydro, wood, wind, solar and geothermal energy sources. Natural gas is considered to be a “cleaner” energy resource.

²⁹ Yukon Government’s Energy Strategy notes, “the Yukon government recognizes that oil and gas will continue to be a significant component of Yukon’s energy mix and energy resources for the foreseeable future”, “the government is committed to ensuring the oil and gas sector will deliver optimal benefits to Yukon” and “ will encourage the use of Yukon’s resources to replace imported produces” as part of “overall efforts to rely on local energy sources where possible to ensure a stable and secure supply of energy for Yukon.”

³⁰ This includes Yukon’s Energy Strategy and the Yukon Climate Change Action plan and any other relevant government policies or directions, as well as Yukon Energy’s Strategic Plan.

1 As Dr. Mark Jaccard noted during the Charrette:

2 "Like other jurisdictions, Yukoners want energy services that are affordable, reliable and
3 environmentally responsible. But the Yukon's isolated grid and the substantial but uncertain
4 energy needs from mining activity mean that energy system flexibility has a high value in Yukon
5 too."

6 **1.2 CAPACITY AND ENERGY PLANNING CONTEXT**

7 As the main generator and transmitter of electrical power in the Yukon region, Yukon Energy plans the
8 capacity and energy electric power requirements:

- 9 • **Capacity planning** - Focuses on the highest or peak megawatt (MW) generation capability
10 (capacity) required on each system during each year, including sufficient reserve capability
11 (based on the system's capacity planning criteria) to address generation and transmission unit
12 breakdowns.
- 13 • **Energy planning** - Focuses on the number of kilowatt hours (kW.h) of electricity that are
14 required to be generated over the course of a year on each system.

15 The 2011 Resource Plan develops a roadmap that guides Yukon Energy's ability, working with others, to
16 develop clean and renewable legacy generation and transmission resources while effectively addressing
17 current power needs³¹. Consistent with Yukon Energy's 2006 Resource Plan, the plan focuses on near-
18 term requirements and longer-term opportunities (to be addressed during the next five years) as follows:

- 19 • **Near-term requirements by 2014** - Yukon Energy generation and transmission commitments
20 required before the end of 2014 for major investments with anticipated costs of \$3 million or
21 more. Given the time needed for possible construction, this assessment examines possible in-
22 service needs to meet loads to 2017.
- 23 • **Longer-term opportunities before 2021** - Appropriate Yukon Energy planning activities
24 required during the next five years to protect longer-term legacy resource development options
25 for potential start of construction *before* 2021.

³¹ The 2006 Yukon Energy 20-Year Resource Plan addressed major electrical generation and transmission requirements and options in Yukon during the 2006-2025 period, focusing on Yukon grids. It was reviewed and recommended by the Yukon Utilities Board in its January 2007 Report to the Minister. One of the Board's recommendations was that the 2006 Resource Plan be updated every five years.

- 1 • **Longer-term opportunities after 2021:** Appropriate Yukon Energy planning activities
2 required during the next five years to protect longer-term legacy resource development options
3 for potential development *after* 2021.

4 **1.3 CHARACTERISTICS OF EXISTING YUKON GRID**

5 The new integrated grid, including the new Mayo B and Aishihik 3rd Turbine hydro units, has 142 MW of
6 installed generation of which approximately 77 MW can be relied upon for the winter peak.

7 The existing diesel infrastructure³² is utilized today primarily as reserve capacity to meet peak or short-
8 term emergency needs - however, it remains available as well to provide baseload energy as required³³.
9 Although the grid has ample diesel infrastructure to supply reliable energy when hydro capability is fully
10 utilized, reliance upon diesel generation to supply energy requirements in excess of hydro capability has
11 high cost and emission impacts. Accordingly, a primary focus of the Resource Plan is the examination of
12 more affordable and environmentally responsible supply options which have the capability to displace
13 diesel energy generation.

14 Key features of the current Yukon system include:

- 15 • Current Yukon population is approximately 35,000³⁴, roughly 76% of whom are in Whitehorse.
16 The small population means there is a lower overall ratebase over which to share costs of
17 facilities required to meet growth on the system (whether those costs are due to need for
18 increased baseload diesel or new renewable generation).
- 19 • Over 94% of the Yukon population is served today by hydro generation on the Yukon Energy
20 hydro grids (Integrated System grid now includes Whitehorse-Aishihik-Faro [WAF], Carmacks-
21 Stewart [CS], and Mayo-Dawson [MD] transmission). Watson Lake, Destruction Bay, Beaver
22 Creek, Swift River and Old Crow are each served by Yukon Electrical's isolated diesel generation.
- 23 • Diesel generation facilities account today for 57% of reliable utility capacity to serve the grid
24 winter peak and all of utility capacity for the five separate off-grid diesel communities served by

³² The existing diesel infrastructure is reviewed in Appendix A.

³³ At 90% capacity factor the existing 44.2 MW of grid diesel capacity could potentially provide almost 350 GW.h per year of electricity.

³⁴ Yukon Bureau of Statistics, June 2011 –Yukon population estimated at 35,175; Whitehorse population at 26,711 or 75.9% of Yukon population.

1 Yukon Electrical. Diesel generation also currently supplies off-grid industrial mine projects (e.g.,
2 Wolverine mine) not supplied by Yukon power utilities.

3 • The Integrated System grid is isolated from grids outside of Yukon such as BC and Alaska.

4 ○ The isolated nature of the existing Yukon grid system means that when large industrial
5 loads come on and off the grid system there can be material electric utility revenue and
6 cost impacts, and therefore rate impacts for other customers. In the past, due to the
7 historic investment in material capital intensive assets mine loads (e.g., Faro mine or
8 UKHM) leaving the system led to material rate impacts and surplus hydro generation.

9 ○ The isolated nature of the Yukon grid also prevents any export sale of surplus Yukon
10 renewable generation or import of electricity when Yukon supplies are constrained, and
11 therefore careful attention must be paid to matching the development opportunity with
12 forecast loads.

13 ○ This Yukon reality is significantly different than exists with southern grids such as in
14 British Columbia³⁵.

15 Continued reliance on the existing grid system to deal with load growth means, unless other viable
16 alternatives are found, an increasing need to rely on more costly diesel generation to meet energy loads
17 over the near and longer-term.

18 • The predominance of hydro generation on the Yukon system, combined with the fact that Yukon
19 is isolated from other grids outside the territory, means that other forms of backup capacity are
20 required to supplement available hydro to meet the system's winter/spring seasonal generation
21 constraints, and to provide reliable energy generation in drought years.

22 ○ **Winter constraints** - Seasonal water storage is typically needed for hydro facilities to
23 be fully utilized in winter. In Yukon, controlled seasonal storage exists at Aishihik and to
24 a much lesser extent at Mayo, but is largely unavailable at Whitehorse. As a result, there
25 is an increasing need to rely on diesel generation to meet baseload energy loads in
26 winter and early spring when grid loads are highest and hydro water flows are
27 constrained.

³⁵ Inability to market surplus renewable generation, for example, constrains Yukon ability to accommodate in a cost effective way long-term renewable resource contracts with independent power producers (IPPs) in the same way as such arrangements are made in British Columbia, and means that such long-term contracts may not fit easily with the current requirements of the Yukon system.

1 ○ **Summer constraints** - In contrast, until loads increase to much higher levels, little if
2 any diesel generation is likely to be required during summer and fall when the
3 Whitehorse hydro units actually have surplus hydro generation (because of lower loads
4 and high water levels from summer fall runoff).

5 These system characteristics undermine the cost effectiveness of capital-intensive
6 renewable resource options to displace diesel generation, unless such options focus their
7 new generation in winter (i.e. generation from these resources are not needed and
8 therefore cannot be utilized in the summer and fall because of the surplus hydro that
9 exists on the system).

10 ○ **Drought-flood year constraints** - In addition to seasonal supply constraints, systems
11 predominantly based on hydro generation resources such as the Yukon grid are
12 vulnerable to drought (low water) conditions, and in these circumstances hydro
13 generation must be supplemented by other reliable forms of generation³⁶. Hydro-based
14 systems must also anticipate flood (high water) conditions (where the need to rely on
15 other reliable forms of generation will be greatly diminished or eliminated).

16 This high variability based on available water in combination with the isolated nature of
17 the Yukon Grid undermines the cost effectiveness of capital-intensive renewable resource
18 options developed to displace diesel generation unless they are flexible to this inherent
19 hydro based system variability.


20 Accordingly, assessments of the viability of diesel displacement opportunities must fully consider
21 these constraints.

22 Figure 1-1 highlights the widely varying seasonal levels of demand and hydro supply at the Whitehorse
23 generating facility³⁷. Winter, which is in the middle of the figure, shows that when demands tend to peak
24 the hydro supplies at Whitehorse tend to be most constrained.

³⁶The requirement for thermal resources to back up hydro resources exists even in interconnected systems such as Manitoba (which continues to include a small amount of thermal generating resources in its power resource plan) and British Columbia (e.g., the Burrard generating station).

³⁷ Seasonal hydro storage can enhance winter hydroelectric generation at Aishihik and Mayo generating facilities relative to Whitehorse – but the overall seasonal swings of demand and hydro supply remain a key feature of the existing Yukon grid system.

1 **Figure 1-1: Illustrative Seasonal Electricity Demand and Hydroelectric Supply**



2

3 Under the Public Utilities Act and related regulatory principles Yukon Energy has an obligation to serve all
 4 customers that seek service within its franchise area. In relation to industrial customers this obligation is
 5 subject to certain limitations i.e., Yukon Energy is not required to serve a new industrial customer unless
 6 that customer is prepared to fund directly the interconnection costs and risks required for Yukon Energy
 7 to connect the new load to the grid³⁸. As a result, new major industrial customers located far from the
 8 current grid would in all likelihood not be added to the Yukon system primarily because of the costs of
 9 interconnection. In those circumstances new major industrial loads would typically be supplied by isolated

³⁸ Following the 2006 Resource Plan review by the YUB, Yukon Energy has received YUB approval for Power Purchase Agreements (PPAs) for the Minto mine and the Alexco mine - these PPAs have established a range of new measures to manage risks related to serving new industrial customer connections to the grid, including those noted here and in Appendix B. Similar PPAs would be required prior to connecting future potential mines such as Victoria Gold and Carmacks Copper (in the case of Carmacks copper, a material contribution would also be required towards the capital costs incurred for the Carmacks-Stewart Transmission Project). Appendix B also reviews other measures that Yukon Energy has adopted in the past to manage ratepayer risks related to development of legacy renewable resources on the grid, including flexible debt financing to manage overall load shift impacts on capital costs charged to ratepayers, third party financing to reduce ratepayer impacts related to such capital investments, and special funds used to manage other utility risk related to changes in circumstances (e.g., low water/drought risks and diesel fuel price variability risk).

1 on-site diesel generation with all costs excluded from YUB consideration in rate setting for utility
2 customers served on the grid or in off-grid communities.

3 In addition to these Yukon system realities the planning context within which the 2011 Resource Plan is
4 being developed is also materially different than in 2006.

- 5 • The WAF capacity shortfall that was pending in 2005 has been addressed. The capacity of the
6 interconnected WAF and MD grids is now more than adequate to serve current winter peak
7 loads³⁹.
- 8 • Since 2005, the material hydro surplus has been nearly fully utilized because of greater than
9 expected non-industrial load growth, and the interconnection of the Minto (2008) and Alexco
10 (2010) mines⁴⁰.
- 11 • Since 2005/06, most of the hydro enhancement opportunities identified in the 2006 Resource
12 Plan or in 2007/08 Yukon Energy studies have now been either developed or are currently under
13 active consideration. As a result consideration is required of new renewable resource supply
14 options so that diesel energy generation is not by default relied upon to meet increasing future
15 incremental loads. Pursuing new greenfield resources limits supply options available in the near-
16 term, and requires extensive planning through the next five years to protect any priority new
17 legacy renewable clean resource supply options that might be needed or preferred by 2021.

³⁹ Yukon Energy's 2006 Resource Plan proposed new generation capacity planning criteria, and forecast significant WAF generating capacity shortfalls based on these criteria as early as 2007 and 2008. To address these winter peak generating capacity shortfalls, a planning sequence was set out in the 2006 Resource Plan proceeding that secured cost effective options for up to 25.4 MW of WAF capacity in a staged and flexible manner comprised of recommissioning a 5 MW Mirrlees unit at Faro, acquisition of 6.4 MW of diesel units at Minto, plus staged refurbishment of up to three Mirrlees units at Whitehorse (totalling 14 MW) over the period to 2012. With the 2008/2009 GRA (and Order 2009-8) YEC has determined not to proceed with the purchase of the Minto diesels.

⁴⁰In 2005, surplus hydro generation on WAF prior to secondary (interruptible) sales approximated 90 GW.h/year at normal flows. The 2006 Resource Plan forecasts indicated that at normal flow levels (i.e., average hydro energy generation) absent new industrial loads, some surplus hydro was forecast to remain on both the WAF and Mayo Dawson ("MD") grids until at least around 2020. Diesel generation was not forecast to be required to supply sustained loads (i.e., loads in excess of average annual hydro energy generation) until the 2020 timeframe, increasing to about 28 GW.h/year in 2025. It was also noted that some diesel generation would be required for peaking purposes (i.e., brief time periods during the winter peak months), but these peaking diesel generation requirements were forecast to remain below 10 GW.h per year until after 2020 (i.e., near the end of the 20-year planning period).

1 **1.4 CURRENT RESOURCE PLANNING CHALLENGES & OPPORTUNITIES IN YUKON**

2 The following resource planning challenges were noted in the Yukon Energy 2011 Charrette Report:

- 3 • **Need for new supply to meet future growth** - Yukon must plan and build new supply for
4 new electricity demand that supports economic growth within the reality of high diesel prices and
5 limited short-term alternatives other than diesel generation. The challenge is to determine how
6 increases in demand driven by economic growth can be turned into opportunities to create a
7 supply of clean or sustainable energy that Yukoners can afford and support.
- 8 • **Need to provide safe and reliable service in a cost effective manner** - Regulatory rules
9 that exist tend to be confusing and complex. Most people do not know the true cost of electricity
10 and expect that they should continue to receive low cost power. While Yukoners have enjoyed
11 and come to expect low cost power, a key theme of the Charrette (enforced by speakers from
12 outside the Yukon) was that utilities across Canada are all expecting material increases in the
13 cost of supply and this will impact rates⁴¹. The challenge for resource planning in all jurisdictions
14 including the Yukon is to ensure future supply options remain affordable and do not unfairly
15 burden ratepayers⁴².
- 16 • **Need for flexibility to address challenges related to the isolation of Yukon's electricity**
17 **system** - As noted by Dr. Mark Jaccard during the Charrette, "Yukon's isolated grid and the
18 substantial but uncertain energy needs from mining activity mean that energy system flexibility
19 has a high value in Yukon" in addition to values such as affordability, reliability and
20 environmental responsibility.
- 21 • **Need to pursue new sources of generation in a manner that promotes environmental**
22 **responsibility** - Generation of power must be done with the least amount of impact on the
23 environment. This includes the need to avoid, as much as possible, the production of greenhouse
24 gases. Renewable energy is attractive but can be expensive in the short to medium term. Hydro
25 can impact the environment through flooding. How can we plan for future energy needs in a

⁴¹ The Charrette presentation of Pierre Guimond indicates in 2009 total capital investment in the electric power sector at \$16 billion with a further significant capital investment requirement (up to \$237.6 billion). The presentation notes that of the \$237.6 billion (in 2007 CDN dollars) \$88.3 billion is expected to be spent over the period from 2007-2015 and \$149.3 billion is expected to be spent over the period from 2016 to 2030. The presentation also notes over the period from 1998 to 2009 average electricity prices have increased by \$1.05/KW.h (in 2008 c/KW.h and based on 1000 KW.h monthly consumption), underlining the new costs pressures in this sector throughout Canada.

⁴² As with other Canadian power utilities, Yukon Energy is also required to undertake major investments to maintain its current system, replace assets, enhance system reliability, and plan for potential new resource supply developments.

1 more integrated way that takes into account ideas such as district heating, reduction of
2 transportation fuels, minimizing environmental foot prints, renewable energy and the use of local
3 resources⁴³?

4 These resource planning challenges and the unique characteristics of the Yukon System underline the
5 additional challenge of determining how increases in demand driven by economic growth can be turned
6 into an opportunity to create a supply of clean or sustainable electricity that Yukoners can support and
7 afford. Higher costs to secure new grid supply will impact rates for all utility customers. Higher GHG
8 emissions from new generation will hamper Yukon's ability to secure overall GHG emission reductions,
9 whether or not the new demand occurs on or off the grid.

10 Accordingly, although the existing grid has sufficient capacity and energy capability to meet near-term
11 load requirements⁴⁴, until such time as other affordable and environmentally sensitive supply options can
12 be developed non-industrial and industrial load growth will increase baseload diesel generation with
13 consequent added upward pressure on utility costs (and therefore rates) and GHG emissions.

- 14 • For example, with current and committed grid resources and no development of new supply
15 options, a 2015-2016 grid load forecast at 545 GW.h⁴⁵ will require 101 GW.h of baseload grid
16 diesel generation (as compared to a forecast 2 GW.h of baseload grid diesel at forecast 2011
17 loads) which could be supplied by existing diesel generation resources.
- 18 • This level of diesel generation at current approved Hydro zone diesel generation costs (30
19 cents/kW.h) would add approximately \$30 million operating costs to utility rates. After
20 considering related revenue growth from such increased loads, the average net rate impact for all
21 utility ratepayers would potentially be almost 6 cents per kW.h.
- 22 • This level of new future diesel generation would also increase future Yukon GHG emissions by
23 70,000 tonnes per year, whether or not the new demand occurs on or off the grid.

⁴³ Pierre Guimond President and CEO, Canadian Electrical Association noted during the Charrette that, "cost-effectiveness, reliability, and safety are the pillars on which the Canadian electric power system was built. A new constant, sustainability, is one of the key driving forces behind the transformation that will occur in the decades to come. The future industry will take into consideration the balance of environmental, social, and economic impacts, which the system will have on Canadians."

⁴⁴ Subject to the need for added diesel capacity to meet capacity planning requirements (due to retirements and new mine loads).

⁴⁵ A 545 GW.h/year grid load in 2015 would be only very slightly higher than the forecast for that year with Victoria Gold (Eagle Gold mine) connected, without any impacts from future DSM/SSE.

1 Today Yukoners derive material benefits from past investment in legacy transmission and generation
2 infrastructure developed in response to major industrial loads⁴⁶. In the past, Northern Canada Power
3 Commission and Yukon Energy (since 1987) successfully pursued legacy investments that have provided
4 low cost and renewable power over the long-term for Yukon ratepayers. These environmentally
5 responsible energy investments were characterized by higher costs over the short-term (when capital
6 costs in the early years result in high amortization costs), and low and stable costs over the long-term.

7 Planning activities for the Yukon grid must continue to address the challenges arising from sharp changes
8 in load when major industrial loads are connected or are shut down:

- 9 • For example with connection of Victoria Gold (Eagle Gold) an increase in grid load of 103
10 GW.h/year is forecast in 2015-2016 (from 442 GW.h/year to 545 GW.h/year), excluding any
11 impacts from new DSM. This will - with current and committed grid resources - increase diesel
12 generation by about 76 GW.h/year (and the reverse would occur when the mine life expires).
- 13 • With the additional connection of Carmacks Copper and Whitehorse Copper a further increase in
14 grid load of 65 GW.h/year is forecast in 2015-2016 (from 545 GW.h/year to 610 GW.h/year). This
15 will further increase diesel generation by about 59 GW.h/year (and the reverse would again occur
16 when the mine's lives expire).

17 Unlike many other supply options, existing diesel generation is highly flexible to increases or decreases in
18 grid loads. Therefore, alternative new supply options -- to be viable -- will also need to be very sensitive
19 to the extent and duration of the loads that are used to justify such investments. New greenfield legacy
20 hydro developments, for example, require many years for planning, i.e., planning over the next five years
21 is needed if such an option is to be protected for in-service by 2021 – and once developed, grid load
22 levels sufficient to ensure effective utilization of such a capital intensive resource are required for 30+
23 years.


24 Managing these risks is required to develop over the long-term new renewable legacy projects so that
25 Yukon load growth can be met with resource options that are lower cost (and more environmentally
26 responsible) than diesel generation.

⁴⁶ Legacy renewable power assets are long-lived and capital intensive renewable resource investments with low operating costs. Legacy or heritage renewable hydro investment in the past has yielded these benefits in Yukon and in other jurisdictions in Canada such as British Columbia, Manitoba and Quebec.

1 The existing power infrastructure, active and potential mine developments, the potential Alaska Highway
2 Pipeline, and future power supply options in Yukon over the resource planning period are detailed in
3 Figure 1-2 below. This provides an overview of specific renewable resource locations examined in the
4 2011 Resource Plan within the context of the current integrated grid power supply infrastructure and the
5 diverse range of industrial development opportunities that could develop in the Yukon during the 20 year
6 planning period. Figure 1-2 identifies areas within a 50 km boundary from the current and potential
7 future electric grids (based only on the current southern highway structure).

1 **Figure 1-2: Existing Yukon Power Infrastructure, Potential Supply Options, and Active & Potential Mine Loads**

LOCATION OF EXISTING POWER INFRASTRUCTURE AND POTENTIAL SUPPLY OPTIONS IN RELATION TO ACTIVE AND POTENTIAL MINE LOADS



2

iPlan_Nov1.dgn
 1 NOV 2011

1 **2.0 FORECAST LOAD REQUIREMENTS & CHALLENGES**

2 Section 2 reviews forecast electrical load requirements in Yukon over the 20-year planning period and
3 beyond, as well as capacity and energy related challenges for the existing grid under these forecast
4 loads.

5 Load forecasting is a key component of the Resource Plan, providing one foundation for assessing the
6 need and justification of the resource planning options reviewed in Sections 3 through 6.

- 7 • Near-term forecast load requirements for the grid, for example, define the opportunities for near-
8 term major project options to be committed before 2015 and the extent to which such new
9 resources may continue to be utilized effectively over the 20-year planning period. Capital
10 intensive options that are technically feasible in the near-term were shown in the Charrette to
11 pose major risks to ratepayers unless the load requirements to justify them are reasonably likely
12 to be sustained through the 20-year planning period.
- 13 • Longer-term potential load requirements (off as well as on grid) define opportunities for Yukon to
14 develop legacy renewable resource projects. Credible load opportunities within the planning
15 period are a prerequisite for the major planning budgets required to pursue longer-term
16 greenfield renewable options during the next five years.

17 In addition to defining specific near-term load growth challenges, the 2011 Resource Plan identifies
18 potential load opportunities in Yukon within the planning period that are appropriately large and
19 sustained to play a determinative role in defining legacy planning measures that could merit serious
20 consideration today for Yukon Energy. As a consequence, ongoing planning activities are discussed in
21 Sections 5 and 7 to examine potentially beneficial opportunities beyond the near-term to work with major
22 new off-grid mines and/or pipeline developers to explore potential new legacy renewable power asset
23 developments by 2021.


24 Section 2 includes the following subsections (detailed supporting information is provided in Appendices C
25 and D):

- 26 • Background and Context;
- 27 • Overview of Potential Yukon Loads: 2011-2050;
- 28 • 2011 Resource Plan Grid Load Scenarios: 2011-2030; and
- 29 • Capacity & Energy Related Challenges for Existing Grid Under Forecast Loads.

1 **2.1 BACKGROUND AND CONTEXT**

2 The scale of industrial load today on the existing system, and balance of industrial and non-industrial load
 3 on the current system, may be contrasted with the system in 2005 (when no industrial customers were
 4 present on the system) and with 1996/97 (when the Faro mine was operating). As reviewed in Figure 2-
 5 1, the closure of the Faro mine reduced industrial loads by nearly 200 GW.h a year, but it also
 6 dramatically reduced the loads in communities local to the mine (such as Faro, which reduced from an
 7 average residential customer count of 478 in 1996 to an average of 189 in 2001) and in major centres
 8 such as Whitehorse (Yukon Energy wholesales to YECL declined from 232 GW.h in 1996 to 217 GW.h in
 9 2001). During this 1998-2001 period out-migration of about 10% of the Yukon's population occurred
 10 (over 3,000 people).

11 **Figure 2-1: Historical Grid Non-Industrial and Industrial Sales – 1994-2010 (GW.h/year)**



12

Sales (GW.h/yr)*	1995	1996	1997	1998**	2000**	2005	2009	2010
Grid Non-Industrial Firm	247	267	254	254	251	273	307	314
Grid Industrial	90	179	78	17	2	0	29	30
Secondary	6	5	4	3	4	19	17	10
Losses	27	30	19	18	19	24	28	31
Total Generation	369.9	480.4	355.5	292.1	275.5	316.1	381.9	385.6

* WAF & MD loads for all years. Sales exclude energy losses required for the sales.


** Grid Non-Industrial Firm sales include (Grid Industrial exclude) Faro site dewatering sales after Faro Mine closure charged as "Industrial" prior to 2005.

13

1 Over the 2005 to 2010 period, grid non-industrial sales increased from 273 GW.h/year to 314 GW.h/year
 2 (a 41 GW.h increase over the period reflecting higher growth than was forecast in the 2006 Resource
 3 Plan). Year over year increases over the period tended to exceed the 1.85% non-industrial percentage
 4 annual growth forecast in the 2006 Resource Plan, with annual growth ranging from a 1.8% annual
 5 increase in 2007 to a 5.5% annual increase in 2006. In contrast, grid industrial sales were minimal from
 6 1998 until 2008⁴⁷ and increased to 30 GW.h in 2010 (primarily due to connection of Minto mine in
 7 November 2008). As noted in Figure 2-1, the Minto and Alexco mine loads combined in 2010 were less
 8 than 17% of the Faro mine load in 1996.

9 Figure 2-2 reviews annual generation by source (hydro/wind and diesel) over the same 1994-2010 period
 10 for WAF and the Mayo-Dawson systems.

11 **Figure 2-2: Yukon Grid Generation – 1994-2010 (GW.h/year)**



12

Grid Generation by Source (GW.h/year)	1995	1996	1997	1998	2000	2003	2005	2009	2010
Total Grid Hydro & Wind (Incl Fish Lake)	317.5	362.3	259.6	270.3	259.5	288.3	315.5	379.3	380.5
Total WAF Diesel	39.5	104.6	81.8	7.2	0.7	0.3	0.1	2.1	2.7
Total Mayo Dawson Diesel	12.9	13.6	14.0	14.6	15.3	11.1	0.5	0.5	2.4
Total WAF & MD Diesel	52.4	118.1	95.9	21.8	16.0	11.4	0.6	2.6	5.1
Total WAF & MD Generation	369.9	480.4	355.5	292.1	275.5	299.6	316.1	381.9	385.6

13

⁴⁷ Minimal industrial loads are noted from 1999 through to the end of 2004 – these relate only to ongoing Faro dewatering activities after final shutdown of the mine. Starting in 2005, these loads became general service (non-industrial) loads.

1 Generation on WAF and the Mayo-Dawson systems peaked in 1996 (480.4 GW.h), with 362.3 GW.h of
2 hydro and 118.1 GW.h of diesel generation. The highest annual generation in these areas thereafter (in
3 2010) was 385.6 GW.h, with 380.5 GW.h of hydro and only 5.1 GW.h of diesel generation. During the
4 1996 to 2010 period, resource planning activities on both grids have focused on opportunities to cost-
5 effectively enhance the existing grid systems in order to displace higher cost diesel with lower cost
6 surplus hydro generation available due to mine closures.

- 7 • Dawson was an isolated diesel community in 1996 and was served solely by diesel generation
8 until September 2003⁴⁸. Figure 2-2 illustrates ongoing amounts of diesel generation in Dawson
9 increasing from about 12.9 GW.h in 1995 to 15.3 GW.h in 2000 and then falling to 11.1 GW.h in
10 2003. The completion of the Mayo Dawson Transmission Line (MDTL) interconnected the
11 community of Dawson with Mayo (which, due to the closure of the UKHM mine in the late 1980's
12 had material surplus hydro available). This led to a sharp reduction of diesel in the Mayo-Dawson
13 system with diesel requirements in the range of 0.3 GW.h per year to 0.8 GW.h per year between
14 2004 and 2009 and 2.4 GW.h/year in 2010⁴⁹. Hydro generation was correspondingly increased.
- 15 • When the Faro Mine was in operation, all of Yukon's WAF hydro generation was absorbed by the
16 system and material diesel generation was required on an ongoing basis throughout the year.
17 Figure 2-2 illustrates requirements of 104.6 GW.h of WAF diesel in 1996 and 81.8 GW.h of WAF
18 diesel in 1997 followed by 7.2 GW.h of WAF diesel in 1998. After the shutdown of the Faro mine
19 diesel requirements were minimal on WAF (0.7 GW.h of diesel in 2000 and 0.1 GW.h of diesel by
20 2005). As there were no major industrial customers on the WAF grid between 1998 and
21 November 2008⁵⁰ there was material surplus grid hydro generation available on the WAF grid.
22 Secondary sales were developed in the 2000 to 2005 period to provide short-term income
23 recovery on WAF so long as surplus hydro was available.
- 24 • The CSTP Stage 1 development to connect the Minto Mine and Pelly Crossing by late 2008
25 established new firm load utilization for available WAF hydro generation. Although not illustrated

⁴⁸ The MD project was the first large-scale transmission infrastructure development project undertaken by Yukon Energy since the NCPC transfer in 1987.

⁴⁹ The MDTL now supplies almost all of Dawson's energy requirements and also provides lower cost grid electricity to YECL at Stewart Crossing (which was previously served by diesel generation), as well as various locations along the North Klondike Highway that were not previously served by utility power.


⁵⁰ After decades of operation on the WAF grid, including a number of closures and re-openings, the Faro Mine closed permanently in 1998. This mine closure followed the 1989 closure of the UKHM, which had been served by the Mayo hydro plant. Overall generation and diesel usage declined after the Faro Mine's closures in 1983, 1993, 1997 and again after its final closure in 1998.

1 in Figure 2-2, the interconnection and sale of surplus hydro to the Minto Mine through the CSTP
 2 directly reduced off-grid diesel requirements by about 30 GW.h and reduced GHG's by 21,000
 3 tonnes (i.e., the Minto mine commenced commercial operation in October 2007 using its own off-
 4 grid diesel generation).

5 Since 2005, resource planning and development requirements for Yukon's bulk power system (i.e., grid
 6 generation and transmission) have continued to be a key focus for Yukon Energy activities. In response
 7 to new load and funding opportunities available in the period between 2005 and 2009 major new legacy
 8 resources are expected to be in place by the end of 2011, namely CSTP connection of the grids plus,
 9 Mayo B and Aishihik 3rd Turbine new hydro generation.

10 Figure 2-3 shows the major drop in overall Yukon diesel generation and GHG emissions after 1996-97.

11 **Figure 2-3: Yukon Grid & Off-Grid Diesel Generation – 1994-2010 (GW.h/year)**



12

Diesel Generation (GW.h/year)	1995	1996	1997	1998	2000	2005	2008	2009	2010
Total WAF Diesel Generation	39.5	104.6	81.8	7.2	0.7	0.1	1.2	2.1	2.7
Total MD Diesel Generation	12.9	13.6	14.0	14.6	15.3	0.5	0.4	0.5	2.4
Off Grid YECL Diesel Communities	20.0	19.2	19.1	20.0	21.0	21.8	22.1	19.8	19.8
Off-Grid Industrial	0	0	0	0	0	0	25	0	19
Total Yukon Diesel Generation	72.4	137.4	114.9	41.8	37.0	22.4	48.7	22.4	43.9

*OffGrid Industrial sales in 2007 and 2008 relate to estimates (not actuals) for Minto mine prior to interconnection with WAF grid.

GHG Emissions (tonnes/year)	1995	1996	1997	1998	2000	2005	2008	2009	2010
GHGs WAF	27,668	73,189	57,283	5,039	510	80	850	1,495	1,882
GHG's Mayo Dawson	8,996	9,489	9,833	10,222	10,708	326	314	357	1,707
GHG's Off Grid Communities & Industrial	14,020	13,472	13,337	14,009	14,674	15,265	15,446	13,827	27,137
Total Yukon GHG's	50,684	96,150	80,453	29,271	25,892	15,671	16,609	15,679	30,726

13

1 During the period from 2005 until 2010 off-grid communities served by YECL [Watson Lake⁵¹, Beaver
2 Creek, Destruction Bay, Swift River⁵² and Old Crow⁵³] maintained diesel generation that ranged between
3 roughly 20-22 GW.h/year⁵⁴, and displayed minimal overall growth in utility generation (about 0.5 GW.h in
4 total). As reviewed in the table below Figure 2-3, off-grid diesel generation growth since 2009 at the
5 Wolverine mine has doubled off-grid diesel generation GHG emissions (from 13,827 tonnes/year in 2009
6 to 27,137 tonnes/year in 2010).

7 **2.2 OVERVIEW OF POTENTIAL YUKON LOADS: 2011-2050**

8 Yukon is currently experiencing a mining resource boom driven by world commodity market demands. As
9 noted in the Preface, mineral exploration expenditures and claims in Yukon have recently climbed to
10 record highs. The 2011 Resource Plan load forecasts explore the potential implications of this record
11 resource activity for future on and off-grid electricity loads in Yukon. These load forecasts were prepared
12 during 2011, at a time of major uncertainties regarding the health and stability of world markets.

13 Given that the Resource Plan is intended to guide planning and development over the next five years and
14 to be updated every five years, the load forecasts are directed at the near-term time period with
15 extensions over the longer-term 20-year and 40-year time periods in order to help assess longer-term
16 opportunities and challenges.

- 17 • Updated load forecasts have been prepared for firm electricity sales (i.e., excludes secondary
18 sales) to non-industrial customers and industrial customers on the new integrated WAF-MD grid,
19 the YECL off-grid communities and off-grid industrial mine sites.
- 20 • The methodology for these load forecasts as reviewed in Appendix C is consistent with that used
21 in the 2006 Resource Plan, reflecting available population forecasts, recent trends in non-
22 industrial customer electricity load growth and current electricity forecasts for specific mines as
23 noted (see Appendix C for details by customer class). Grid generation forecasts (hydro and diesel
24 generation) have been prepared based on current and committed generation resources,

⁵¹ As noted in Appendix C, Attachment C-1, Watson Lake generation has a very modest annual growth (0.51%), with 2010 generation at 14.0 GW.h.

⁵² As noted in Appendix C, Attachment C-1, Beaver Creek, Destruction Bay and Swift River together have a very modest annual growth in generation (0.13%), with overall 2010 generation at 3.9 GW.h.

⁵³ As noted in Appendix C, Attachment C-1, Old Crow has a moderate annual growth (1.71%), with 2010 generation at 1.9 GW.h.

⁵⁴ Dawson was part of the Large Diesel rate zone and Stewart Crossing was in Small Diesel Rate Zone prior to completion of Mayo Dawson Transmission Project in 2004 and Pelly was Small Diesel Community prior to completion of CSTP Stage 1 in 2008.


1 excluding existing wind generation and Yukon Electrical’s Fish Lake hydro generation (the impact
2 of these exclusions is noted in Appendix C).

3 Load forecasts for a 20-year planning period (let alone for longer periods) are subject to considerable
4 uncertainty and risk. In Yukon, unlike typical southern Canada jurisdictions, connection or disconnection
5 of any one mine load can have potentially major impacts on overall grid generation requirements. The
6 pace of non-industrial load growth in Yukon can also be materially impacted by the pace of mine
7 development and the stability of existing mine loads. Faced with the uncertainties inherent in the
8 industrial load forecasts, the forecast approach focuses more on assessing a range of industrial-related
9 scenarios that need to be considered than on detailed investigation of non-industrial residential or
10 general service retail loads.

11 Figure 2-4 below provides a longer-term overview to 2050 of potential Yukon electricity generation loads,
12 highlighting the overall impact of various off-grid mine loads that are currently being pursued for
13 development in Yukon before 2020 (see Figure 2-5) as well as potential industrial and non-industrial
14 Yukon grid generation loads (including potential new mine loads in YEC’s current near-term load
15 scenarios) that are assumed in this initial overview to be met by existing and currently committed hydro
16 and diesel generation.

17 Figure 2-4 does not include either future diesel generation for the YECL off-grid communities (Figure 2-3
18 shows this load currently at about 20 GW.h/year, with a trend of only modest growth) or potential
19 implications of climate change considerations (discussed below).

Figure 2-4: Existing System Capability to Supply Potential Grid Load & Potential Off-Grid Mine Loads: 2011-2050



*Scenario B - Base Case Load Forecast with Victoria Gold, Carmacks Copper & WHCT

	2011*	2015	2020	2025	2030	2035	2040	2045	2050
Grid Load/Hydro Supply Gap**	2	158	163	40	83	138	204	278	364
(Forecast Diesel Generation-GW.h/yr)									
Potential Off-Grid Mines	37	332	1,538	1,390	1,338	1,338	1,338	1,338	1,088
(Forecast Diesel or LNG*** GW.h/yr)									
Total Yukon Diesel or LNG Generation (GWh/yr)	39	490	1,701	1,430	1,421	1,476	1,541	1,616	1,451
Total Potential GHG's (tonnes)	26,962	343,073	864,118	674,435	667,793	706,413	752,282	804,481	689,306

* 2011 diesel generation is based on long term forecast (not actuals)

** Assumes connection of Carmacks Copper and Victoria Gold to grid

***Assumes Casino develops using LNG with combined cycle power generation & other off grid mines develop using diesel

In sum, Figure 2-4 illustrates many of the resource planning challenges to be addressed in the 2011 Resource Plan:

- Focusing on the grid, there is a material increase in potential grid connected industrial loads in the near-term (2013-2021) reflecting potential Victoria Gold (Eagle Gold) and Carmacks Copper mine loads as well as growth in currently connected Minto and Alexco loads; however, as discussed below, this spike in potential grid load growth is not currently forecast to continue beyond about 2021. Forecast grid diesel requirements with such increased load (and no new generation resources) climb to 176 GW.h/year in 2018-19, decline sharply to 22 GW.h in 2022,

1 and then grow thereafter at an annual forecast rate of 2.26% per year (reflecting base case
2 forecast non-industrial load growth prior to any demand side management program), increasing
3 to slightly over 80 GW.h by 2030 (the end of the current 20-year planning period).

- 4 • Looking at the off-grid industrial loads, within the 20-year resource planning period and well
5 beyond 2030 material and sustained potential off-grid generation is indicated – and, unlike any
6 past experience in Yukon, the potential off-grid industrial loads effectively dwarf the current
7 projected grid system load potential before 2020. Based on the magnitude and duration of these
8 potential loads, resource planning challenges arise in looking to define what, if any, legacy
9 generation and transmission resource developments could merit serious consideration today for
10 Yukon.

- 11 • In total, the potential loads in Figure 2-4 show that, absent solutions that include new renewable
12 or low GHG emitting sources of generation being developed, total Yukon diesel or other non-
13 renewable generation could exceed 490 GW.h by 2015 and 1,700 GW.h by 2020. The table below
14 Figure 2-4 shows the potential resulting dramatic increase in Yukon GHG emissions by as soon as
15 2015, with a potential increase in GHG emissions from about 27,000 tonnes in 2011 to over
16 340,000 tonnes in 2015 and over 800,000 tonnes by 2020. While impacts from potential new grid
17 mine loads (primarily Victoria Gold and Carmacks Copper) are currently expected to be for a
18 limited time period (from 2013 through 2021), GHG emission impacts from potential off-grid
19 mines are expected to persist well beyond the 20-year resource planning period.

20 Currently connected mine loads and new industrial loads that are potentially expected to be connected to
21 the grid over the next few years appear to offer only limited potential justification for developing new
22 capital intensive legacy resources. If all of these potential mine connections and loads materialize, there
23 will be a relatively brief period when industrial generation loads on the grid will increase from 46 GW.h in
24 2011 to more than 230 GW.h between 2015 and 2018, and then decline to slightly over 195 GW.h in
25 2020 before dropping sharply (to 14 GW.h in 2021 and zero in 2022).

- 26 • It is possible that connected mine loads will continue longer than is currently forecast – or that
27 delays in development of some of the new mine loads could facilitate spreading out of the
28 duration of these grid loads. Sensitivity tests for such possible extensions to 2025 or 2030 are
29 provided in subsequent sections when assessing generation resource options. However, until
30 specific new information is available to confirm the likely occurrence of such possibilities, it would
31 be difficult and risky to commit new resources dependent on these possibilities.


- 1 • It is also possible that other new mines will undertake the costs and commitments needed to
2 connect to the grid. There are currently only a limited number of potential mine opportunities
3 located within 50 to 100 km of the 69-138 kV grid (e.g., potentially Rau Gold, Ketz River and
4 Brewery Creek)⁵⁵. Larger potential new off-grid mines such as Casino, Selwyn, Mactung and
5 Northern Dancer⁵⁶ are not currently considering connection to the Yukon grid in order to meet
6 load requirements.
- 7 • The possibility also exists that new mine connection loads will be much more limited than
8 assumed in Figure 2-4, due to delays or limitations in the development of specific mines, serious
9 and sustained slumps in world mining commodity demands, or inability to secure the approvals
10 needed for such connections. To the extent that new mines are in fact developed, the GHG
11 emission related generation impacts will remain as a major issue regardless as to whether or not
12 the mine is connected to the grid⁵⁷.

⁵⁵ As discussed in Appendix B, Attachment B-2, the current industrial maximum utility investment policy requires that industrial customers seeking interconnection pay the full capital costs for any line to connect the mine site with the Yukon grid. Generally, interconnections at distances greater than 50-100 km are considered to be cost prohibitive for potential industrial customers. The limited current information on the prospective mines noted to be within 50-100 km of the 69-138 kV grid suggests requirements for a relatively small scale power load with a relatively short mine life.

⁵⁶ The Northern Dancer mine would be located within 100 km to the east of Teslin which is served by 35 kV transmission connected to YEC's 138 kV WAF grid; however, the scale of the Northern Dancer load (i.e., 30- 35 MW) would require upgrade to at least 138 kV for any Yukon grid connection.

⁵⁷ Stakeholder comments included in the Charrette Participant's Guidebook indicate a concern on the part of those individuals and entities consulted to consider greenhouse gas targets and reductions and to consequently reduce reliance on diesel generation (and emission) through development of renewable resource projects or through replacing diesel with cleaner burning fuels. Strong public preference for alternative sourced energy is also supported by other Yukon Energy surveys undertaken in 2011.

1 **Figure 2-5: Potential Off-Grid Mine Loads – 2010-2030 (GW.h)**



2

Potential Off-Grid (GWh):*	2011	2015	2020	2025	2030	2035	2040	2050
Wolverine	37	37	-	-	-	-	-	-
Casino	-	-	941	941	941	941	941	941
Selwyn	-	147	147	147	147	147	147	147
Mactung	-	58	58	-	-	-	-	-
White Gold	-	-	52	52	-	-	-	-
Coffee	-	90	90	-	-	-	-	-
Northern Dancer	-	-	250	250	250	250	250	-
Total	37	332	1,538	1,390	1,338	1,338	1,338	1,088

3 *** Potential mines > 100 km distance from 69-138 kVgrid, from grid, based on current information

4

Forecast scenario	2011	2015	2020	2025	2030	2035	2040	2050
Industrial GHG Emissions (tonnes)								
GHGs - Potential Off Grid Mine Loads								
Wolverine	25,900	25,900	-	-	-	-	-	-
Casino**	-	-	331,914	331,914	331,914	331,914	331,914	331,914
Selwyn	-	102,900	102,900	102,900	102,900	102,900	102,900	102,900
Mactung	-	40,600	40,600	-	-	-	-	-
Northern Dancer	-	-	175,000	175,000	175,000	175,000	175,000	-
White Gold	-	-	36,400	36,400	-	-	-	-
Coffee	-	63,000	63,000	-	-	-	-	-
Total Off Grid Mine GHGs	25,900	232,400	749,814	646,214	609,814	609,814	609,814	434,814

4 **Assumes develop using LNG & combined cycle power generation

5 Figure 2-5 provides added detail for 2010-2030 regarding the seven specific potential off-grid mine loads
 6 included in Figure 2-4. The table below the figure extends the generation load information to 2050 for
 7 each mine, and also provides estimated GHG emissions for each mine.

8 Off-grid mine developers have emphasized the need for certainty in meeting their energy requirements,
 9 i.e., in seeking to secure all relevant commitments needed to proceed, they do not want to "put their fate

1 in other's hands" and need assurance that energy requirements will be met for projected timelines and at
2 competitive costs (based on their own supply option assessments).

3 In this respect, the developers of the off-grid Casino mine (with a large scale power requirement of 130
4 MW and 941 GW.h/year potentially sustained over several decades) expect to use LNG (rather than
5 diesel) with combined cycle generation as the preferred energy source⁵⁸ for on-site generation in order to
6 reduce costs related to baseload power generation at the mine site to within an 11-15 c/kW.h range
7 (versus the 30+ cents/kW.h range for diesel). Under this approach, Casino would retain flexibility to
8 further reduce operating costs by converting the power generation to natural gas when/if local natural
9 gas becomes available (e.g., power generation costs estimated at <10 c/kW.h with access to Alaska
10 Highway Pipeline Project natural gas). Use of LNG also provides additional complimentary opportunities
11 for Casino (i.e., use of LNG for truck transport).

12 Yukon Energy is working with Western Copper and Gold (the developers of the Casino mine project) to
13 explore opportunities for joint activities to secure mutual benefit from development of LNG-based
14 generation (as planned currently for Casino) or other new Yukon resource options that might be justified
15 and developed with the Casino project. Access to LNG in Yukon may provide an opportunity for Yukon
16 Energy to replace diesel gensets (required for peaking or baseload use) with dual fuel diesel/gas units
17 that are lower cost to operate when using LNG and that have overall (30%) lower emissions when
18 operated with LNG⁵⁹.

⁵⁸ The mine developers (Western Copper and Gold) currently plan to import LNG from new supply facilities currently being planned at Kitimat and/or that could be developed in the Fort Nelson area. See Section 6 for more detailed review of LNG option opportunities.

⁵⁹ Environmental impacts of diesel generation include air emissions (e.g., GHG at approximately 700 tonnes per GW.h with normal operation of a new unit generating about 4 kW.h per litre of diesel fuel, and regulated health-related emission effects re: NO_x, SO₂ and particulates), noise, and potential fuel spills effects (including storage tank leaks). In contrast, LNG or natural gas offers cleaner environmental impacts than with diesel generation, e.g., GHG for simple cycle operation using 8.204 Mcf/MWh at approximately 36% less than diesel fuel (about 451 tonnes GHG emissions per GW.h) and for combined cycle using 6.562 Mcf/MWh are 48% reduction (about 361 tonnes GHG emissions per GW.h); regulated health air emission effects re: NO_x, SO₂ and particulates are also typically materially lower than diesel fuel emissions; and there are reduced potential concerns re: fuel spills effects (including storage tank leaks) compared with diesel fuel. Use of combined cycle options (rather than single cycle) would further reduce fuel requirements and GHG emissions, and could also facilitate use of waste heat to displace fossil fuel heating requirement. By way of example, at the Casino mine scale of operation, operation on LNG with combined cycle at over 50% efficiency results in about 353 tonnes GHG per GW.h or approximately 50% of what would occur with normal diesel generation.

1 Introduction of LNG into the territory may also enable fuel switching (e.g., for use in vehicles) on a
2 territory wide basis, helping to reduce overall Yukon GHG emissions⁶⁰.

3 It is recognized that any new off-grid load opportunities to develop new legacy resource options for
4 Yukon are each clearly subject to project-specific negotiation and joint planning with each developer to
5 determine if mutually acceptable arrangements and opportunities can be concluded, including appropriate
6 risk management and mitigation measures to protect all other grid-served customers from unacceptable
7 rate-related risks. In the case of the larger off-grid mine projects, initial operation would also likely need
8 to commence using fossil fuels and on-site power generation (as was the case with the Minto Mine
9 connected to the grid in 2008) with any grid connected generation commitments being linked to the
10 completion of new legacy generation and transmission facilities with appropriate third-party contributions
11 towards planning and construction costs as occurred with CSTP⁶¹ and Mayo B; a sufficiently large and
12 stable load extending over 20 or more years would also likely be needed to ensure that the energy
13 generated by new bulk power assets is fully utilized over a reasonable period of years.

14 Overall, the March 2011 Charrette also recognized the importance in electricity resource planning of
15 addressing climate change considerations in Yukon going forward. Currently in Yukon, utility power
16 generation accounts for only about 3% of GHG emissions, while transportation and building heating
17 account for over 85% of GHG emissions⁶². In order to reduce GHG emissions in Yukon, heating and
18 transport sector fossil fuel use reductions may be sought through fuel switching and electrification.

19 The following considerations are noted with regard to potential fuel switching and electrification
20 programs:

- 21 • Electricity is "clean" when used for heating if generated from a renewable energy source;
22 however, it is generally more efficient to use clean fuels (e.g., biomass) directly in heating

⁶⁰ The calculation of GHG emissions reduction is based on emissions factors provided the National Inventory Report (Environment Canada). Accordingly, the combustion of a litre of diesel fuel a total of 2.7898 kg of CO₂ equivalent [2663g CO₂ + (0.133g x 21)g of CH₄ + (0.40 x 310)g of N₂O]. At an assumed efficiency for a new unit of 4 kW.h per litre of fuel the CO₂ produced per kW.h is 0.6975kg CO₂ equivalent per kW.h or 697.5 tonnes of CO₂ eq. per GW.h (rounded to 700 tonnes for this report). Natural gas combustion would result in emissions factors of 1916g CO₂ per cm (this relies upon emission factors provided for B.C., which are within same range as emissions factors for Alberta; natural gas for Yukon LNG in the near-term would be sourced from Northern BC or Alberta), (0.49 x 21)g of CH₄ and (0.049 x 310)g of N₂O and would result in total of 1.941 kg of CO₂ eq. per cm (or 0.05493 kg per cf). For simple cycle operation at efficiency of 8.204 Mcf/MW.h, GHG emissions equal 451 tonnes per GW.h; for combined cycle at efficiency of 6.562 Mcf/MW.h, GHG emissions equal 361 tonnes per GW.h.

⁶¹ CSTP would not have proceeded absent YEC securing a material contribution towards the Carmacks Stewart Main Line from Minto mine through a Power Purchase Agreement.

⁶² John Streiker.2011 "Climate Change" presentation to YEC Energy Charrette (transport 64% of Yukon GHG emissions, heat 22%, industry 9%, and electricity generation 3%, other 2%).

- 1 applications rather than to use such fuels first to generate electricity that is then used for
2 heating⁶³.
- 3 • Opportunities for combined heat and power (i.e., related to biomass or gas co-generation facility)
4 will depend upon locating the plant where use can be made of waste heat. A biomass plant
5 located at Haines Junction or the Minto area, for example, would reduce transportation costs
6 related to fuel supply, but provide no major opportunity to use waste heat. In contrast, a waste,
7 biomass or natural gas thermal plant located in the Whitehorse may create an opportunity to use
8 some of the waste heat. Reflecting these considerations, Yukon Energy is committed to
9 examining combined cycle units for all new thermal generation facilities in Whitehorse and is also
10 carrying out feasibility work to determine the business case for district heating in Whitehorse.
 - 11 • Electricity for vehicle transportation is a potential new use that in future could greatly increase
12 electricity loads; other potential new electricity uses to help reduce GHG emissions may occur in
13 many different areas, including displacing use of natural gas in pipeline compression stations
14 (potentially relevant in Yukon if new pipelines are developed).
 - 15 • Electrification of pipeline compressor stations⁶⁴ and/or any other major long-term electrification in
16 non-industrial sector loads⁶⁵ are potential additional future electricity generation loads (these
17 potential loads are not included in Figure 2-4 or Figure 2-5). Pipeline compressor stations in
18 Yukon (if developed) are expected to use natural gas⁶⁶; however, this development plan will
19 serve to increase overall GHGs in Yukon. Available information suggests that each of the six
20 compressor stations in Yukon for an Alaska Highway Pipeline (AHPL) Project would have 33 MW
21 demand and about 245 GW.h of annual energy, with an assumed in service date of 2020-21 and

⁶³ See for example Fernando Preto "Bioenergy" presentation to YEC Energy Charette (direct wood heating in home at 75% energy conversion efficiency as compared to 25% energy conversion efficiency for a large biomass electricity generation plant).

⁶⁴ In the event that the Alaska Highway Pipeline is developed (potentially by 2021), there may be an opportunity to electrify some of the project's six compressor stations in close proximity to the grid along the Alaska Highway, thereby securing large, stable long-term loads that would reduce GHG and other emissions if supplied by new hydro or geothermal legacy generation facilities (each of the six planned compressor stations would have an approximate 33 MW load requiring about 245 GW.h/year of electric energy over a project life of 25 years).

⁶⁵ Electrification opportunities that might significantly increase electricity loads include electric vehicles (impacts by the early 2020's are likely to be minimal) and electrification of pipeline compressor stations (as discussed below, any such increase would likely be a material jump in loads). Electrification scenarios reviewed by BC Hydro suggest that electricity retail sales could be as much as 30% to 50% higher in 2050 than would otherwise be the case based on current trends after DSM-related reductions, with most of this electrification-related growth occurring after 2030. Potential electrification trends in North America, however, create considerable uncertainty and risk regarding potential material increases in longer-term grid generation loads after the next 10 to 20 years.

⁶⁶ Current information provided by TransCanada indicates that each station will be self sufficient and electricity will be generated using natural gas from the pipeline.

1 expected project life of 25 years⁶⁷. Assuming use of natural gas, this would in effect potentially
2 result in 109,466 tonnes of new GHG emissions annually per compressor station (and there
3 would be several such stations in Yukon). In addition to reducing GHG emissions, electrification
4 of at least some of the AHPL compressor stations could also potentially provide the type of large,
5 stable long-term load required for development of low cost legacy assets such as large hydro or
6 geothermal.

- 7 • BC Hydro in recent years has begun to examine potential future load growth increases due to
8 fuel switching and electrification. Its latest base forecasts include electric vehicles at only modest
9 levels in the next decade, and expanding to less than 3% of all sales by Fiscal 2031 (approximate
10 16% penetration for light duty vehicles). BC Hydro's analysis includes electrification scenarios
11 wherein retail sales increase by up to 50% by 2050 relative to baseload forecasts, including 70%
12 electrification of light duty fleet vehicles and 42% for the heavy duty fleet vehicles
13 (approximately 75% of the overall 50% retail sales percentage increase occurs after the 20-year
14 time period relevant to the 2011 Resource Plan)⁶⁸.

15 In the event that the electrification scenarios materialize as reviewed in BC Hydro's recent analysis, such
16 electrification trends in North America would also likely result in material increases in longer-term Yukon
17 electricity demand, starting perhaps before 2020 but concentrated primarily after 2030, due to
18 electrification in the residential, commercial, industrial and transportation sectors. Overall, as suggested
19 in BC Hydro's forecasts, electrification may result in long-term growth in electricity demand that more
20 than offsets reductions secured through DSM. To avoid adverse impacts on regional GHG emission
21 reduction goals, such increases to Yukon electricity demand would need to be satisfied with low-carbon
22 electricity resources. Marbek is currently undertaking an end use survey that will provide a more detailed
23 information and analysis related to types of uses that contribute to the system peak (including electric
24 heating) – results may be incorporated into the Resource Plan once finalized.

⁶⁷ Proponents of the Alaska Pipeline Project provided a project schedule in September 2011 community meetings in Alaska (See TransCanada web site on Alaska Pipeline Project - presentation September 21, 2011 to the Alaska Annual Oil & Gas Conference) indicating first gas in 2020 and full gas in 2021, assuming an October 2012 FERC filing and project sanction before mid-2015. It is expected that six compressor stations would be required in Yukon, plus a gas heater station.

⁶⁸ Greenhouse Gas Reduction Scenarios for the Western Interconnection (2010-2050), related Addendum; Energy and Environmental Economics, Inc. (prepared for BC Hydro 2011 Integrated Resource Plan), January 2011. GHG reduction scenarios: 30% reduction in energy related GHG emissions by 2050 relative to 2008; and 80% reduction in energy related GHG emissions by 2050 relative to 2008.

1 Electrification loads noted above (i.e., fuel switching for pipeline compressor stations, transportation and
2 heating) are not included in 2011 Resource Plan load forecasts; however, it is recognized that climate
3 change policies may modify electricity load growth over the longer-term (i.e., starting in the 2020s and
4 extending over the following decades). Potential electrification impacts that may materially increase
5 longer-term Yukon retail (non-industrial) generation loads are identified as a major longer-term forecast
6 uncertainty in the 2011 Resource Plan. On this basis, potential electrification trends in British Columbia
7 and other North American jurisdictions merit ongoing monitoring and review.

8 **2.3 2011 RESOURCE PLAN GRID LOAD SCENARIOS: 2011-2030**

9 In order to provide reliable service, utility planning requires that each grid system have installed
10 generation adequate to supply the required peak capacity (MW) and annual energy (kW.h) as forecast
11 over the planning period.

- 12 • **Capacity planning** focuses on the highest or peak megawatt (MW) generation capability
13 (capacity) required on each system during each year, including sufficient reserve capability
14 (based on the system's capacity planning criteria) to address generation and transmission unit
15 breakdowns.
- 16 • **Energy planning** focuses on the number of kilowatt hours (kW.h) of electricity that are required
17 to be generated over the course of a season or year on each system.

18 Looking at capacity planning, the primary grid system planning consideration in Yukon is the system
19 capacity capability during the peak winter months when hydro capacity is constrained by low water flows
20 (especially at Whitehorse) and overall grid loads are highest (see Figure 1-1). The existing diesel
21 infrastructure as reviewed in Appendix A is utilized today primarily as reserve capacity to meet peak or
22 short-term grid emergency needs.

23 Looking at energy planning, the primary grid system planning consideration today in Yukon is to provide
24 affordable and environmentally responsible service. Existing diesel generation capacity on the grid
25 currently ensures that Yukon has ample capability to supply reliable energy when hydro capability is fully
26 utilized (including during winter months when hydro capability is constrained), i.e., at 90% capacity
27 factor for the diesel units, the existing 44.2 MW of grid diesel capacity could potentially provide almost
28 350 GW.h per year of electricity. However, reliance upon diesel generation to supply energy requirements
29 in excess of hydro capability has high cost and emission impacts - accordingly, utility planning examines
30 forecast diesel energy requirements in order to identify and assess technically feasible and appropriate
31 options to displace diesel energy generation.

1 The 2011 Resource Plan examines forecast electricity generation on the new integrated grid as well as
2 off-grid mine sites that might be connected to the grid⁶⁹. New resource supply options are assessed in
3 the context of forecast capacity and energy generation load requirements over the near-term and longer-
4 term based on forecast firm electricity sales to non-industrial customers and industrial customers, and
5 excluding secondary sales⁷⁰. As reviewed below, the existing generation and transmission system can
6 reliably supply energy and capacity by resorting to default diesel. Priority attention is first directed to
7 forecast grid energy requirements, reflecting the extent to which increased diesel energy requirements
8 (versus capacity requirements) can adversely impact Yukon Energy costs and GHG emissions.

9 **2.3.1 Forecast Grid Energy Requirements 2011-2030**

10 New resource opportunities in Yukon are typically defined by forecast grid diesel energy generation to be
11 displaced by less costly and/or lower GHG emission options. The 2011 Resource Plan load forecasts focus
12 on diesel displacement opportunities as one of the major challenges related to Yukon being an isolated
13 grid, and the reality that diesel generation to date has remained the default option in Yukon to meet new
14 capacity and energy load requirements not otherwise supplied by existing hydro generation.

15 Forecast baseload diesel generation reflects combined non-industrial and industrial grid generation
16 requirements, net of the forecast capability of existing and currently committed grid hydro generation to
17 supply these loads⁷¹. Hydro generation forecasts reflect average water year conditions, as well as the
18 forecast loads (i.e., as reviewed in Appendix D, hydro generation for existing facilities will increase to
19 some extent as annual loads increase, and is also sensitive to the seasonal distribution of forecast loads).

⁶⁹ Appendix C provides details on the load forecast scenarios for Yukon industrial and non-industrial loads (on-grid and off-grid); Appendix D reviews capacity and energy capability of the grid generation facilities.

⁷⁰ To simplify the assessment of resource requirements and options, grid generation forecasts also exclude existing wind generation and YECL's Fish Lake hydro generation.

⁷¹ The forecasts as prepared in early 2011 assumed load forecasts for 2012 and 2013 based on the long term trends as noted, and that the Mayo Lake Storage Enhancement Project (i.e., to reduce the licenced bottom storage at Mayo Lake by 1 metre) would be in service starting in 2012. Filing of the YESAB project proposal for the Mayo Lake Storage Enhancement Project is now not expected until later in 2011, and implementation of this project is now not expected prior to winter 2013/2014 at the earliest (more likely winter 2014/2015) – as a result, long term average hydro generation forecasts in the 2011 Resource Plan (which assume that this project is in place) are overstated, and diesel generation forecasts are understated, by about 4 GW.h per year for the period until the Mayo Lake Storage Enhancement Project comes into service. The 2011 Resource Plan also is not amended for any new Yukon Energy Business Plan forecasts developed during 2011 for the years 2012 and 2013.

1 Over the 2011 Resource Plan period non-industrial growth in Yukon is forecast to occur primarily on the
2 grid and at a higher rate than in the previous Resource Plan.

- 3 • The 2011 Resource Plan assumes non-industrial growth⁷² of 2.26% per year together with
4 sensitivities (reviewed in detail in Appendix C and Attachment C-1). Non-industrial annual growth
5 on WAF in the 2006 Resource Plan was projected at 1.85%, or 0.41 percentage points below the
6 forecast medium growth rate of 2.26% in the 2011 Resource Plan. This forecast non-industrial
7 growth is based on the methods developed for the 2006 Resource Plan (described in detail in
8 Appendix C, Attachment C-1). The medium growth rate is based on a combination of Whitehorse
9 population growth and Whitehorse residential Use per Customer (UPC)⁷³ (from 2001 to 2010) and
10 WAF medium-high growth per year (reflecting YEC's nine year average growth rate with native
11 YECL wholesales⁷⁴).
- 12 • The non-industrial growth forecast recognizes:
- 13 ○ Residential and commercial development continues to be evidenced in Whitehorse as
14 well as other areas along the 2001 to 2010 trend line⁷⁵.
- 15 ○ Ongoing Faro reclamation operation general sales loads expected to continue to reflect
16 2009/2010 experience (load projected for 2011 at 4.8 GW.h per year); based on
17 available information, it is assumed that current water pumping and treatment as
18 reflected in the 2010 loads will extend indefinitely.

⁷² Non-industrial includes residential, general service and lighting customer classes.

⁷³ Trends in average electricity use per customer throughout different Canadian utilities have reflected a variety of factors, including increased use of electronics, more efficient appliances, improved building insulation, and various other changes. Moderating impacts on customer use in many jurisdictions also reflect demand side management (DSM) programs implemented by the utilities. The modest growth rates in use per customer assumed in the Resource Plan Update forecast would presumably be reduced by any similar DSM program implementation in Yukon.

⁷⁴ Excluding Fish Lake impacts and impact of Pelly Crossing connection in 2008 and including all Faro dewatering loads after closure of the Faro mine in 1998.

⁷⁵ There is some sensitivity of firm wholesales to secondary wholesales, which varied considerably over this period and were suspended in September 2010 due to low water conditions. Firm wholesales include losses (approximating 7%) on secondary wholesales. In fall 2010, when secondary wholesales were suspended, the majority of secondary sales customers converted to firm service (impact approximates 0.7 GW.h in 2010 for partial year, reflecting ongoing annual impact of 1.5 GW.h).

1 The 2011 Resource Plan defines three near-term grid load scenarios to assess potential resource options
2 (forecast hydro and diesel generation requirements by year for each option is provided in Table 2-2):

- 3 • **Base Case** – The Base Case includes the non-industrial load forecast (annual growth of 2.26%)
4 plus forecast loads for currently connected mines (Minto and Alexco⁷⁶). Diesel generation is
5 forecast to increase from 1.5 GW.h/year in 2011 to 24 GW.h in 2015 and 42 GW.h in 2019;
6 based on the best available information at this time, currently connected mine loads are assumed
7 to shut down after 2020 and as a result grid diesel generation is forecast to decline to 16 GW.h in
8 2021; thereafter baseload diesel generation to supply only non-industrial loads increases to 40
9 GW.h in 2025 and almost 83 GW.h in 2030.
- 10 • **Scenario A** – Scenario A includes the Base Case plus connection of the Victoria Gold mine (i.e.,
11 the Eagle Gold Project at Dublin Gulch property) by 2014⁷⁷. Diesel generation is much higher
12 during the period when Victoria Gold is assumed to operate (until the end of 2020), increasing
13 from 92 GW.h in 2014 to 124 GW.h in 2019⁷⁸. Thereafter, based on the best available
14 information today, the Scenario A load forecast assumes that all of the mines assumed to be
15 connected to the grid are no longer operating and that no other mines would be seeking
16 connection to the grid. Under these assumed load assumptions, forecast diesel after 2020 is the
17 same as the Base Case.

⁷⁶ Alexco's existing mine is located at the Bellekeno mine site in the Keno region. Alexco is currently also operating a mill in the Keno region and plans to develop other mines in the vicinity to use this mill in the near-term.

⁷⁷ Load forecasts as prepared in early 2011 assumed, based on the then available information, Victoria Gold connection in late 2013 with the forecast loads shown here. The likely timing for such connection is currently under review with Victoria Gold, but is not now expected prior to the first quarter of 2014 (the 2011 Resource Plan load forecasts continue to assume connection in late 2013). The Victoria Gold power load forecasts are also currently under review: somewhat higher annual energy and capacity levels are being examined, with reduced levels required during peak winter months and higher levels during the balance of the year such that the overall net result would be little if any overall change in forecast annual grid diesel energy generation requirements (no changes have been made to the 2011 Resource Plan load forecasts for Victoria Gold to reflect such possible adjustments).

⁷⁸ On July 22, 2011 the Eagle Gold Project Proposal (Victoria Gold) completed the adequacy review stage of the YESAB assessment process and commenced the project screening stage. The Project Proposal posted on the YESAB website notes a 7.3 year active mining phase, with mining of the Phase 1 starter pit scheduled to commence mid-year 2013. The Project proposal assumes grid interconnection through a new 45 km and 69 kV transmission line. The 1.5 MW demand required during construction will be supplied through on site diesel generators. The average seasonal forecast for the operations phase is estimated to be 11 MW supplied by grid power with three emergency diesel generation sets available in the event of a power failure. Power demand for closure and reclamation phase has not yet been determined. For the purposes of the environmental assessment Eagle Gold has identified power supply as a valued ecosystem component.

- 1 • **Scenario B** – Scenario B includes the Base Case plus connection of the Victoria Gold mine by
2 2014, the Carmacks Copper mine⁷⁹ in late 2014 and Whitehorse Copper Tailings mine in spring
3 2013⁸⁰. Further increases in diesel generation are forecast, e.g., 112 GW.h in 2014, 176 GW.h in
4 2018 and 2019. By 2022 current planning scenario assumptions based on the best available
5 current information are that all connected mine loads are assumed to be shut down and forecast
6 diesel would return to Base Case levels. Delay in developing and connecting any of these mines
7 would result in corresponding extensions of the mine loads beyond 2021.

8 The three different grid loads described above demonstrate the impact of two different mine connection
9 scenarios over the period to 2021. Resource Plan forecasts have been prepared based on the best
10 available load information regarding potential connected mine loads and timing, and are subject to
11 change in the future in response to new information. See Table 2-1 and Figure 2-6 for a summary of
12 available information on potential mine and pipeline loads.

⁷⁹The Carmacks Copper mine, which is being developed by Copper North Mining Corp. (formerly Western Copper Corporation), completed its YESAB review process in September 2008 (when the Yukon Government issued a Decision Document accepting the YESAB recommendation that the project proceed). The subsequent Yukon Water Board hearing in early 2010 did not result in a water licence for the project. Subsequent to a court ruling on the YWB decision, Western Copper announced in March 2011 that it has initiated engineering studies to determine whether certain aspects of the project could be modified to improve the project's reclamation process and thus satisfy the main concern of the YWB, and is working with regulatory authorities in Yukon to establish the next steps towards getting the project fully licensed. Timing for development and connection of this mine remains very uncertain.

⁸⁰ Based on information available in early 2011. By fall of 2011, delays in timing for this project appear likely, but no changes have been made to the 2011 Resource Plan load forecasts for Scenario B. The load for this mine would be focused entirely in the non-winter season.

1

Table 2-1: Yukon Industrial Development Opportunities

Project	Proponent	Distance To Grid (km)	Peak Demand (MW)	Annual Energy (GW.h)	Project Life (yrs)	Assumed Earliest In-Service Date
Alaska Highway Pipeline Project (33 MW/station)						
Six compressor stations	Trans Canada Corp.	Varies	33x6	246x6	25	2020-21
One heater station	Trans Canada Corp.	NA	33	246	25	2020-21
Potential Mine Developments > 20 MW						
Casino Property	Western Copper and Gold	115 km	132	940.8	20-30+	2018-19
Northern Dancer	Largo Resources	65 km	30-35	200-300	29-30	late 2016 - 2017
Selwyn Project	Selwyn Resources Ltd	170	20	147	80	2014
11 to 20 MW						
Eagle Gold (Dublin Gulch)	Victoria Gold Corp.	45	13	95	7.3	2013 (late)
Coffee Gold Property	Kaminak Gold Corp	N/A	14-15	90	10+	2015
1 to 10 MW						
Carmacks Copper	Copper North Mining Corp.	12	10	52	6.5	2015
Whitehorse Copper Tailings	Eagle Industrial Minerals	0	2	8.7	6	2013
MacTung	North American Tungsten	250	6-8	58	11+	2015
Ketzka River	Yukon-Nevada Gold Corp.	85	2.5	2	6	2012(Dec)
Rau Gold	ATAC Resources Ltd	88 km	N/A	N/A	10	N/A
Brewery Creek	Golden Predator	N/A	N/A	N/A	N/A	N/A
Tagish Lake Gold Property	New Pacific Metals	N/A	4	N/A	N/A	N/A
White Gold	Kinross Gold Corp.	160	5-10	30-60	10	2017
Wolverine	Yukon Zinc Corp.	273	5.1	37	9.5	2010-11


2

Sources and notes: See Appendix C, Attachment C2.

3 It is recognized that a wide range of possible variations in loads may occur over the planning period to
4 2030, including delays in connection of specific mines, extensions in the life of any connected loads and
5 expansions or contractions in connected loads. Rather than attempt to define a certain number of
6 different load scenarios, Sections 4 to 6 test sensitivities of various resource options' cost effectiveness to
7 different potential extensions of mine loads beyond 2020, e.g., diesel displacement assumed with
8 Scenario A or Scenario B peak loads related to connected mines (e.g., in 2019) is extended to 2025 and
9 also to 2030 where relevant to test a resource option's sensitivity to currently projected mine loads.

1


Figure 2-6: Yukon Exploration Projects 2010



2

1 Figure 2-7 below provides forecast grid loads under the three grid load scenarios described above.

2 **Figure 2-7: Forecast Grid Loads: Base Case, Scenario A and Scenario B**




3

	2011	2015	2020	2025	2030
Non-Industrial Growth at 2.26%	339.3	371.9	417.0	467.5	523.9
Base Case					
Alexco	12.8	21.7	15.0	0	0
Minto	33.7	46.7	23.3	0	0
Total GWh	385.8	440.3	455.4	467.5	523.9
Scenario A (Base Case & Victoria Gold)					
Victoria Gold	0	102.6	102.6	0	0
Total GWh	385.8	542.9	558.0	467.5	523.9
Scenario B (Scenario A & CC and WHCT)					
Carmacks Copper	0	56.5	56.5	0	0
Whitehorse Copper Tailings	0	9.4	0.0	0	0
Total GWh	385.8	608.8	614.4	467.5	523.9

4

1 **Figure 2-8: Scenario B Forecast Grid load/Hydro Supply Gap: 2011-2030**



2

	2011	2015	2020	2025	2030
Total Grid Load	386	609	614	467	524
Total Hydro & Wind Generation	384	404	424	446	451
Diesel Requirement No DSM/SSE	2	158	163	40	83

3

4 Figure 2-8 above provides the total available hydro generation under Scenario B grid loads noted in
 5 Figure 2-7 (i.e., Scenario A and Carmacks Copper and Whitehorse Copper Tailings). Notably, under both
 6 Scenario A and Scenario B forecast grid loads there is increased hydro available to displace grid diesel
 7 generation⁸¹. Available hydro and diesel generation under each load scenario is provided in Table 2-2
 8 below.

⁸¹ Hydro generation forecasts are based on YEC's power benefits model which reflects long-term average net generation capability to displace diesel for each year at the forecast power demand – this net hydro generation increases as power demand increases, assuming WAF-MD grid connection by mid 2011, Mayo B in service (with the Mayo Lake Storage Enhancement Project) by start of 2012, and the current licence and Fish Act Authorization rules for Aishihik operation. Filing of the YESAB project proposal for the Mayo Lake Enhanced Storage Project is now not expected until later 2012, and implementation of this project is now not expected prior to winter 2013/2014 at the earliest (more likely winter 2014/2015) – as a result, long term average hydro generation forecasts in the 2011 Resource Plan (which assume that the Mayo Lake Enhanced Storage Project is in place) are overstated, and diesel generation forecasts are understated, by about 4 GW.h per year for the period until the Mayo Lake Enhanced Storage Project comes into service. The power benefits model analysis for the 2011 Resource Plan has also not been adjusted to reflect specific seasonal load shapes for specific mines – based on information as of the fall of 2011 (including potential changes to the Victoria Gold load forecasts), refinement of the power benefits model analysis to reflect specific seasonal load shapes for specific mines would not result in material changes to the diesel generation forecasts currently included in the 2011 Resource Plan.

1 **Table 2-2: Forecast Hydro Generation and Diesel Generation under Forecast Grid Loads:**
2 **Base Case, Scenario A and Scenario B**

Forecast Years	Base case		Scenario A		Scenario B	
	Hydro	Diesel	Hydro	Diesel	Hydro	Diesel
2011	383.3	1.5	383.3	1.5	383.3	1.5
2012	403.1	11.5	403.1	11.5	403.1	11.5
2013	407.5	15.1	419.6	29.0	423.2	34.8
2014	411.7	19.2	441.8	91.7	445.0	112.1
2015	415.6	23.7	443.0	98.9	449.7	158.1
2016	416.5	24.8	443.3	100.5	449.9	159.9
2017	420.2	29.9	444.5	108.2	450.5	168.1
2018	423.6	35.5	445.5	116.2	451.1	176.5
2019	426.8	41.5	446.5	124.4	451.1	176.2
2020	421.8	32.5	445.0	112.0	450.1	163.3
2021	409.1	16.6	409.1	16.6	415.8	24.0
2022	413.9	21.6	413.9	21.6	413.9	21.6
2023	418.4	27.3	418.4	27.3	418.4	27.3
2024	422.4	33.5	422.4	33.5	422.4	33.5
2025	426.2	40.3	426.2	40.3	426.2	40.3
2026	429.5	47.7	429.5	47.7	429.5	47.7
2027	432.6	55.7	432.6	55.7	432.6	55.7
2028	435.4	64.2	435.4	64.2	435.4	64.2
2029	437.8	73.2	437.8	73.2	437.8	73.2
2030	440.1	82.8	440.1	82.8	440.1	82.8

3

4 **2.3.2 Forecast Grid Capacity Requirements: 2011-2030**

5 Yukon Energy included an extensive review of grid capacity planning criteria in the 2006 Resource Plan.
6 This review resulted in new criteria being adopted for Yukon Capacity Planning purposes on the WAF and
7 MD grids.

- 8 • **Loss of Load Expectation (LOLE)⁸²** - In 2006, the system-wide capacity planning criteria for
9 WAF and MD provided that each integrated system would be planned not to exceed a Loss of
10 Load Expectation of 2 hours/year⁸³.

⁸² This is a probability based measure to evaluate the maximum loads that a grid system can safely carry by identifying the potential interruption of service for any customer (forecast of the average number of system outages per year). The LOLE criteria also recognize the role of transmission reliability, where relevant. The LOLE function is an average that does not indicate how long any particular outage will last, or the potential severity of consequences for customers – thus a further emergency standard (N-1 criteria) was also adopted.

- 1 • **Emergency (or “N-1”) Standard⁸⁴** - This criterion determines system capacity assuming the
2 loss of the system’s single largest generating or transmission-related generation resource. This
3 approved capacity planning criteria looks only at non-industrial grid loads and currently provides
4 for WAF sufficient winter peak capacity reserve to accommodate loss of the Aishihik transmission
5 connection to Whitehorse⁸⁵. It is recognized today that Aishihik hydro plant capability is being
6 increased to 37 MW (reflecting addition of the 3rd turbine in 2011); however, loss of the
7 Whitehorse transmission connection to the Aishihik hydro plant is considered the single largest
8 contingency on the grid system and, therefore, no Aishihik generation capability is included as
9 reliable capacity for purposes of the N-1 test.

10 The January 2007 YUB Report to Commissioner in Executive Council on the 2006 Resource Plan generally
11 recommended to the Yukon Government adoption of the capacity planning criteria as proposed by Yukon
12 Energy; however, the YUB’s report recommended that major industrial loads not be included in the LOLE
13 calculation⁸⁶. An approach that excludes industrials from the LOLE calculation would mean that normal
14 firm rates charged to these customers (as compared to some materially lower rate more akin to
15 secondary power) can likely only be justified if these customers are assured firm power supplies based on
16 inclusion of all such customers in LOLE calculations⁸⁷. On this basis Yukon Energy’s position is that
17 industrial loads must continue to be included in the LOLE calculation. The YUB has suggested that any
18 such issues be brought forward in subsequent applications⁸⁸.

⁸³ The WAF system has substantial hydro generation availability that is directly affected by certain transmission; the WAF system also has been trending to an increasing probability of longer outages as it expands (particularly with expansion of residential and commercial loads and major reductions in industrial load). Yukon Energy therefore in 2005 incorporated the LOLE approach, with recognition of transmission reliability where relevant, into its system planning criteria to better protect all of its firm customers from generation-related outages.

⁸⁴ Under this emergency standard, each integrated system (WAF and MD) is planned to be able to carry the forecast peak winter loads (excluding major industrial loads) under the largest single contingency (known as the N-1).

⁸⁵ In 2006 it was noted that for WAF the single most critical system component is the Aishihik transmission line and the largest single potential loss of supply at that time would be 30 MW (the installed Aishihik capacity) due to loss of transmission line from Aishihik to Whitehorse.

⁸⁶ See YUB Report to Commissioner in Executive Council re YEC 20-Year Resource Plan – Jan 2007 at page 10. The YUB’s recommendation was “in order to ensure that no new generating capacity is added for the purposes of ensuring reliable supply to major industrial customers and to ensure consistency with the N-1 criterion, major industrial loads should not be included in the LOLE calculation.” The YUB re-iterated this recommendation in Order 2007-5 at page 27.

⁸⁷ See for example response YUB-YEC-1-5 in the Part 3 hearing regarding Mayo B.

⁸⁸ See page 16 of YUB Report re Part 3 Review of CSTP.


1 ***Updated Assessment of N-1 Standard for 2011 Resource Plan***

2 Table 2-3 below sets out the current grid generating units and rating (MW capability assumed for winter
3 peak period) by location and utility, comparing capacity rating by unit today with what was provided in
4 the 2006 Resource Plan. Table 2-3 also includes current assumed retirement dates by unit. In summary,
5 grid capacity shortfalls under the N-1 capacity planning criteria are materially impacted by potential diesel
6 plant retirements prior to 2030 (Table 2-2 indicates a total 35.6 MW reduction in diesel capacity over the
7 planning period that includes all current YEC reliable diesel plant)⁸⁹.

8 Figure 2-9 below shows the N-1 grid capacity planning MW surplus (shortfall) for 2011-2030 assuming
9 diesel units planned to retire are not life-extended or replaced.

⁸⁹In the 2006 Resource Plan, YEC proposed Life Extension plans for all existing Mirrlees units at Whitehorse. Since that time YEC has proceeded with refurbishment of the Mirrlees unit at Faro and one Mirrlees unit at Whitehorse (these units are now planned to retire in 2021). These refurbishments of 9 MW were completed at an average cost of approximately \$0.467 million/MW, excluding the WD3 generator rebuild. YEC currently plans to retire the two remaining Mirrlees units, reflecting significant increases experienced in off engine equipment requirements as engines approach end of life (e.g., cooling system, HVAC systems, electrical systems, air start systems) and changes in availability of parts and service support. The WD 2 unit will be used as spare parts for WD3 and FD1.

1 **Figure 2-9: Grid Capacity Capability & N-1 Capacity Requirements – 2011-2030 (MW)**



	2011	2015	2020	2025	2030
Existing Plant (MW)	116.2	108.2	101.9	86.4	80.6
Requirement without DSM/SSE (MW)					
N-1 Requirement	104.7	111.1	120.0	129.9	141.0
Surplus (shortfall) (MW)	11.6	-2.8	-18.0	-43.5	-60.4

2

3 Figure 2-9 indicates grid capacity shortfalls emerging in 2015, and expanding thereafter, under the N-1

4 capacity planning criteria and assuming diesel units planned to retire are not life-extended or replaced.

5 This assessment is based only on forecast non-industrial loads on the integrated grid and is therefore not

6 affected by load forecast variations related to different potential industrial loads.

1

Table 2-3: Current Integrated Grid Generating Complement

Unit	2006 Resource Plan Rating (MW)	2011 Resource Plan Rating (MW)	Expected Retirement Date
Whitehorse Hydro (winter for all units)	24.00	24.00	NA
Whitehorse diesel #1 (Mirrlees)	3.00	3.50	2014
Whitehorse diesel #2 (Mirrlees)	4.20	4.50	2015
Whitehorse diesel #3 (Mirrlees)	4.20	4.50	2021
Whitehorse diesel #4 (EMD)	2.50	2.25	2025
Whitehorse diesel #5 (EMD)	2.50	2.25	2025
Whitehorse diesel #6 (EMD)	2.70	2.50	2025
Whitehorse diesel #7 (Caterpillar)	3.30	3.00	2026
Faro Diesel #1 (Mirrlees)	0.00	4.00	2021
Faro Diesel #3 (Caterpillar)	1.00	0.85	2019
Faro Diesel #5 (Caterpillar)	1.30	1.20	2020
Faro Diesel #7 (Caterpillar)	3.00	2.80	2027
Aishihik #1	15.00	15.00	NA
Aishihik #2	15.00	15.00	NA
Aishihik #3	0.00	7.00	NA
Carmack's Diesel (YECL)	1.30	1.60	
Pelly Crossing (YECL)	0.00	0.98	
Haines Junction diesel (YECL)	1.30	1.75	
Teslin diesel (YECL)	1.30	1.50	
Ross River diesel (YECL)	1.00	1.00	
Fish Lake hydro (2 units - YECL, winter capacity)	0.40	0.40	
Total WAF	<u>87.00</u>	<u>99.58</u>	
Dawson diesel #1 (Caterpillar)	0.80	0.72	2018
Dawson diesel #2 (Caterpillar)	1.00	0.92	2017
Dawson diesel #3 (Caterpillar)	1.00	0.92	2020
Dawson diesel #4 (Caterpillar)	0.70	0.00	
Dawson diesel #5 (Caterpillar)	1.50	1.40	2031
Mayo diesel #1 (Caterpillar)	1.00	0.85	2019
Mayo diesel #2(Caterpillar)	1.00	0.85	2019
Mayo hydro (winter all units)	5.40	11.00	NA
Stewart Crossing diesel (YECL)	0.00	0.40	
Total MD	<u>12.40</u>	<u>17.06</u>	
Total Integrated System -Winter Capacity (incl. Fish Lake)	99.40	116.64	
Grid Winter Capacity after N-1 event (excl. Fish Lake)	67.70	77.49	

2

1 ***Updated Assessment of LOLE Criteria for 2011 Resource Plan***

2 Under the LOLE capacity planning criteria in the 2006 Resource Plan (see Appendix D), additional grid
3 capacity would be required in the near-term under the Base Case, Scenario A and Scenario B in response
4 to forecast grid mine loads in excess of about 13 MW (see Appendix C, Attachment C2, Table C2-2) from
5 late 2013 until approximately 2020⁹⁰. By the 2012 timeframe, industrial loads are projected to increase to
6 the level where LOLE criterion as set out in the 2006 Resource Plan would begin to become relevant for
7 capacity planning purposes; however, based on forecast load requirements over the resource planning
8 period, and to the extent that industrial loads become relevant for capacity planning, the LOLE criterion
9 would become relevant over a relatively brief period (with industrial loads currently forecast to shutdown
10 by 2021).

11 For the 2011 Resource Plan, Yukon Energy has reviewed the adequacy of the capacity planning criteria
12 given the material changes on the integrated grid system since the last review (i.e., integration of MD
13 and WAF grids through completion of CSTP and Mayo Hydro Enhancement project)⁹¹. Preliminary results
14 from the LOLE review suggest that the earlier model assessments of LOLE for WAF may still be usefully
15 applied for the integrated grid, subject to the 25 km line L172 between Takhini and Whitehorse being
16 appropriately reinforced so as to provide no line constraint.

17 Estimated required added capacity under Scenario A and B loads is assessed (see Figure 2-10) based on
18 the assumption that grid industrial peak winter load requirements in excess of 13 MW add directly to the
19 required grid capacity⁹² and that diesel units planned to retire are not life-extended or replaced.

20 On this basis, the following added capacity requirements (relative to the N-1 assessment) are assumed
21 when the LOLE capacity planning criteria is applied with forecast industrial loads (see Figure 2-10 for the
22 resulting capacity shortfall forecasts)⁹³.

⁹⁰In its recent Part 3 Report on Mayo B, the YUB noted that YEC intended to produce an LOLE model of its integrated system and to conduct a study of future generating capacity requirements utilizing this model for future review as part of the five-year update of its 20-Year Resource Plan (see page 17 of YUB Report re: Part 3 review of Mayo B).


its recent Part 3 Report on Mayo B, the YUB noted that YEC intended to produce an LOLE model of its integrated system and to conduct a study of future generating capacity requirements utilizing this model for future review as part of the five-year update of its 20-Year Resource Plan (see page 17 of YUB Report re: Part 3 review of Mayo B).

⁹² Estimated based on LOLE assessments update with Victoria Gold load distribution.

⁹³ Victoria Gold capacity during winter is assumed at 13 MW based on forecasts available in early 2011. This is subject to ongoing review (more recent information suggests that the winter peak requirement may be materially reduced).

- 1 • **Base Case:** No added capacity needed under LOLE over N-1. The capacity shortfall in 2015 is
- 2 approximately 3 MW, increasing to 18.0 MW in 2020.
- 3 • **Scenario A:** Added capacity of 10 MW needed in 2015 through 2020 and no impacts after 2020.
- 4 The capacity shortfall in 2015 is approximately 13 MW, increasing to 27 MW in 2020.
- 5 • **Scenario B:** Added capacity of 18 MW needed in 2015 through 2020 and no impacts after 2020.
- 6 The capacity shortfall in 2015 is approximately 21 MW, increasing to 35 MW in 2020.

Figure 2-10: Grid Capacity Capability Requirements – 2011-2030 (MW)



	2011	2015	2020	2025	2030
Existing Plant (MW)	116.2	108.2	101.9	86.4	80.6
Requirement without DSM/SSE (MW)					
N-1 Requirement	104.7	111.1	120.0	129.9	141.0
Surplus (shortfall) (MW)	11.6	-2.8	-18.0	-43.5	-60.4
LOLE - Base Case	104.7	111.1	120.0	129.9	141.0
Surplus (shortfall)	11.6	-2.8	-18.0	-43.5	-60.4
LOLE - Scenario A	104.7	121.1	129.1	129.9	141.0
Surplus (shortfall)	11.6	-12.8	-27.1	-43.5	-60.4
LOLE - Scenario B	104.7	129.1	137.1	129.9	141.0
Surplus (shortfall)	11.6	-20.8	-35.1	-43.5	-60.4

1 **2.4 CAPACITY & ENERGY RELATED CHALLENGES FOR EXISTING GRID UNDER**
2 **FORECAST LOADS**

3 **Challenge to Displace Diesel Energy Generation**

4 Based on the 2011 Resource Plan grid load forecasts, the major near-term challenge for the next five
5 years in particular is to reduce costs and GHG emissions by displacing diesel energy generation that
6 would otherwise be required between 2014 and 2021. Assuming that the current Yukon mining boom is
7 sustained, the very large longer-term challenge highlighted by the 2011 Resource Plan load forecasts is
8 to secure long-term grid load growth beyond 2021 sufficient to achieve low cost and low GHG emission
9 legacy energy supply project development.

10 These conclusions reflect the following summary of capacity and energy related challenges for the
11 existing integrated grid under the forecast loads during the 20-year planning period:

12 • **Capacity:**

- 13 ○ In the next 5 to 10 years, the grid capacity challenge relates mostly to replacement on
14 retirement of between 8 MW and 23 MW of diesel generation assets, and providing
15 between 3 MW and 24 MW of additional reliable peak winter capacity for added industrial
16 loads, as required, under the LOLE criteria.
- 17 ○ Within the 20 year planning period, replacement of all (35.6 MW) YEC diesel capacity is
18 expected to be required plus a further 25 MW of new capacity by 2030.
- 19 ○ Under the Scenario A or B load forecasts, industrial loads within the next 5 years are
20 forecast to accelerate the need for new capacity that will otherwise be required later
21 within the 20-year planning period.

22 • **Energy:**

- 23 ○ The grid energy challenge throughout the 20-year planning period is to reduce costs and
24 GHG emissions by displacing diesel energy generation that would otherwise be required.
- 25 ○ Existing and committed grid generation resources can fully supply the near-term forecast
26 annual and seasonal energy loads during the 20-year planning period⁹⁴.

⁹⁴ Assumes replacement of diesel generation assets on retirement and added diesel capacity as required under the capacity planning criteria (N-1 and LOLE); applicable even with all potential new grid connected mine loads forecast prior to 2021 under Scenarios A or B.

1 ○ With the diminished surplus hydro generation available today, continued reliance on the
2 existing grid system (i.e. prior to considering new non-diesel resource options) to address
3 load growth will require increased reliance on costly diesel generation to meet energy
4 loads. By 2015, grid diesel generation is forecast to increase from 2 GW.h/year in 2011
5 to 23.7 GW.h under the Base Case (no new mine connections), to 98.9 GW.h under
6 Scenario A loads, and to 158.1 GW.h under Scenario B loads. After 2021, when no mine
7 loads are currently forecast to be connected, grid diesel generation is forecast to grow
8 from 21.6 GW.h in 2022 to 82.8 GW.h in 2030.

9 The predominance of hydro generation on the Yukon system, combined with the fact that Yukon is
10 isolated from other grids outside the territory, means that backup capacity is required to supplement
11 available hydro in circumstances of low water or drought. The substantial diesel capacity on the grid
12 provides this required backup capability.

13 However, diesel energy generation as projected under the forecast loads (particularly under load
14 Scenarios A or B) defines a significant challenge for the existing grid during the planning period – a
15 challenge not faced since the Faro mine closed in 1998 and a challenge made much more difficult today
16 by higher diesel fuel prices plus policy concerns about GHG emissions from diesel fuel generation.

17 As will be reviewed in Sections 3 and 4, this challenge can be addressed in part through programs to
18 reduce loads (Demand Side Management) and improve the efficiency of the existing grid (Supply Side
19 Enhancement). However, the Scenario A and B load forecasts in particular define sharp jumps in diesel
20 energy generation potentially as soon as 2014-2015. Aside from the challenge inherent in developing new
21 and less costly supply in Yukon within such a short time period, the Scenario A and B load forecasts also
22 show sharp reductions in diesel energy generation potentially as soon as by 2021. This means that any
23 new supply must also be very flexible (as well as less costly than diesel) in order to accommodate such
24 major potential load swings within such a short time period.

25 Longer-term legacy supply resource development during the planning period will require sustained ability
26 to displace sufficient forecast diesel generation on the grid. The 2011 Resource Plan load forecasts show
27 that the opportunity to secure such loads will likely be dependent upon the extent to which the current
28 Yukon mining boom is sustained and can provide the foundation for long-term grid load levels sufficient
29 to achieve legacy energy supply project development.

30 • Looking beyond the near-term, the 2011 Resource Plan grid load forecasts show steady growth
31 in diesel generation requirements after 2021; however, by 2030 these requirements are still
32 expected to remain below the 2014 Scenario A forecast diesel generation unless connected mine
33 loads are sustained.

- 1 • At the same time, off-grid industrial load forecasts show the potential for dramatic growth if the
2 current Yukon mining boom is sustained. This includes the potential development within the next
3 10 years of three major new mines (i.e., Casino, Selwyn and Northern Dancer), each with annual
4 energy requirements ranging from 100 to 941 GW.h. Each of these mine loads is expected to
5 continue for 20 years of operation (or longer).

6 **Challenge to Displace Seasonal Diesel Requirements**


7 Forecast diesel requirements for the Yukon grid in any year are concentrated in the winter/spring
8 seasons. The challenges related to this reality reflect the following distinctive factors affecting the Yukon
9 grid (also see Figure 1-1):

- 10 • Seasonal grid loads (which peak in winter and are lowest in summer);
- 11 • Current hydro generation supply (which tends towards surplus in summer, is constrained in
12 winter, and is also highly variable from year-to-year); and
- 13 • The isolated nature of the Yukon grid which prevents any export sale of surplus summer/fall
14 renewable generation or import of non-Yukon generation.

15 Figure 2-11 demonstrates the extent to which grid diesel generation is concentrated in winter-spring
16 months under mean water flow⁹⁵ with an annual grid load of 545 GW.h (reflects the approximate
17 Scenario A load with Victoria Gold in 2015-2016). Under this load, 69% of diesel generation occurs in four
18 winter months (December to March), and only 2% occurs in the five summer/fall months (June to
19 October).

⁹⁵ Average of all water years of record [1981-2008] and 20 "load years" (each examines a different hypothetical scenario to reflect different sequences of the recorded water years), of which 13 load years are used for the final averaging (this deletes cases where starting or ending volumes can distort results). In total, 364 cases are examined 28 water years and 13 load years).

1 **Figure 2-11: YEC Grid Electricity Seasonal Generation by Source: Mean Flows**
 2 **(average of all water years) at 545 GW.h/year Grid load net of Fish Lake and Wind**



3

GW.h	Jan-Mar Wks 1-13	April Wks 14-17	May Wks 18-22	June-Oct Wks 23-44	Nov Wks 45-48	Dec Wks 49-52	Annual
Diesel Generation	59.9	17.2	9.1	1.9	3.2	9.8	101.1
	59%	17%	9%	2%	3%	10%	100%
Hydro Generation	100.5	25.3	37.1	199.0	41.3	40.6	443.9
	23%	6%	8%	45%	9%	9%	100%
Total Generation	160.4	42.5	46.2	201.0	44.5	50.4	545.0
	29%	8%	8%	37%	8%	9%	100%

4

5 Concentration of diesel generation outside the summer-fall period remains a key feature of the Yukon
 6 grid under a wide range of load and water flow conditions, as demonstrated by the following examples:

- 7
- 8 • Under a 610 GW.h/year “high” load scenario (Scenario B) for 2015-16 and in an average water
 9 year, over 95% of the direct diesel displacement opportunities occur in the seven month period
 10 from November to May (i.e., less than 5% of direct diesel displacement opportunities occur in the
 11 five summer/fall months (June to October)).
 - 12 • Under a 610 GW.h/year “high” load scenario and the lowest water year at this load (1996), over
 90% of the average diesel displacement opportunities in that water year still occur in the seven

1 month period from November to May (i.e., diesel direct displacement opportunities in summer/fall
2 remain minimal at these loads even in the lowest water year))⁹⁶.

3 In response to the seasonal diesel challenge, non-diesel resource options for the Yukon grid that
4 concentrate generation in winter/spring months will clearly be better able to directly displace diesel
5 generation than resource options that are concentrated in summer/fall months. Resource options that
6 provide increased generation during summer/fall (e.g., wind or a biomass thermal plant requiring year-
7 round operation) will in effect displace hydro generation⁹⁷. However, indirect diesel displacement benefits
8 will occur from displacing hydro generation during summer/fall to the extent that enhanced hydro storage
9 is facilitated during summer/fall that allows increased hydro generation during winter/spring.

10 Figure 2-12 provides an illustrative example of the projected impact a 21 MW wind project would have on
11 seasonal and annual grid generation (mean water flow capability) at an annual grid load of 545 GW.h.
12 The wind project is assumed to provide 55.8 GW.h of new generation over the year with significantly
13 higher generation in winter than during summer⁹⁸.


- 14 • About 62% of the wind generation (34.6 GW.h) is able to directly displace diesel generation,
15 primarily in winter/spring months – the balance of the wind generation (38% or 21.2 GW.h)
16 displaces hydro generation, primarily in the summer/fall months.
- 17 • However, slightly over two-thirds (69%) of the displaced hydro is able to be stored in this case –
18 and used to displace diesel generation during winter/spring months.
- 19 • As a result, the wind project on average displaces 49.2 GW.h of diesel generation, with 70% of
20 this displacement occurring directly and the balance (30%) through incremental hydro generation
21 from use of incremental stored water resulting from the wind generation.
- 22 • The balance of the wind generation (6.6 GW.h) displaces hydro generation that is spilled and
23 lost.

⁹⁶ See Figure D-6B in Appendix D.

⁹⁷ The concept of wind or wood biomass thermal operation “displacing” generation from existing hydro resources assumes that the wind or wood biomass operation is not suspended at such times as hydro generation cannot be used, i.e., water is spilled rather than used to run the generators. For the purpose of highlighting the challenges related to the existing hydro grid, this concept is retained in this analysis. However, where feasible, YEC would not in practice allow existing hydro generation to be displaced by other more costly sources of generation.

⁹⁸ The assumed wind generation approximates 1.5 GW.h/week during winter months versus less than half this level during summer.

1 **Figure 2-12: YEC Grid Electricity Seasonal Generation by Source: Mean Flows**
 2 **(average of all water years) with 21 MW Wind Project Displacing Diesel and Displacing**
 3 **Hydro at 545 GW.h/year Grid Load (Scenario A 2015-16 load)**



4

	Without Wind Project	With 21 MW Wind Project	Change	Breakdown of Wind Generation Impacts (GW.h/yr)
Grid Generation at 545 GW/h load* (GW.)	545.0	545.0		
Grid Load	545.0	545.0		Directly Displacing Diesel 34.6
Grid Generation				Directly Displacing Hydro
Hydro*	443.9	437.3	(6.6)	Stored Hydro Displacing Diesel 14.6
Diesel	101.1	51.9	(49.2)	Spilled Hydro (not required)** 6.6
Wind*	-	55.8	55.8	Total Wind Project Generation 55.8
Total	<u>545.0</u>	<u>545.0</u>		

* Existing Wind and Fish Lake generation not included.

Total Displaced Diesel = 34.6 + 14.6 = 49.2 GW.h

**This figure provides an example that illustrates impacts this supply option would have on the existing generation system;

5 This does not suggest YEC would operate the system in a manner that results in hydro being displaced by other forms of more costly generation

6 The impacts of new renewable resource on existing hydro facility generation will vary widely depending
 7 on the assumed grid loads and the assumed seasonal distribution of the new renewable generation. For
 8 example, at roughly the same annual load as assumed in Figure 2-12 (542.9 GW.h before DSM/SSE) and
 9 with assumed demand side management and supply side enhancement (DSM/SSE) as reviewed in
 10 Section 4 (reducing grid load to 526.5 GW.h), stored hydro would account for a lower percentage (56%)
 11 of hydro displaced by this same 21 MW wind generation.

1 Thermal waste-to-energy (Municipal Solid Waste or MSW) or wood biomass thermal projects, with
2 assumed steady levels of generation throughout the year⁹⁹, will also displace hydro generation during
3 summer months and thereby result in widely varying incremental stored hydro capability to displace
4 diesel generation during winter/spring months, depending on the grid load as well as the scale of the
5 thermal generation project. The following examples are noted at grid loads approximating 545
6 GW.h/year:

- 7 • Small waste-to-energy projects (1.4 to 2.2 MW) generating between 10.8 and 17.1 GW.h/year
8 will utilize 81 to 83% of this generation to displace diesel, either directly or through incremental
9 stored hydro generation. Slightly over 60% of hydro generation displaced by these projects
10 would be used as incremental stored hydro generation at this assumed load.
- 11 • With a 15 MW wood biomass project and 545 GW.h/year load, about 37% of the hydro displaced
12 by the biomass generation is re-used as incremental stored hydro generation (this re-use
13 percentage falls to 27% if DSM/SSE are assumed as in Sections 4 and 5 and the grid load falls to
14 526.5 GW.h).
- 15 • In contrast, with a 25 MW wood biomass project at 545 GW.h/year load only about 13% of the
16 hydro displaced by the biomass generation is re-used as incremental stored hydro generation
17 (this re-use percentage falls to 5% if DSM/SSE are assumed as in Sections 4 and 5 and the grid
18 load falls to 526.5 GW.h).


19 To demonstrate the differences discussed above, Figure 2-13 shows the grid generation by week at the
20 545 GW.h load with a 25 MW wood biomass project generating 197 GW.h/year. This level of renewable
21 generation on the Yukon grid at the 545 GW.h grid load succeeds in displacing forecast diesel generation
22 - however, on average the level of displaced available hydro that is spilled (95.9 GW.h/year) under the
23 assumed biomass plant operation is almost as large as the diesel displaced (101.1 GW.h/year), and only
24 about 51% of the wood biomass generation is used to displace diesel generation.

25 In effect, the above analysis underlines the overriding need for any inflexible generation supply source
26 (such as assumed in the above examples) to be scaled to the extent feasible to match the diesel
27 generation to be displaced. Developing new generation that cannot displace diesel generation would be

⁹⁹ Unlike wind, the assumed inflexibility of operation for these specific renewable thermal generation reflects assumed economic factors rather than technology requirements. If required, waste or wood biomass generation plants could be shut down for a season or any other specific time period – the relatively high cost of such shut downs, however, would be related to the high capital cost per MW for these options (other aggravating factors might also be related to seasonal supply realities).

1 wasteful – a factor which is demonstrated, for example, when explaining why long-term large hydro
 2 resource developments in Yukon (which offer local renewable supply with minimal GHG emissions) would
 3 not be economically feasible without first securing long-term diesel displacement loads to at least match
 4 the new hydro generation to be developed. The same principles that apply at an annual load level also
 5 apply at the seasonal load level, subject to the ability to facilitate enhanced hydro storage for use during
 6 the winter season¹⁰⁰.

7 **Figure 2-13: YEC Grid Electricity Seasonal Generation by Source: Mean Flows**
 8 **(average of all water years) with 25 MW Wood Biomass Project Displacing Diesel and**
 9 **Displacing Hydro at 545 GW.h/year Grid Load (Scenario A 2015-16 load)**



10

Grid Generation at 545 GW/h load* (GW.h)	Without Biomass Project	With 25 MW Biomass Project	Change	Breakdown of Biomass Generation Impacts (GW.h/yr)	
Grid Load	545.0	545.0		Directly Displacing Diesel	87.0
Grid Generation				Directly Displacing Hydro	
Hydro*	443.9	348.0	(95.9)	Stored Hydro Displacing Diesel	14.1
Diesel	101.1	-	(101.1)	Spilled Hydro (not Required)**	95.9
Biomass	-	197.0	197.0	Total Biomass Project Generation	197.0
Total	545.0	545.0			

* Existing Wind and Fish Lake generation not included.

Total Displaced Diesel = 87.0 + 14.1 = 101.1 GW.h

**This figure provides an example that illustrates impacts this supply option would have on the existing generation system;

This does not suggest YEC would operate the system in a manner that results in hydro being displaced by other forms of more costly generation

11

¹⁰⁰ The underlying economic feasibility issues noted here are not resolved by resort to secondary sales (interruptible sales) of the surplus hydro. The basic premise of secondary sales is that, at most, very limited investment is made to facilitate such sales, and that such sales are incidental to the project's primary objectives (see response to YUB-YEC-1-44, YEC Mayo B Application for an Energy Project Certificate). On a seasonal basis, secondary sales opportunities in Yukon are also weakest in summer (i.e., the season when diesel generation displacement opportunities are minimal). In summary, while secondary sales would continue to be promoted during periods of hydro surplus in order to reduce overall costs charged to firm service customers, such secondary sales cannot provide a sound economic rationale for planned developments that create surplus hydro on the grid.

1 Challenge to Displace Diesel Generation with Widely Varying Annual Hydro Generation

2 Forecast diesel generation at any specific annual grid load is highly variable by year, as well as by season
3 within the year, due to widely varying annual hydro generation. This annual variability creates added
4 flexibility requirements for any new resource developed to displace grid diesel generation.


5 Annual average diesel energy generation on the grid as shown by week in Figure 2-11 reflects averages
6 of widely varying annual water flow conditions. With annual loads at a 545 GW.h annual average diesel
7 generation is projected at 101.1 GW.h/year in Figure 2-11. This average however, includes diesel
8 generation ranging from 13.0 GW.h/year under extreme high water conditions to 198.8 GW.h under
9 extreme low water conditions.

10 As shown in Figure 2-14, similar variability in annual water conditions is shown at lower (442 GW.h/year)
11 and higher (610 GW.h/year) grid loads, reflecting the approximate range of grid loads in 2015-16 under
12 low (Base Case) and high (Scenario B) 2011 Resource Plan forecasts¹⁰¹.

13 This annual variability in hydro generation is a key feature of the Yukon grid affecting the diesel
14 displacement impact to be expected from any new renewable resource. The isolated nature of the Yukon
15 grid prevents any export sale of surplus renewable generation during summer months or during high
16 water years. In effect, when water is available for hydro generation, YEC faces the reality that this water
17 must either be used or lost (spilled) unless it can be stored. Seasonal water storage exists at Aishihik
18 Lake and (to a much more limited extent) at Mayo Lake – Aishihik Lake can also provide limited annual
19 storage.

¹⁰¹ See Section 4 of Appendix D, and specifically Table D-2 and Figures D-5 to D-7. "Extreme or Median Load Year" is one year out of the 364 cases examined (28 water years and 13 load years). "Averaged Load Years" are the average annual value for a water year calculated over all 13 load years. For the 545 GW.h/year grid load, the extreme low water diesel generation for Averaged Water Year would require 166.7 GW.h/year diesel generation (reflects 1996 water year of record), and the extreme high water diesel generation for Averaged Water Year would require 34.1 GW.h/year diesel generation (reflects 1992 water year of record).

Figure 2-14: YEC Annual Grid Diesel Generation Variability at Different Grid Loads (GW.h/yr)



Annual Diesel Generation (GW.h/yr)	Annual Grid Load (GW.h/yr)		
	442	545	610
Mean Capability	24.6	101.1	160.2
Median Water Conditions (Median Load Year)	13.6	98.6	155.7
Extreme Low Water	119.7	198.8	263.8
Extreme High Water	0.1	13.0	46.2

Based on Yukon’s grid conditions, it is desirable to balance the available hydro generation with flexible thermal generation (such as diesel) which has low capital cost to provide capacity and can also be operated on an “as needed” basis. As shown, the hydro generation variability in any year accordingly results in high variability in forecast annual diesel generation:

- Annual diesel generation for any specific load scenario is below average in many (perhaps most) years (e.g., under the 545 GW.h/year “mid” load scenario), diesel generation is less than the average 101 GW.h in 15 of the 28 water years, and less than 86 GW.h in 10 of the 28 water years. This variability highlights one of the challenges facing renewable resource options intended to displace diesel generation on the grid (i.e., reduced generation requirements in many years may undermine the cost effectiveness of a new renewable resource).
- Annual hydro variability also creates the need to rely on greater-than-average diesel generation in drought years. For example, diesel generation capacity required under extreme low water years would approximate 119.7 GW.h at the 442 GW.h/year at the Base Case load in 2015-16,

1 about 198.8 GW.h at the 545 GW.h/year Scenario A load in 2015-16, and about 263.8 GW.h at a
2 610 Scenario B load in 2015-16 – these requirements will be moderated in practice to the extent
3 that water storage is able to be facilitated by non-hydro generation during summer months¹⁰².

4 **Summary Challenge for Diesel Displacement Resource Options**

5 In summary, non-diesel resource options will be more effective in displacing diesel generation to the
6 extent that they can be focused in the priority diesel generation periods (winter/spring) and flexible to
7 address annual hydro variability. This reality reflects the lack of grid connection in Yukon to external
8 markets - and the resulting need to ensure where feasible that local generation matches the local grid
9 load requirements (as surplus generation cannot otherwise be usefully used or sold).

10 For example, flexible thermal generation non-diesel resource options (e.g., natural gas/LNG combustion
11 turbines) which can be shut down as required when hydro generation can supply all of the load will tend
12 to operate at low (40-55% range) annual average capacity factors based on the summer/fall hydro
13 capability on the grid. In contrast, flexible thermal generation options also intended to displace average
14 water year diesel generation will require peak winter generation capacities in excess of the average year
15 requirements in order to displace diesel requirements during extreme low water years.

16 In contrast, inflexible resource options (e.g., wind) that cannot be shut down as required when hydro
17 generation can supply all of the load will result in varying levels of generation (e.g., during summer/fall
18 seasons and during higher water years) that cannot currently be used to displace diesel on the Yukon
19 grid. As demonstrated above, similar unused generation will occur for thermal generation options (e.g,
20 wood or waste biomass generation) which are assumed to operate at high annual capacity factors in
21 order to secure high utilization of the capital cost resources. The degree of such unused generation will
22 be very sensitive to the overall scale of the resource option (e.g., the wasted generation will typically be
23 much greater for a 25 MW facility than for a 2 MW facility).

24 In order to address these Yukon-specific challenges, assessment of the cost effectiveness of new non-
25 diesel resource supply options in the 2011 Resource Plan is based on costs per kW.h of actual diesel
26 generation displaced or “net generation” (considering annual generation impacts and seasonal variability)

¹⁰² Under the lowest water years peak diesel generation capacities required may be higher, e.g., based on weekly generation averages for each water year, peak diesel generation capacities required could approximate 37 MW at the 442 GW.h/year “low” scenario, about 55 MW under the 545 GW.h/year “mid” load scenario, and about 64 MW under the 610 GW.h/year “high” load scenario.

1 rather than on the costs per kW.h generated by the option¹⁰³. At a simple level, the impacts of this
2 approach can be demonstrated as follows:

- 3 • A non-diesel resource option will typically be initially examined in Section 3 (reflecting the March
4 2011 Charrette) to show costs per kW.h assuming full utilization of all generation, e.g., a wind
5 resource costing \$7.5 million per year and generating 50 GW.h per year will be shown to have an
6 average cost of 15 cents per kW.h. This generation will occur throughout the year, and not vary
7 depending on the level of hydro generation that occurs in any year. Lifetime present value costs
8 for the resource (Levelized Cost of Energy or "LCOE") will similarly assume full utilization of the
9 50 GW.h during each year of the assumed project life.
- 10 • However, the 2011 Resource Plan in Sections 5 and 6 will examine the extent to which each non-
11 diesel resource option's generation is forecast to displace diesel generation, taking into account
12 forecasts grid loads each year, seasonal generation from existing and committed generation
13 resources (other than the new non-diesel resource) and annual variability in hydro generation
14 due to variable water conditions.
- 15 • For example, if in a given year the wind resource in the above example is only forecast to
16 displace 25 GW.h, then the wind cost will be assessed in that year at 30 cents/ kW.h (not 15
17 cents), reflecting the cost per kW.h of diesel displaced (i.e., per kW.h of useful generation).
- 18 • Over the economic life of the each non-diesel resource option, a lifetime average present value
19 cost per kW.h will be determined that reflects that lifetime useful generation able to displace
20 diesel generation – this lifetime cost will reflect the forecast diesel generation without the wind
21 resource (including annual seasonal and hydro variability, as well as sharply reduced diesel in
22 years when mine loads are not forecast to be connected).

23 As discussed in Section 3, Full Utilization LCOE (i.e., assumes all generation fully used to displace diesel)
24 and Forecast LCOE (i.e., looks at forecast ability to displace diesel generation) for any specific non-diesel
25 resource option can vary significantly. Based on Yukon realities and load forecasts, the Forecast LCOE
26 provides the assessment required of a resource option's ability to displace diesel generation.

¹⁰³ This approach is consistent with the assessments that Yukon Energy provided of the Mayo B Project during regulatory reviews, including review by the Yukon Utilities Board.

1 **3.0 RESOURCE PLANNING OPTIONS – OVERVIEW AND SCREENING**

2 **3.1 INTRODUCTION**

3 Section 3 and Sections 4 to 6 identify and evaluate resource planning options for implementation by
4 Yukon Energy over the next five years (2011-2015), focusing on the need to determine:

- 5 • Preferred near-term major project options to be committed before 2015 to meet energy and
6 capacity requirements in Yukon out to 2017;
- 7 • Appropriate planning activities during 2011-2015 to protect longer-term legacy resource
8 development options for potential start of construction before 2021; and
- 9 • Appropriate planning activities during 2011-2015 to protect longer-term legacy resource
10 development options for potential development after 2021.

11 Consistent with the 2006 Resource Plan, this planning level assessment is based on currently available
12 information regarding grid and off-grid forecast and potential energy and capacity requirements (Section
13 2) and available resource supply alternatives. Several planning stages are required after the 2011
14 Resource Plan prior to any YEC decision to proceed with construction for any preferred project¹⁰⁴.

15 Reflecting the March 2011 Charrette outcomes, near and longer-term options are assessed concurrently
16 in the context of overall Yukon requirements (i.e., off-grid as well as on-grid for all major power loads as
17 reviewed in Section 2), agreed upon resource planning principles (as reviewed in Section 1), and the
18 assumption that Yukon Energy is proceeding with a robust and aggressive Demand Side
19 Management/Supply Side Enhancement (DSM/SSE) program in response to Yukon Utilities Board
20 directives, government policy considerations and stakeholder comments.

21 Section 3 reviews and screens current resource options as identified in the Charrette. Thereafter, the
22 potential resource portfolios options are used to evaluate current resource planning options based on the
23 four planning principles. The portfolio options examined are as follows:

- 24 • Section 4 - Default Diesel Portfolio;

¹⁰⁴ Subsequent planning stages include: the final feasibility assessment, costing, design and contract arrangements (and related tendering to obtain final estimated costs); consultation with First Nations and others; all required external reviews, approvals and agreements (includes where relevant YESAB, DFO, YWB and other regulatory authorities as required, as well as seeking YUB review of near-term projects over \$3 million).

- 1 • Section 5 - Minimum GHG Emissions Portfolio Options; and
- 2 • Section 6 - LNG Transition Portfolio Options.

3 **3.2 SCREENING OF CURRENT RESOURCE OPTIONS**

4 Table 3-1 provides an overview of the various resource options considered at the March 2011 Charrette.
5 Some of these options were considered in the previous 20-Year Resource Plan (Appendix A of the 2006
6 Resource Plan). Some options continue to be reviewed at this time as part of Yukon Energy's ongoing
7 planning processes (e.g., separate ongoing assessments for completion by this fall are currently being
8 undertaken of DSM/SSE resource options; ongoing assessments also continue for hydro enhancement
9 options, wind, waste-to-energy, biomass and LNG). The 2011 Resource Plan has been prepared based on
10 information currently available, recognizing that assessments remain subject (as was the case with the
11 2006 Resource Plan) to ongoing adjustment as new information and priorities emerge.

12 The 2011 Resource Plan assumes that Demand Side Management (DSM) and Supply Side Enhancement
13 (SSE) measures will be implemented concurrent with any other resource supply options and a range of
14 possible DSM/SSE program impacts are considered when assessing all resource supply options examined.

15 Each option in Table 3-1 is addressed in detail in a separate supporting attachment to either Appendix E
16 (near-term options) or Appendix F (longer-term legacy options).

17 **3.2.1 "Near-Term", "Long-Term Hydro" and "Long-Term Other" Resource Options**

18 Table 3-1 characterizes resource options as "near-term" versus "long-term hydro" and "long-term other",
19 addressing the potential ability of each option to be available in Yukon within the relevant planning
20 period:

- 21 • **Near-Term Options** – These resource supply options are potentially available to start
22 construction before the end of 2014 for in-service no later than 2017, based on consideration of
23 potential ability to develop, licence and construct the option within this near-term planning
24 period. As outlined in Table 3-1, the near-term options identified at the Charrette include
25 DSM/SSE, diesel (the existing default option), hydro enhancements (includes Marsh Lake
26 Storage, Atlin Storage and Gladstone Diversion), thermal-biomass (includes wood biomass and
27 municipal solid waste), thermal-liquid natural gas (LNG), and wind (includes Ferry Hill and Mount
28 Sumanik wind farm sites).

1 These options are examined further in Sections 4, 5 and 6, subject to the following screening
2 refinements as reviewed in Appendix E:

- 3 ○ **DSM/SSE** – Yukon Energy is planning to proceed with a robust and aggressive DSM/SSE
4 program in the very near-term as an integral element of the 2011 Resource Plan - based
5 on current Yukon Government policy (as set out on in the Energy Strategy for Yukon and
6 the Yukon Climate Change Action Plan) and current broad public support for conservation
7 measures (including Yukon Utilities Board directives¹⁰⁵). A successful DSM/SSE program
8 will include a portfolio of specific DSM/SSE options that effectively reduce the
9 requirements for demand and energy on the system and thereby reduce the diesel
10 available to be displaced by other resource options – accordingly, in order to assess other
11 resource options for resource planning purposes it is important to have an initial
12 assessment of DSM/SSE potential impacts during the planning period.

- 13 ▪ DSM and SSE potential and related programs are currently being developed for later
14 this year¹⁰⁶. Yukon Energy is pursuing, for example, a LED streetlight program – 567
15 streetlights in Mayo, Dawson and Faro have been replaced with more energy efficient
16 LED streetlights (a reduction in consumption approximately of 0.2 GW.h/year while
17 maintaining safety and security attributes of streetlights).
- 18 ▪ Pending completion of this DSM/SSE program development, the 2011 Resource Plan
19 has been prepared (see Section 4) assuming DSM/SSE program commencement by
20 2013 sufficient to secure a 67% reduction in annual non-industrial forecast medium
21 load growth each year¹⁰⁷. It is assumed for simplicity and pending completion of
22 more detailed future analysis and program development, that assumed DSM
23 reductions in ongoing non-industrial growth apply annually and equally to forecast
24 non-industrial capacity and energy generation loads. As reviewed in Section 4,
25 industrial DSM is also being pursued by Yukon Energy; however, no specific DSM
26 assumptions have been adopted in the 2011 Resource Plan for industrial DSM.

¹⁰⁵ Given YUB's previous orders and recommendations on DSM, and forecast diesel generation levels, it is reasonable to assume that meaningful and prudent DSM expenditures and actions will be supported by the regulator.

¹⁰⁶ YEC, YECL and YG are now proceeding with a detailed energy conservation potential review as required to determine by later this year the specific extent and cost/implication plans for feasible DSM programs to be implemented thereafter.

¹⁰⁷ YEC's DSM planning includes load reductions for industrial customers such as Minto, and therefore DSM savings are also expected for these loads. No specific industrial DSM estimates, however, are forecast or assumed in the current 2011 Resource Plan.

- 1 ▪ The 67% assumed reduction estimate is considered reasonable as BC Hydro
2 currently is required (by the BC Clean Energy Act) to meet at least 66% of all load
3 growth through DSM (separate from SSE). BC Hydro plans to exceed this DSM
4 requirement by a combination of programs, standards and rate structures at unit
5 energy costs for DSM averaging well under 10 cents/kW.h¹⁰⁸.
- 6 ○ **Hydro Enhancements** – Discussion at the Charrette identified three separate projects
7 that YEC was working to develop in order to enhance its existing hydro facility
8 generation: Marsh Lake Storage, Atlin Storage and the Gladstone Diversion. Due to the
9 BC Government decision recently to designate Atlin River as a Class A park (and
10 expectation that the designated park will include the river), work on the Atlin Storage
11 project has currently ceased. For the remaining hydro enhancements, current potential
12 earliest full year operation is assumed in Section 5 as follows (implies in-service later the
13 previous year): Marsh Lake Storage (2015) and Gladstone Diversion (2018). Capacity
14 enhancements provided by Marsh Lake Storage (about 1 MW) are considered in the
15 current evaluation (no peak winter capacity enhancement is provided by Gladstone
16 Diversion). In addition to the Marsh Lake and Gladstone hydro enhancement projects,
17 Yukon Energy continues to pursue various other potential near-term hydro enhancement
18 opportunities that are not addressed further in the current Section 5, including:
- 19 ▪ Amendments to the current Fisheries Act Authorization provisions for Aishihik
20 generation which are estimated to provide potentially an additional 9 GW.h of annual
21 energy on average from the Aishihik plant;
- 22 ▪ Transmission connection of the Yukon grid to the Taku River Tlingit owned Pine
23 Creek Hydro Generating Station near Atlin, B.C. to take advantage of underutilized
24 existing capacity plus undeveloped capability at the generating station. Transmission
25 connection of the Yukon grid to the Taku River Tlingit owned Pine Creek Hydro
26 Generating Station near Atlin, B.C. is being examined for various options. A 1.5 MW
27 option would utilize surplus hydro from the existing TRTFN Pine Creek hydro plant,

¹⁰⁸ BC Hydro's DSM projections indicate similar material impacts from DSM on load growth in each major customer sector (residential, commercial and industrial); however, for each sector the impacts of specific DSM program components can vary a great deal. In the 2008 DSM program filings, for example, "Codes and Standards" DSM activities accounted for over 50% of the forecast residential DSM impacts, while sector-specific DSM "Programs" accounted for over 60% of the forecast commercial DSM impacts and over 80% of the forecast industrial DSM impacts. DSM "Rate Programs" (the third and final major DSM component in the BC Hydro package) typically accounted for between about 15 and 20% of the DSM impacts in each major customer sector in the 2008 DSM program. BC Hydro's 2011 Integrated Resource Plan Draft 2010 Resource Options Report reviewed DSM energy-focused options with a resource cost ranging from 3.7 cents/ kW.h to 4.6 cents/kW.h.

- 1 with annual potential of 10 GW.h/yr over a 25 kV powerline. A 3.5 MW option would
2 use the same exiting surplus hydro with a 2.2 MW expansion, with annual potential
3 of 23 GW.h over a 35 kV powerline. A 8.0 MW option would use the expanded
4 existing hydro plant plus a new 4 MW downstream plant with annual load potential of
5 52 GW.h over a 69 kV powerline¹⁰⁹; and
- 6 ■ Current assessments in the 2011 Resource Plan assume that the Mayo Lake
7 Enhanced Storage Project is committed and approved for 2012 (this project, which is
8 assumed on average to provide an added 4 GW.h per year of grid hydro energy, has
9 yet to proceed to regulatory approval stage and earliest implementation now would
10 be in 2013).
 - 11 ○ **Thermal options** – Current information for thermal wood biomass, thermal municipal
12 waste and thermal LNG supply options is preliminary, particularly as regards feedstock
13 supply development and/or arrangements. Initial pre-feasibility studies have been used
14 in Sections 5 and 6 to assess the potential relevance of further work on any of these
15 options, and further pre-feasibility analysis would likely be required prior to relying on
16 any of these options for near-term supply. Each option is assumed to be located close to
17 existing transmission.
 - 18 ■ **Thermal wood biomass** is considered in Section 5 based on information from the
19 Charrette, available BC Hydro reports and a preliminary draft evaluation of
20 opportunities to generate electricity in Yukon using wood biomass recently prepared
21 for Yukon Energy by Morrison Hershfield. Lack of feedstock supply security has been
22 identified as a significant project risk that will require mitigation prior to any wood
23 biomass project development in Yukon. Based on the Morrison Hershfield report the
24 economics of a 25 MW wood biomass thermal plant in Whitehorse by late 2014
25 (2015 first full year of operation) are assessed; in addition, a smaller 10 to 15 MW
26 biomass plant scale option for the same in-service timing (located at either the Minto
27 burn area or Whitehorse) is also assessed based on currently available information.
 - 28 ■ **Thermal municipal waste** is considered in Section 5 based on a recent draft
29 summary report (provided to Yukon Energy by Morrison Hershfield) on use of
30 municipal solid waste (MSW) as a feedstock in a thermal generation process at

¹⁰⁹ Yukon Energy has engaged in very preliminary discussions with representatives of the First Nation Development Corporation and a mutual interest has been expressed to continue discussions.

- 1 Whitehorse to provide increased firm electrical generation capacity as well as
2 potential use of waste heat from the generation process in a future District Heating
3 System. This “waste to energy” (WTE) option has been considered using the
4 MSW/biomass feedstock and power generation scale ranges examined by the most
5 recent Morrison Hershfield study (i.e., between 1.4 – 2.2 MW); for the purpose of
6 Section 5 analysis, a 2.2 MW facility is assumed to be in-service by late 2014 (2015
7 first full year of operation) with MSW and wood biomass feedstock requirements and
8 sale of district heat as per the Morrison Hershfield draft report.
- 9 ▪ **Thermal LNG** is considered in Section 6 for a 25-30 MW LNG/natural gas power
10 plant to be located at Whitehorse by late 2014 (2015 first full year of operation); the
11 assumed plant scale reflects what is considered necessary to displace diesel under
12 near-term loads with mines connected to the grid. Reflecting preliminary studies
13 done to date¹¹⁰, trucked-in LNG is assumed until local natural gas supplies are
14 available (for initial costing, an LNG supply is assumed to be secured from facilities
15 developed at Kitimat or at Fort Nelson, B.C., with the LNG then shipped to
16 Whitehorse, Watson Lake [for YECL utility generation] and potentially off-grid mine
17 sites). Finalizing the preferred sourcing of the LNG fuel supply is a significant issue to
18 be addressed if this option is pursued.
 - 19 ○ **Wind** – It is assumed that at most only one 20-21 MW scale wind project could be
20 accommodated on the grid during the planning period, given the non-dispatchable nature
21 of this energy supply option and the cost limits related to securing necessary added
22 energy storage.

¹¹⁰ Initial assessments utilized internal working papers prepared for Oil and Gas Resource Branch, Yukon Department of Energy, Mines and Resources, and studies for the developers of the Casino mine (Western Copper and Gold), as referenced in Appendix E, Attachment E4 regarding initial costing of an LNG supply to be developed at Fort Nelson, B.C., with the LNG then shipped to Whitehorse. As reviewed in Chapter 6 and Appendix E, Attachment E4, Western Copper and Gold is also examining the option of sourcing LNG by ship and truck from Kitimat (by truck through BC, or by ship/truck through Skagway) or Fort Nelson (by truck). Yukon Energy has been working recently with Western Copper and Gold to examine LNG supply chain options for Yukon suited for use by YEC, Western Copper and Gold (at Casino), YECL (at Watson Lake) and other off grid mine operations (see Section 6 reference Yukon Energy participating with Western Copper and Gold to retain Braemar Wavespec and Berger ABAB to evaluate LNG & Natural Gas supply chain options in lieu of diesel for electrical power generation fuel at various Yukon locations).

- 1 For simplicity, Section 5 evaluation of wind farm options focuses only on the following
2 Ferry Hill options for assumed in-service by late 2014 (2015 first full year of
3 operation)¹¹¹:
- 4 ▪ 21 MW option connected to the Stewart Crossing south substation, assuming 5 MW
5 of added diesel rotary uninterruptible power (DRUPS) is required for reliability if this
6 level of wind resource is developed¹¹²; and
 - 7 ▪ 10.5 MW option connected to the Stewart Crossing north substation, assuming that
8 no added DRUPS is required for reliability so long as the wind resource development
9 is limited to this scale on the grid.
- 10 • **Long-Term Hydro Options** – These greenfield resource supply options are potentially available
11 to start construction before 2021 to provide new low cost, clean and reliable long-term electricity
12 supply in Yukon, subject to adequate and reasonably assured long-term load levels to utilize the
13 new energy supply. These potential new greenfield hydro sites require up to 10 years or more to
14 plan, secure regulatory approvals and develop; accordingly, if such options are to be available to
15 start construction before 2021 there is a need to begin site specific planning processes today that
16 are sustained as required throughout the near-term. These options are examined further in
17 Section 5, subject to the following screening refinements as reviewed in Appendix F identifying
18 total potential supply exceeding 6,800 GW.h/year from hydro sites with estimated full utilization
19 costs (with transmission) below 15 cents/kW.h (2009\$).
- 20 Figure 3-1 indicates the location of these and other potential hydro sites that YEC has examined,
21 as well as the relative location of the Casino, Selwyn, MacTung and Northern Dancer off-grid
22 mine projects¹¹³.

¹¹¹ YEC continues to examine the Mount Sumanik 20 MW wind farm option, and if developed rather than Ferry Hill its overall generation and costs would likely be similar to those assumed in Section 3 for Ferry Hill.

¹¹² In assessing either Ferry Hill or Mount Sumanik 21 or 20 MW wind farms, it is assumed that approximately 5 MW of spinning reserve is currently available and that (regardless of wind resource use) about 10 MW of existing non-base loaded hydro units would be converted to synchronous condenser peaking units (see Appendix E, Attachment E5). A 21 MW wind farm is then assumed to require that a further 5 MW DRUPS be added to the grid to provide adequate reliability.

¹¹³ Hydro sites that are protected in the Yukon First Nation Final Agreements include elements of Granite Canyon (Selkirk First Nation), Hess (Na-Cho Nyak Dun First Nation), Morley (Teslin Tlingit Council First Nation), Aishihik (includes various related projects such as the Gladstone Diversion – Champagne/Aishihik First Nation and Kluane First Nation), Drury Lake/Creek (Little Salmon/Carmack First Nation) and North Fork (Tr'ondek Hwech'in First Nation). Upper Canyon on the Frances River, Finlayson River and Hoole/Slate are classed as "interim protected" (i.e., are in traditional areas of First Nations that do not today have a land claims agreement).

- 1 ○ **Small Hydro Options (<10 MW; up to 70 GW.h/year at 20-22cents/ kW.h) –**
2 Aside from potential transmission connection to underutilized and undeveloped hydro
3 capacity near Atlin, B.C., small scale hydro options are identified in the Southern Lakes
4 region (near Tutshi Lake, B.C.) at Moon Lake and Tutshi River or Tutshi (Windy Arm).
5 Annual energy potential for each site approximates 30- 39 GW.h/year with full utilization
6 life cycle costs (with transmission to the Yukon grid) estimated at 20-22 cents/kW.h.
- 7 ○ **Medium Hydro Options (11-60 MW; over 2,070 GW.h/year at less than 15**
8 **cents/kW.h)**
- 9 ▪ Four sites or schemes investigated by Yukon Energy (or NCPC in the past) have
10 estimated full utilization costs (with transmission) below 10 cents/ kW.h (2009\$)
11 and offer over 850 GW.h/year of average annual sustainable energy supply after
12 considering duplication among these sites. These sites include Hoole Canyon with
13 Storage [275 GW.h/year], Slate Rapids [266 GW.h/year], Granite Canyon Small
14 [400 GW.h/year] and Finlayson [129 GW.h/year].
- 15 ▪ A further five medium size sites or schemes with full utilization costs between 10
16 and 15 cents/kW.h offer over 850 GW.h/year of additional average energy supply
17 after considering for site modifications already addressed in the sites with costs
18 below 10 cents/kW.h. These include Combined Slate Rapids [361 GW.h/year]
19 and another Slate Rapids site [156 GW.h/year], Two Mile Canyon [280
20 GW.h/year], Ross Canyon [181 GW.h/year], and False Canyon [370
21 GW.h/year]¹¹⁴.
- 22 ▪ A further two medium size sites north of Watson Lake have full utilization costs
23 less than 15 cents/kW.h if exceptionally high transmission costs to connect to the
24 existing grid are excluded. These sites are Middle Canyon [200 GW.h/year] and
25 Upper Canyon [176 GW.h/year].

¹¹⁴ The last site (False Canyon) is highly impacted by transmission distance to east of the current grid.

- 1 ▪ Recently, the developer of the Northern Dancer mine has reported on studies for
2 the Morley River site with potential generation exceeding 300 GW.h per year and
3 costs under 10 cents/kW.h¹¹⁵.
- 4 ○ **Large Hydro Options (>60 MW; over 4,740 GW.h/year at less than 15**
5 **cents/kW.h)**
- 6 ▪ Five sites or schemes have estimated full utilization costs (with transmission)
7 below 10 cents/kW.h (2009\$) and offer over 3,540 GW.h/year of average annual
8 sustainable energy supply after considering duplication among these sites and
9 after considering for site modifications already addressed in the medium size
10 sites. These include Fraser Falls Low [700 GW.h/year] and Fraser Falls High
11 [2,100 GW.h/year]; Slate Rapids/Hoole [459 GW.h/year]; and Granite Canyon
12 Low [600 GW.h/year] and Granite Canyon High [1,783 GW.h/year].
- 13 ▪ A further three medium size sites or schemes with full utilization costs between
14 10 and 15 cents/kW.h offer over 1,200 GW.h/year of additional average energy
15 supply after considering for site modifications already addressed in the sites with
16 costs below 10 cents/kW.h. These include Detour Canyon [435 GW.h/year] and
17 Detour Canyon with Storage [585 GW.h/year], and Liard Canyon [659
18 GW.h/year]¹¹⁶.

¹¹⁵ The medium scale hydro sites currently screened by Yukon Energy do not include Morley as past Yukon Energy information for this site indicated only about 22 GW.h/year of potential average annual generation based on reasonable development options with impacts confined within Yukon (i.e., not involving trans-border impacts in BC). Largo Resources Limited's public information regarding the Northern Dancer mine development indicates more recent hydro site potential investigations of the Morley River below Morley Lake suggesting a potential for over 300 GW.h/year generation at an average cost of less than 10 cents/kW.h. Yukon Energy has not to date reviewed the Largo Resources study. Recent (October 2011) discussions with Northern Dancer, however, indicate that the Morley River hydro option is no longer being considered (in the absence of grid connection to BC, which would allow this mine to be located in BC and to secure BC industrial rates, transport of liquefied natural gas (LNG) to the site is being considered).

¹¹⁶ The last site (Liard Canyon) is highly impacted by transmission distance to the east of the current grid.

- 1 • **Other Long-Term Options** – These long-term resource supply options require external action
2 by others to be considered potentially available for development before 2021. More specifically,
3 ability to pursue these options further requires new information (e.g., successful exploration
4 results for geothermal¹¹⁷), new technology (e.g., a cost-effective clean coal technology, proven
5 and cost-effective mini-nuclear plant technology and/or solar technology suitable for Yukon use),
6 or other external action (e.g., indigenous coal development close to the grid in Yukon¹¹⁸;
7 commitment by others to provide natural gas in southern Yukon through an Alaska Highway
8 pipeline and/or Eagle Plains development¹¹⁹; commitment by others to connect Yukon’s grid with
9 grids in British Columbia¹²⁰ or Alaska). These options merit ongoing monitoring of developments,
10 but are not considered further in Section 3.

11 **3.2.2 Key Planning Principle Characterization of Resource Options**

12 Resource options are also initially characterized in Table 3-1 using each of the four key planning
13 principles agreed to by Charrette participants¹²¹.

- 14 • **Reliability** – Reliability is assessed in Table 3-1 regarding winter peak and reserve capacity, as
15 well as security of resource supply and in-service timing for new development.
- 16 ○ Diesel and thermal options (biomass, LNG) provide high reliable winter peak and reserve
17 capacity, while wind options do not provide reliable winter peak or reserve capacity (and
18 therefore require other concurrent resource measures to ensure reliable capacity).

¹¹⁷ Geothermal opportunities offer future potential to provide significant low cost, clean, and reliable long-term electricity supply in Yukon if successful exploration can define appropriate opportunities close to the grid. Section 5.1.2 reviews a preliminary resource assessment and prioritization of sites recently undertaken for Yukon energy. As reviewed in Appendix F, Attachment F2, considerable costs would likely be required to carry out the necessary ongoing exploration and confirmation drilling to locate and then develop geothermal as a generation resource in Yukon. Funding for this type of development activity at the scale likely to be needed is not typical for a regulated utility such as Yukon Energy. Accordingly, the 2011 Resource Plan does not provide any specific major proposed activities for geothermal beyond ongoing monitoring of related activities in Yukon.

¹¹⁸ Monitoring indigenous Yukon coal resource development as well as evolving clean and small scale coal technology also merits attention, given Yukon coal resources that exist in close proximity to the grid.

¹¹⁹ Proponents of the Alaska Pipeline Project provided a project schedule in fall 2011 community meetings in Alaska indicating first gas in 2020 and full gas in 2021, assuming an October 2012 FERC filing and project sanction before mid-2015 (see Section 6). There is currently no timing or plan for development of Eagle Plains, but potential options may emerge tied to development of a major new load such as the Casino mine.

¹²⁰ Appendix F, Attachment F2 reviews a conceptual-level study done for YEC of a transmission interconnection between Yukon and B.C. Four alternatives were considered, with costs ranging from \$1.2 billion to \$2.4 billion.

¹²¹ Further details of this initial characterization are provided in Appendix B, Attachment B-1.

- 1 ○ Regulatory approval risk affecting timing and cost is characterized as high for near-term
2 hydro enhancement options and longer-term medium/large greenfield hydro options –
3 highlighting a key concern affecting in-service timing for these options.
- 4 • **Affordability** – Affordability is assessed in Table 3-1 as discussed at the Charrette based on an
5 option’s full utilization levelized cost of energy (“Full Utilization LCOE”¹²²) per kW.h over the
6 option’s economic life, assuming adequate load throughout each year of the project life to ensure
7 full utilization of all energy supplied by the option to displace (in the current Yukon context)
8 diesel generation that would otherwise have been required.
- 9 ○ DSM/SSE and certain hydro options (hydro enhancements and large greenfield hydro)
10 are characterized with high affordability (i.e., Full Utilization LCOE generally less than 10
11 cents/kW.h), while diesel and thermal-biomass options are characterized with low
12 affordability (i.e., Full Utilization LCOE at 20 to over 30 cents/kW.h).
- 13 ○ As discussed below, further evaluation of affordability for each option is to consider the
14 extent to which the energy supplied is forecast to be utilized in an effective manner
15 based on forecast loads as reviewed in Section 2 (i.e., seasonal load and hydro supply
16 forecasts [including consideration of annual hydro variability] as well as near and long
17 term load forecasts). For example, large scale greenfield hydro generation projects are
18 characterized with “high affordability” in Table 3-1 (i.e., levelized costs of 5-11
19 cents/kW.h), assuming full utilization of all generation; however, generation from these
20 large scale greenfield hydro projects would clearly not come close to being “fully utilized”
21 under current forecast grid loads – and until reasonable levels of utilization are forecast
22 over 20-30 or more years, such capital intensive projects would in reality be highly
23 unaffordable in Yukon.
- 24 ○ In the context of the 2011 Resource Plan, energy generated by a non-diesel option that
25 fails to displace diesel generation otherwise required has no economic value (i.e., it is
26 “wasted” energy that fails to save costs for the utility or its ratepayers and has no value
27 in meeting forecast load requirements).

¹²² LCOE indicates on a consistent and comparable basis each option’s overall costs per kW.h in current dollars (\$2010). It includes capital and operating costs and, where specified, any related transmission, storage or capacity costs. This cost is subject to ongoing annual inflation for each subsequent year of operation in order to assess costs over the option’s economic life. This cost does not mean that Yukon Energy or ratepayers would face this specific cost per kW.h during each year of operation (while LCOE may reflect annual costs for fuel intensive options, capital intensive options will have costs per kW.h above LCOE at the outset, declining over time to be less than LCOE). LCOE assessment for each option in the 2011 Resource Plan assume the same cost of capital (6.56% blended cost of debt and equity as last approved by the YUB for YEC’s 2009 GRA) and general inflation at 2% per year.

- 1 • **Flexibility** – Flexibility is assessed in Table 3-1 based on ratepayer risks regarding mine load
2 reductions. As reviewed in Section 2.4, flexibility can also be an important factor on the Yukon
3 grid in accommodating diesel generation displacement during the summer/fall season and under
4 the wide range of annual hydro generation conditions.
- 5 ○ Diesel and thermal-LNG options show high flexibility, while thermal-biomass, wind and
6 long-term hydro options show low flexibility (reflecting the capital intensive nature of
7 these options).
- 8 ○ Options showing low flexibility in Table 3-1 may show “Forecast LCOE” (LCOE based on
9 costs per kW.h of diesel displaced) that is materially higher than Full Utilization LCOE to
10 the extent that forecast grid loads are unable to fully utilize the option’s new generation
11 and the new option’s costs are not flexible in response to grid load changes.
- 12 • **Environmental Responsibility** – Environmental responsibility is assessed in Table 3-1 based
13 primarily on reduction of GHG emissions in Yukon.
- 14 ○ Hydro enhancements, thermal-biomass and wind options show high environmental
15 responsibility, while diesel shows low environmental responsibility reflecting higher GHG
16 emissions than any other option.
- 17 ○ Environmental responsibility issues are also noted in Table 3-1 regarding the large
18 footprint associated with longer-term greenfield hydro projects and the related impacts
19 on land, waters and people. Concerns have been raised by local communities and/or First
20 Nations regarding potential adverse environmental impacts on lands, water and people
21 regarding each of the hydro enhancement project options - these concerns will be
22 addressed in any environmental assessment and permitting by regulatory authorities,
23 and are the basis for the regulatory reliability issues noted earlier for these projects. No
24 major environmental impact issues regarding land, water or people that might affect
25 project timing or viability have been identified to date for the other near-term renewable
26 options (wind and wood biomass). In regard to longer-term resource options, hydro sites
27 or schemes screened above for longer-term consideration with estimated full utilization
28 costs below 15 cents/kW.h have the following range of potential reservoir areas and
29 salmon fisheries related issues:
- 30 ▪ **Small Hydro Option (<10 MW)** – These options do not involve any material new
31 inundation, and no salmon-related fisheries issues.

- 1 ▪ **Medium Hydro Options (11- 60 MW)** – Finlayson has smallest reservoir area
2 (<11 km²)¹²³; several options have between 60 and 85 km² of reservoir area (Hoole
3 Canyon with Storage¹²⁴, Two Mile Canyon¹²⁵, Ross Canyon and False Canyon¹²⁶).
4 Slate Rapids has 102 km² and Combined Slate Rapids has 162 km² ¹²⁷. Finlayson and
5 False Canyon are the only options with no salmon-related fisheries issues.
- 6 ▪ **Large Hydro Options (>60 MW)** – Detour Canyon has the smallest reservoir area
7 (70 km²). Four sites have between 119 and 147 km² of reservoir area (Slate
8 Rapids/Hoole, Detour Canyon with Storage, Liard Canyon and Fraser Falls Low).
9 Fraser Falls High has 372 km² of reservoir area. Liard Canyon is the only option with
10 no salmon-related fisheries issues.

11 The overall resource planning objective is to select a portfolio of resource options that achieves an
12 appropriate balance among the four key principles based on currently known near-term and longer-term
13 load requirements throughout Yukon (including off-grid industrial loads) during the 20-year planning
14 period (2011-2030).

15 Reliability is addressed as a fundamental requirement in each resource option portfolio based on forecast
16 loads and currently committed grid resource availability as reviewed in Section 2. Flexibility is addressed
17 by subjecting each resource option portfolio to potential changes in mine loads beyond the forecasts in
18 Section 2. The major remaining challenge is to balance affordability and environmental responsibility in
19 the selection of resource options.

- 20 • In the longer-term, Table 3-1 indicates that new greenfield hydro options offer the potential in
21 Yukon to provide both low cost and low GHG emissions, subject to securing adequate load to
22 utilize effectively this new generation over 30+ years and subject to successfully addressing
23 regulatory risks affecting timing and costs. Geothermal and clean coal are identified in Table 3-1
24 as other long-term options that might, subject to successful exploration (geothermal) or new
25 technology (clean coal) also provide in Yukon both low cost and low GHG emissions.

¹²³ Noted permafrost challenges. Minor potential impact on settlement land.

⁷⁷ Material new access to previously inaccessible wilderness.

⁷⁸ Impact on settlement land.

¹²⁶ Ross Canyon, False Canyon and Middle Canyon are not on protected sites (all other sites are protected); False Canyon and Middle Canyon have no salmon present in river – all other sites have salmon in river. False Canyon and Middle Canyon also have no permafrost challenges. Ross Canyon would have effects on harvesting activities, small heritage impact and impacts on tourism.

¹²⁷ Noted permafrost challenges. Also, Slate will dewater significant length of Pelly River between dam and powerhouse and likely would require mitigation measures to address. Material potential impact on settlement land.

- 1 • In the near-term, Table 3-1 highlights the high cost (approximating 30 cents/kW.h) and high
2 GHG emissions associated with diesel generation; other than hydro enhancements (which have
3 high regulatory risks affecting in-service timing), all near-term options to diesel show Full
4 Utilization LCOE ranging from 15 to over 30 cents/kW.h, indicating costs for near-term
5 incremental generation well above current average grid generation costs. Near-term reductions in
6 GHG emissions relative to diesel are offered by all non-diesel options; however, aside from hydro
7 enhancements, low GHG emissions are offered only by thermal-biomass and wind options that
8 display high capital costs and low flexibility. Sourcing fuel supply remains a significant issue for
9 both thermal-biomass and thermal-LNG and further pre-feasibility analysis would be required
10 prior to relying on either of these options for near-term supply (i.e., for start of construction
11 before the end of 2014).

12 **3.3 OVERVIEW OF SUBSEQUENT SECTIONS**

13 Sections 4 to 6 examine three broadly different resource portfolio options in order to gain insight into the
14 basic choices available today:

- 15 • Section 4 looks at the Default Diesel Portfolio Option, focusing on defining grid economic impacts,
16 Yukon GHG emissions impact, and longer-term development considerations for this basic default
17 option. Assumed DSM/SSE is outlined in this section, and is included in subsequent analysis in
18 Sections 5 and 6 as a resource option that Yukon Energy is assumed to pursue no matter what
19 other resource options are developed¹²⁸.
- 20 • Section 5 looks at Minimum GHG Emissions Portfolio Options, focusing on potential renewable
21 resource development responses to the forecast energy and capacity requirements as one path
22 to reduce reliance on diesel generation. Grid economic impacts, Yukon GHG emission impact and
23 longer-term development considerations are reviewed for these portfolio options. Focusing on
24 longer-term affordability and GHG emission reduction, greenfield hydro resource options are
25 examined to identify ongoing planning activities during the next five years to protect longer-term
26 legacy resource development options for potential start of construction before 2021.
- 27 • Section 6 looks at LNG Transition Portfolio Options, focusing on an option to retain flexibility
28 similar to that provided by diesel generation while materially reducing the costs and GHG

¹²⁸ In the past, reflecting YUB review after the Faro mine closed in 1993, DSM tended to be suspended as a utility planning cost during periods of surplus hydro on the grid. No attempt has been made in the 2011 Resource Plan to assess under what conditions future DSM/SSE as assumed in the analysis might be similarly suspended in future.

1 emissions relative to the Default Diesel Portfolio. Near-term loads under each load scenario are
2 addressed, while also encouraging the ability to plan for, and pursue, cost effective and
3 environmentally responsible wind, hydro or other renewable legacy resource development when
4 feasible over the longer-term planning horizon. Grid economic impacts, Yukon GHG emission
5 impact and longer-term development considerations are reviewed for these portfolio options.

6 Focusing on the near-term capital intensive options that have low GHG emissions (hydro enhancements,
7 thermal-biomass, and wind), near-term assessments in Section 5 (Minimum GHG Emissions Portfolio
8 Options) look at Forecast LCOE (i.e., the extent to which the new generation will be utilized at forecast
9 loads) and initial operating year costs (i.e., costs ratepayers would face in the initial years of operation).

- 10 • Both Forecast LCOE and initial operating year costs per kW.h for these options as reviewed in
11 Section 5 are considerably higher than the Full Utilization LCOE estimates in Table 3-1.
- 12 • As reviewed in Section 5, high Forecast LCOE costs for these renewable resource options reflect
13 low flexibility to address loss of mine loads after 2021 (as well as low forecast diesel generation
14 displacement opportunities during summer/fall months), while high operating year costs per
15 kW.h in the initial operating years (i.e., 2015 to 2020, when mine loads are assumed to be
16 connected to the grid) reflect the capital intensive nature of these options.


Table 3-1: Range of Resource Supply Options & Initial High Level Characterization

AVAILABLE OPTIONS		RELIABILITY Reliable winter peak capacity, & reliable development (timing & cost)	AFFORDABILITY c/kW.h (\$2010) if fully utilized	FLEXIBILITY Ratepayer cost risks re Mine Load Reductions	ENVIRONMENTAL RESPONSIBILITY Env. impact mitigation - reduction of GHG Emissions
NEAR-TERM – potentially available start to construction before end of 2014 (available no later than 2017)	DSM/SSE	MEDIUM - depends on uptake and type of DSM/SSE	HIGH - <10 c/kW.h	MEDIUM – reasonably flexible; curtailable as/when needed	HIGH
	Diesel – existing default option	HIGH - low cost peaking & reserve capacity on system; low regulatory risk	LOW- Approx. 30c/kW.h	HIGH – low capital cost; save fuel & operating cost when load not there (summer/mine shutdown)	LOW- higher GHG & emissions than any other option
	Hydro Enhancements	MEDIUM – reliable winter energy but high regulatory risk	HIGH <10 c/kW.h	MEDIUM – reasonable flexible; winter storage; long-term value	HIGH
	Thermal - Biomass (incl. waste)	HIGH - baseload energy & capacity (no development planning to date)	MEDIUM – approx 15 c/kW.h; Scalability issues	LOW – not flexible – high capital cost; intended for yr-round energy supply	HIGH
	Thermal - Liquid Natural Gas (LNG)	HIGH - peaking & reserve capacity; low regulatory risk	MEDIUM/HIGH – <15 c/kW.h	HIGH - low capital cost; save fuel & operating cost when load not there (summer/mine shutdown)	MEDIUM – 30% to 50% lower GHG emissions than diesel
	Wind	LOW – not add reliable peaking/ reserve capacity; not dispatchable; but low regulatory risk	MEDIUM – approx 15 c/kW.h; includes storage	LOW – not flexible – high capital cost & not dispatchable	HIGH
LONG-TERM HYDRO - (greenfield) potentially available start before 2021	Small Hydro (< 10 MW)	MEDIUM – reasonably reliable; medium regulatory risk	LOW to MEDIUM (15 to > 20 c/kW.h)	LOW – not flexible; high capital costs req’s sustained demand (30+ yrs)	MEDIUM - HIGH – minimal emissions; large footprint
	Medium Hydro (11 to 60 MW)	MEDIUM – reasonably reliable; high regulatory risk	LOW to MEDIUM (10 to 20 c/kW.h)	LOW – not flexible; high capital costs req’s sustained demand (30+ yrs)	MEDIUM - HIGH – minimal emissions; large footprint
	Large Hydro (> 60 MW)	MEDIUM – reasonably reliable; high regulatory risk	HIGH – 5 to 11 c/kW.h	LOW – not flexible; high capital costs req’s sustained demand (30+ yrs)	MEDIUM – HIGH – minimal emissions; large footprint
OTHER LONG-TERM (require information, technology or other external action to be considered potentially available before 2021)	Geothermal (exploration)	HIGH re: energy & capacity LOW re: development risk as depends on successful exploration	HIGH - low cost to build and operate LOW– high exploration costs	LOW – not flexible; high capital cost req’s sustained demand; Not dispatchable	HIGH – minimal emissions/ footprint
	Clean Coal	HIGH - baseload energy & capacity	MEDIUM to HIGH	LOW – relatively inflexible; issues re: Scalability	LOW-MEDIUM - Need new tech. to prevent GHG emissions
	Nuclear	HIGH – baseload energy & capacity	UNKNOWN	LOW – capital intensive; req’s sustained demand;	LOW-MEDIUM – low emissions; nuclear-specific env. issues
	Solar	LOW - not dispatchable, dependant on sun availability	LOW - high cost at this time 20 to 60 cents & req storage	LOW - capital intensive; req’s sustained demand;	HIGH
	Pipeline/ Nat gas	HIGH - provides peaking & reserve capacity; low reg. risk	MEDIUM to HIGH (high cost to establish)	HIGH - low capital cost; save fuel & operating costs when no loads	MEDIUM - lower GHG emissions than diesel
	Grid Connection (B.C. or Alaska)	MEDIUM-HIGH	LOW – high cost to provide	LOW - capital intensive; may enhance greatly flexibility in Yukon	MEDIUM-HIGH – offers clean energy options

Note: “Affordability” in this table is assessed assuming adequate load to fully utilize the resource, e.g., greenfield large hydro lifecycle costs of 5 to 11 cents/kW.h assume full use of the resource throughout a 65 year life. In practice, project feasibility for each option depends on forecast lifecycle costs (LCOE) based on forecast utilization of the option over its life.

1

Figure 3-1: Location of Existing Grid, Potential Hydro Sites, and Various Existing & Potential Mines



2

Legend: Large Blue circles >100 MW; Purple circles 60-100 MW; Red circles 20-60 MW; Black circles <20 M.

1 **4.0 DEFAULT DIESEL PORTFOLIO**

2 **4.1 DEFINING THE PORTFOLIO**

3 The near-term 2011 Resource Plan assessment of grid options acknowledges that diesel is currently the
4 default generation resource option in Yukon (i.e., in the Yukon context diesel is the reliable, established
5 and available supply option against which other new supply options must be assessed). Assuming
6 replacement of diesel generation assets on retirement, today's existing and committed grid generation
7 resources can fully supply the near-term forecast loads including new grid connected mine loads
8 reviewed in Section 2.

9 Further, as reviewed in the Section 3.2 screening of resource options, the 2011 Resource Plan assumes
10 that DSM/SSE programs will be implemented concurrent with any other resource supply option developed
11 at this time.

12 Accordingly, the near-term resource planning assessment in effect establishes diesel and an assumed
13 DSM/SSE development together as the baseline portfolio against which all other near-term resource
14 options are to be assessed.

15 • **Diesel – Existing Supply Default Option** – Due to high operating costs and high GHG
16 emissions, diesel is not considered a preferred or acceptable option in Yukon to supply long-term
17 baseload generation¹²⁹. However, unless other less costly and/or lower GHG emission sources of
18 grid generation are developed in the near-term, available diesel generating capacity on the grid
19 will remain the effective default option to supply baseload energy requirements when grid load
20 surpasses what existing renewable resources can supply¹³⁰. Diesel today is also the default option
21 in all off-grid power supply situations in Yukon.

22 While it is not a preferred resource to supply ongoing baseload generation requirements, diesel is
23 considered a low capital cost option to supply the grid capacity that is required for reserves
24 (including security of local community supply) or occasional peaking use. Over time new diesel
25 generating facilities will need to be provided for this purpose simply to replace diesel unit

¹²⁹ Baseload diesel generation is diesel generation required throughout major portions of the year under long-term average water conditions.

¹³⁰ As reviewed in Appendix D and elaborated on in Attachment E2, existing diesel capacity is more than adequate to supply forecast energy requirements under each of the near-term load forecast scenarios.

1 capacity upon retirement of existing units, or as otherwise required, solely to address grid
2 capacity planning shortfalls.

3 • **DSM/SSE** – As reviewed in the Section 3.2 screening of resource options, for the 2011 Resource
4 Plan DSM/SSE is assumed to be in place when assessing all other near-term resource options,
5 and is further assumed to secure a 67% reduction in annual non-industrial grid load growth (both
6 capacity and energy) each year starting in 2013¹³¹. For the purpose of 2011 Resource Plan
7 annual cost impact assessments under each portfolio, it is further assumed that DSM/SSE
8 programs incur an average annual cost equal to 7.5 cents/ kW.h (2010\$) of assumed energy load
9 reduction¹³².

10 ○ Pending completion of current DSM/SSE studies and program development, no costs
11 have been estimated for specific DSM/SSE programs in the current 2011 Resource Plan
12 for this DSM/SSE resource program (these will be addressed later after completion of the
13 current DSM/SSE studies).

14 ○ YEC is developing DSM with industrial customers. Although no estimates are provided in
15 this analysis for industrial DSM savings, it is anticipated that there are some likely added
16 DSM-related load reductions (potentially in the order of 10%) related to forecast
17 industrial loads on the grid.


18 Figure 4-1 summarizes forecast utility annual default diesel energy requirements for on grid and off-grid
19 loads¹³³ for scenarios with and without DSM/SSE. This illustrates the extent to which forecast diesel
20 energy generation is assumed to be reduced as a result of the assumed DSM/SSE under each of the
21 forecast load scenarios: Base Case, Scenario A and Scenario B (based on current best available forecasts,
22 after 2021 load levels and growth assumptions for Base Case, Scenario A and Scenario B are the same
23 and default diesel energy requirements are therefore also the same after 2021).

¹³¹ This reduction is equivalent to lowering the non-industrial growth from 2.26%/year to about 0.75%/year, a very modest growth rate that is below the low growth rate scenario for non-industrial loads. Pending completion of the current detailed conservation potential review study, the assumed DSM/SSE is considered to provide a reasonably conservative assessment of overall DSM/SSE impacts over the planning period and to be affordable (low cost), reasonably flexible, reasonably reliable and environmentally responsible. When specific costs for programs are developed over the coming year the projected impacts will be refined. It is understood that actual DSM/SSE programs may well result in differential impacts on energy versus capacity growth rates.

¹³² An average annual cost of 7.5 cents/kW.h (2010\$) of new annual DSM/SSE load reduction has been assumed simply to ensure that a reasonable cost is included in the annual cost impact assessments provided in the 2011 Resource Plan; it is assumed that DSM/SSE costs are amortized over 10 years, i.e., no cost carryover after 10 years. [The average cost for all DSM/SSE is assumed to be considerably less than a potential target cost limit not to exceed about 50% of avoided costs for diesel and other resource supply options, i.e., for the grid, not to exceed 50% of 20 to 30 cents/kW.h (2010\$). BC Hydro projected costs for various DSM options in the 2011 IRP were less than 5 cents/kW.h.].

¹³³ Each grid diesel energy load forecast scenario reflects long-term average water year hydro generation capability for existing and currently committed hydro generation resources at Whitehorse, Aishihik and Mayo.

Figure 4-1: Diesel Energy Requirements (Grid & Off-Grid Utility) for Resource Plan Scenarios: 2011-30



Diesel Energy Requirement	2011	2015	2020	2025	2030
Base Case (GWh)					
with DSM/SSE	1.5	15.2	8.7	1.8	7.5
without DSM/SSE	1.5	23.7	32.5	40.3	82.8
Scenario A (GWh)					
with DSM/SSE	1.5	84.9	72.5	1.8	7.5
without DSM/SSE	1.5	98.9	112.0	40.3	82.8
Scenario B (GWh)					
with DSM/SSE	1.5	142.9	120.6	1.8	7.5
without DSM/SSE	1.5	158.1	163.3	40.3	82.8
Off Grid Diesel Community (GWh)	19.9	20.4	20.9	21.5	22.1
Diesel Energy Cost (Fuel & O&M)					
Base Case (\$ millions)					
with DSM/SSE	0.4	4.7	3.0	0.7	3.1
without DSM/SSE	0.4	7.3	11.1	15.2	34.5
Scenario A (\$ millions)					
with DSM/SSE	0.4	26.3	24.8	0.7	3.1
without DSM/SSE	0.4	30.6	38.3	15.2	34.5
Scenario B (\$ millions)					
with DSM/SSE	0.4	44.2	41.2	0.7	3.1
without DSM/SSE	0.4	48.9	55.8	15.2	34.5
Off Grid Community (\$ millions)	5.9	6.6	7.5	8.6	9.9

Table 4-1 provides forecast annual diesel generation by year for each of the load scenarios, showing for each year the forecast range between the assumed DSM/SSE versus no DSM/SSE. Provision of this range is used to test the sensitivity of other resource option assessments to the outcome of the DSM/SSE program that is currently being developed. Table 4-1 also shows the assumed grid load reduction impact (GW.h) each year of the assumed DSM/SSE for non-industrial grid loads.

1 **Table 4-1: Forecast Grid DSM/SSE & Diesel Generation by Load Scenario – 2011-2030**
2 **(GW.h/year)**


Forecast Years	Base case no DSM	Base case with DSM	Scenario A no DSM	Scenario A with DSM	Scenario B no DSM	Scenario B with DSM	Non-industrial DSM/SSE
2011	1.5	1.5	1.5	1.5	1.5	1.5	0.0
2012	11.5	11.5	11.5	11.5	11.5	11.5	0.0
2013	15.1	12.7	29.0	25.9	34.8	31.5	5.4
2014	19.2	13.9	91.7	82.6	112.1	102.5	10.9
2015	23.7	15.2	98.9	84.9	158.1	142.9	16.6
2016	24.8	13.4	100.5	81.7	159.9	139.3	22.3
2017	29.9	14.7	108.2	84.1	168.1	142.0	28.2
2018	35.5	16.2	116.2	86.6	176.5	144.7	34.3
2019	41.5	17.6	124.4	89.1	176.2	138.9	40.5
2020	32.5	8.7	112.0	72.5	163.3	120.6	46.8
2021	16.6	0.0	16.6	0.0	24.0	2.0	53.2
2022	21.6	0.0	21.6	0.0	21.6	0.0	59.8
2023	27.3	0.3	27.3	0.3	27.3	0.3	66.6
2024	33.5	1.0	33.5	1.0	33.5	1.0	73.5
2025	40.3	1.8	40.3	1.8	40.3	1.8	80.6
2026	47.7	2.7	47.7	2.7	47.7	2.7	87.8
2027	55.7	3.7	55.7	3.7	55.7	3.7	95.2
2028	64.2	4.9	64.2	4.9	64.2	4.9	102.7
2029	73.2	6.1	73.2	6.1	73.2	6.1	110.4
2030	82.8	7.5	82.8	7.5	82.8	7.5	118.3

3
4 Diesel generation varies in the near-term under the above load scenarios during the years 2013 to 2021,
5 reflecting varying assumptions as to connected industrial loads. In summary, the maximum grid diesel
6 energy generation displacement opportunities are forecast during 2015-19 (under average water year
7 conditions) with DSM/SSE from 13 to 18 GW.h/year under the Base Case (non-industrial load and
8 currently connected mines), from 82 to 89 GW.h/year under Scenario A (Base Case with Victoria Gold),
9 and from 139-145 GW.h/year under Scenario B (Base Case plus Victoria Gold, Carmacks Copper, WHCT).

10 Figure 4-2 highlights forecast new default diesel capacity requirements by year on the grid for each load
11 scenario with and without DSM/SSE. Figure 4-2 and accompanying table reflect forecast peak loads under
12 the grid load scenarios, forecast generation unit retirements, and Yukon Energy's grid capacity planning

1 requirements to meet peak winter loads (as discussed in Section 2.3.2 and depicted in Table 2-2 and
 2 Figures 2-8 and 2-9¹³⁴).

3 **Figure 4-2: New Diesel Grid Capacity Requirements for Resource Plan Scenarios: 2011-30**



4

	2011	2015	2020	2025	2030
New Diesel Capacity Requirement (MW)					
With DSM/SSE					
N-1	0.0	0.0	8.8	27.6	37.1
Base Case	0.0	0.0	8.8	27.6	37.1
Scenario A	0.0	9.6	17.9	27.6	37.1
Scenario B	0.0	17.6	25.9	27.6	37.1
Without DSM/SSE					
N-1	0.0	2.9	18.0	43.5	60.4
Base Case	0.0	2.9	18.0	43.5	60.4
Scenario A	0.0	12.9	27.1	43.5	60.4
Scenario B	0.0	20.9	35.1	43.5	60.4
Diesel Capacity Additions (\$Millions)¹					
With DSM/SSE					
Base Case	0.0	0.0	15.8	52.1	72.1
Scenario A	0.0	15.7	30.6	50.0	70.0
Scenario B	0.0	28.7	43.6	47.0	67.0
Without DSM/SSE					
Base Case	0.0	4.7	31.7	81.0	116.9
Scenario A	0.0	21.0	46.4	78.8	114.7
Scenario B	0.0	34.0	59.4	76.3	112.2

1. Cumulative diesel capacity spending to date after 2010 to meet capacity planning requirements (escalated dollars - assumed cost of \$1.5 million/MW [\$2010]).

5

¹³⁴ Section 2.3.2 reflects circumstances without DSM/SSE.

1 4.2 GRID ECONOMIC IMPACTS

2 For overall cost comparison of diesel with other generation options the 2011 Resource Plan examines
3 generation resource Portfolio options (i.e., different mixes of resource options to meet the forecast grid
4 energy and capacity requirements). Each portfolio is designed to meet the full grid generation
5 requirement each year under the specified forecast scenario; accordingly, whatever energy or capacity is
6 not supplied by non-diesel resource options is supplied by diesel and the related diesel costs are included
7 in the portfolio assessment unless otherwise noted.

8 The overall cost comparison of diesel and other portfolio options focuses on the following assessments
9 for each Portfolio:

- 10 • **Present Value Assessment:** An overall present value (PV) assessment is provided for each
11 portfolio to show PV (2010\$) total grid generation costs (energy and capacity) required to meet
12 incremental capacity and energy requirements over the 20-year planning period (2011-2030)
13 under the three near-term load scenarios as well as both with and without assumed DSM/SSE.
14 The PV assessment adopts a consistent economic impact framework, as reviewed below, to
15 compare the Default Diesel Portfolio with other portfolio options over the 20-year planning
16 period.
 - 17 ○ Diesel fuel and O&M costs per kW.h are assumed (2010\$) at approximately 28
18 cents/kW.h¹³⁵; diesel capacity requirements are also included in the PV costs for each
19 portfolio¹³⁶.
 - 20 ○ Review of diesel option costs relative to other resource options and review of annual cost
21 impacts for different resource portfolios that include diesel generation need to look at
22 sensitivity to changes in the diesel fuel price forecast. Experience over the past few years
23 as well as the past few decades has shown periods of high oil price volatility as well as
24 periods when the oil price was relatively stable. The use of one number (28 cents/kW.h

¹³⁵ The 2011 Resource Plan assumes diesel fuel and O&M costs per kW.h (2010\$), escalated at general inflation after 2010 (2% annual inflation assumed), based on fuel and other O&M costs approved in current rates (per 2009 GRA) for the WAF grid (28 cents/kW.h is a 50/50 blend of existing units at 30 cents/kW.h and more efficient new units assumed at 26 cents/kW.h, with O&M costs accounting for about 3.0 cents/kW.h for existing units and 2 cents/kW.h for new units – see Appendix E, Attachment E2).

¹³⁶ Diesel capital costs required for new capacity are included in the PV assessment; each portfolio is credited in the PV assessment with any present value savings affecting diesel capacity capital costs during the 20-year planning period. New diesel capacity is assumed to cost \$1.5 million per MW (2010\$).

1 the specific resource option package. The diesel default resource option cost for fuel and O&M
2 costs (2010\$ at approximate 28 cents/kW.h) is assumed for comparison¹³⁸.

3 **Present Value Costs**

4 Table 4-2 provides for the 20-year planning period (2011-2030) the detailed PV analysis for the Default
5 Diesel portfolio for each Resource Plan load scenario: Base Case, Scenario A and Scenario B. The Total
6 PV Cost (millions\$) for the Default Diesel portfolio is based on the sum of the PV Energy costs and the PV
7 Capacity costs.

8 The Default Diesel portfolio option meets the forecast energy and capacity requirements for the grid over
9 the planning period, relying on diesel generation and capacity to supply any shortfalls. The PV
10 assessment for each portfolio option discounts costs at 6.56% per year, reflecting YEC's last approved
11 blended cost of capital (i.e., to the extent that YEC's future approved cost of capital is higher than 6.56%
12 the current PV assessment understates PV costs for capital intensive resource options relative to non-
13 capital intensive resource options).

14 Generally, as noted in Table 4-2, for each resource option portfolio the following are included in the PV
15 assessment:

16 • **PV Energy Costs:** Present value energy costs include all annualized costs (depreciation, return,
17 fuel and O&M costs by year of operation) over the planning period for new non-diesel resource
18 options included in a portfolio option plus diesel fuel and O&M costs for all energy supplied by
19 diesel generation. Non-diesel resource option residual asset values that remain after 2030 are not
20 addressed.

21 ○ For the Default Diesel Portfolio, this is the PV of the total diesel generation fuel and O&M
22 costs over the life of the project (discounted back to 2010\$), and assumes a 50/50
23 blended cost based on use of existing and new diesel units¹³⁹.

24 • **PV Capacity Costs:** The present value capacity costs includes the full capital costs for new
25 diesel capacity needed to meet capacity reliability requirements (i.e., diesel capacity additions

¹³⁸ This ignores diesel capacity capital costs. As noted, diesel plant capacity costs are very low relative to other resource options and YEC also can utilize existing diesel capacity throughout most of the planning period. Diesel capacity costs are fully considered in the PV analysis - excluding these costs from the Forecast LCOE analysis is done to simplify the analysis.

¹³⁹ Average diesel fuel and O&M cost of 28.03 cents/kW.h based on average of diesel fuel cost for existing units (30 cents/kW.h) and diesel fuel and O&M costs for new units (26.06 cents/kW.h) escalated annually by 2%.

1 needed to deal with retirements and/or load growth impacts on N-1 or LOLE capacity planning
2 criteria). This includes all capital costs when the capacity is projected to be required, i.e., it does
3 not address only annualized costs over the planning period. For non-diesel resource options,
4 diesel capacity requirements are deferred or removed from the planning period as appropriate
5 (i.e., to reflect firm capacity provided by a non-diesel resource option), and the portfolio is
6 thereby credited with appropriate PV diesel capacity cost savings.

- 7 ○ For the Default Diesel Portfolio, this includes the PV (2010\$) of capital costs assumed for
8 LOLE related added capacity requirements (based on mine loads in excess of 13 MW) as
9 well as N-1 capacity requirements (depending on which planning criteria takes
10 precedence) – assuming diesel replacements occur at \$1.5 million/MW with annual 2%
11 inflation where there are forecast capacity shortfalls.
- 12 ○ Based on capacity shortfall forecasts, during the 20-year planning period 60.4 MW of
13 new diesel capacity is required under the no DSM/SSE case, and 37.1 MW of new diesel
14 capacity is required with assumed DSM/SSE (i.e., this overall 20-year requirement is not
15 affected by the different load scenarios). This is because all three load scenarios assume
16 mine closures after 2021 and adopt the same non-industrial load forecast through the
17 planning period.
- 18 ○ Variation in capacity PV between load scenarios in Table 4-2 reflects the impact of
19 projected mine loads in accelerating the timing of new capacity additions during the
20 planning period (as a result of the LOLE capacity planning criteria requirements).

- 21 • **DSM/SSE Impacts:** The analysis shows present values with and without the assumed DSM/SSE
22 to facilitate assessment of the extent to which uncertainty regarding the assumed DSM/SSE may
23 affect the conclusions.

24 Table 4-2 shows PV costs (2010\$) for the Default Diesel Portfolio increasing with higher forecast loads,
25 and decreasing as a result of the assumed DSM/SSE. PV Energy costs are dominant (i.e., PV Capacity
26 costs account for only 14-17% of total PV costs for all load scenarios other than the Base Case with
27 DSM/SSE), where PV Energy costs are very low.

1 **Table 4-2: Default Diesel Portfolio Option Present Value Grid Costs**
 2 **(2010\$million): 2011-2030**

PV 2010\$ million ¹	PV Energy Costs ²	PV Capacity Capital Costs ³	DSM/SSE Cost ⁴	Total PV Costs
No DSM/SSE				
Base Case	111.8	52.8		164.6
Scenario A	227.6	55.9		283.5
Scenario B	304.6	59.1		363.7
With DSM/SSE				
Base Case	30.8	31.9	35.4	98.1
Scenario A	133.9	34.7	35.4	204.0
Scenario B	207.3	38.4	35.4	281.2

Notes:

1. Costs discounted at 6.56% per year YEC blended cost of capital.
2. Diesel fuel O&M - assumes 50/50 blend of existing and new units.
3. Includes present value (2010\$) capital cost of assumed LOLE-related added capacity requirements (based on mine loads in excess of 13 MW) as well as N-1 capacity requirements where these are prime requirement.
4. DSM/SSE average annual costs assumed at 7.5 cents/kW.h.

3
 4 The above Default Diesel portfolio includes the impacts/effects of an assumed robust DSM/SSE programs
 5 (i.e., effect of DSM/SSE saving of diesel-related energy and capacity costs is approximately \$80-\$82
 6 million under Scenario A or B). As noted, for this analysis DSM/SSE costs are assumed at 7.5 cents/ kW.h
 7 (2010\$); in reality, DSM/SSE costs will vary depending on the types of DSM methods/programs (e.g.,
 8 rates, subsidies, standards and costs) selected and the effectiveness of those choices in reaching their
 9 energy reduction targets. As Canadian jurisdictions typically assess DSM/SSE program cost effectiveness
 10 relative to total resource costs as well as rate impacts, DSM/SSE program costs are required to be
 11 competitive with costs of new generation and are often assessed to be well below costs for new
 12 generation¹⁴⁰. Ongoing costs associated with DSM (e.g., O&M) generally include recurring or consistent
 13 program implementation costs, program evaluation costs and regulatory costs. Analysis regarding
 14 DSM/SSE costs and benefits is based on (and limited by) the best available information at this time
 15 (absent completion of the current conservation potential review and determination to proceed with
 16 specific DSM/SSE programs).

¹⁴⁰ This provides the utility with room to adjust for any uncertainty regarding the sustainability, costs and/or effectiveness of DSM energy reductions over the longer-term.

1 **4.3 YUKON GREENHOUSE GAS EMISSIONS IMPACT**

2 Increased diesel generation on or off the grid in Yukon will increase GHG emissions from power
3 generation, with about 700 tonnes added GHG emissions per GW.h of diesel generation¹⁴¹. Annual levels
4 of diesel generation (and related GHG emissions) vary a great deal under the Default Diesel Portfolio
5 depending on the loads considered:

6 • **Grid Power Generation** – GHG emissions (tonnes/year) with the Default Diesel Portfolio vary
7 as follows during the planning period for the different load scenarios with DSM/SSE.

8 ○ **Base Case load:**

- 9 ▪ 2012-2020 – Vary from 6,100 to 12,400 tonnes/year
10 ▪ After 2020 – Vary from zero to 5,300 tonnes/year

11 ○ **Scenario A load:**

- 12 ▪ 2012-2020 – Vary from 8,100 to 62,400 tonnes/year
13 ▪ After 2020 – Vary from zero to 5,300 tonnes/year

14 ○ **Scenario B load:**

- 15 ▪ 2012-2020 – Vary from 8,100 to 101,300 tonnes/year
16 ▪ After 2020 – Vary from zero to 5,300 tonnes/year


17 • **Off-Grid Diesel Community Power Generation** – Over the past five years, off-grid
18 communities served by YECL [Watson Lake, Beaver Creek, Destruction Bay, Swift River and Old
19 Crow] have maintained diesel generation in a range between 20-22 GW.h/year (14,000 to 15,400
20 tonnes of GHGs per year). Minimal overall growth in off-grid utility generation is projected over
21 the planning period. Under the Default Diesel Portfolio for the grid, these off-grid GHG emissions
22 are not affected.

23 • **Off-Grid Industrial Power Generation** – As noted in Section 2, off-grid mines (at a distance
24 that currently makes interconnection infeasible) are projected to develop using either on-site
25 diesel or LNG, increasing potential overall Yukon GHG emissions by an additional 232,400 tonnes
26 in 2015 and 749,800 tonnes by 2020. Under the Default Diesel Portfolio for the grid, these off-
27 grid GHG emissions are not affected.

¹⁴¹ As reviewed in Section 2, 700 tonnes GHG emissions per GW.h of diesel generation approximates the expected emissions with a new baseload unit under normal operating conditions (e.g., 4 kW.h/litre fuel use). Older diesel units or operating conditions with lower energy efficiencies will result in higher GHG emissions per GW.h.

1 Figure 4-3 below shows the total grid and off-grid utility power generation GHG emissions over the
 2 resource planning period with assumed DSM/SSE. Under Scenario A and Scenario B loads grid GHG
 3 emissions will exceed off-grid utility community GHGs over the period from 2012 through 2020. However,
 4 after 2021 minimal on grid GHG emissions are forecast compared to off-grid utility community GHG
 5 emissions in diesel rate zones. Overall grid and off-grid Yukon GHG emissions from power generation are
 6 expected to be much higher than the emissions shown in Figure 4-3 (i.e., off-grid industrial GHG
 7 emissions by 2015 and following may potentially be more than four times the Default Diesel grid
 8 emissions under Scenario A (see Figure 4-4)).

9 **Figure 4-3: Grid & Off-Grid Diesel Community Power Generation GHG Emissions**
 10 **(tonnes/year) 2012-2030 with assumed DSM/SSE**



Yukon Utility GHG Emissions	2012	2015	2020	2025	2030
Base Case	8,067	10,635	6,079	1,255	5,273
Scenario A	8,067	59,420	50,776	1,255	5,273
Scenario B	8,067	99,999	84,414	1,255	5,273
Off Grid Diesel Community GHGs	14,013	14,247	14,644	15,053	15,473

11
 12
 13 The above GHG emissions relate only to utility electricity generation (grid and off-grid diesel
 14 communities) and not total Yukon GHG emissions from all sources. The total Yukon wide estimate for
 15 GHG emissions in 2011 is approximately 375,000 tonnes (with total electrical sector GHGs in 2011
 16 estimated to be 0% of this total (i.e., 1106 tonnes of a total 375,000 tonnes of emissions)).

1 As reviewed below, connecting mine loads in the near-term (rather than having these mines supplied off-
2 grid with on-site diesel generation) will reduce GHG emissions even under the Default Diesel Portfolio to
3 the extent that underutilized existing hydro generation can be used to reduce incremental diesel
4 generation required for these incremental loads.

5 Considering 2015 forecast loads (with and without DSM/SSE), the following are noted with each grid load
6 scenario regarding GHG emissions under the Default Diesel Portfolio¹⁴²:

- 7 • **Base Case (with Minto and Alexco)** – Absent interconnection with the Yukon grid and
8 considering 2015 forecast loads these mines would produce 44,100 tonnes of GHGs. With grid
9 interconnection total grid GHG emissions are 10,640 tonnes with DSM/SSE and 16,590 tonnes
10 without DSM/SSE. This equals between 27,510 and 33,460 tonnes of GHG emission savings in
11 2015 through these mines being interconnected.
- 12 • **Scenario A (Base Case with Victoria Gold)** – With interconnection of Victoria Gold, 2015 grid
13 diesel requirements with and without DSM (including non-industrial loads losses) are 84.9 GW.h
14 and 98.9 GW.h respectively. Total tonnes of GHG emissions with Victoria Gold connected to the
15 grid are 59,430 tonnes with DSM/SSE and 69,230 tonnes without DSM/SSE; compared to the
16 Base Case (same load excluding Victoria Gold), the added GHG emissions associated with the
17 Victoria Gold load are 48,790 tonnes with DSM/SSE and 35,770 tonnes without DSM/SSE.
 - 18 ○ Absent an interconnection, the 95 GW.h of Victoria Gold load at site would be provided
19 through diesel generation at site¹⁴³ (66,500 tonnes of GHG emissions off-grid if assume
20 same diesel efficiency, slightly less if assume higher diesel unit efficiency).
 - 21 ○ In summary, if Victoria Gold comes into operation with the loads as assumed, overall
22 GHG emissions would be lower if Victoria Gold is connected to the grid versus supplied
23 with off-grid power.
- 24 • **Scenario B (Scenario A with Carmacks Copper and Whitehorse Copper Tailings**
25 **[WHCT])** – With interconnection diesel requirements (for Scenario B including non-industrial
26 loads and losses) with and without DSM/SSE are 142.9 GW.h and 158.1 GW.h respectively. Total
27 amount of GHGs with these mine loads connected to the grid are 100,030 tonnes with DSM/SSE

¹⁴² Estimates provided below do not consider or reflect scenarios where a mine may have process heat requirement and use waste heat. The GHG emission analysis also focuses only on power generation impacts in Yukon, i.e., other GHG emissions from each sector for heat, transport or other activities are not addressed.


¹⁴³ Given the location of this mine north of the Keno area, non-diesel options such as LNG would likely be severely constrained by haul cost impacts.

1 and 110,670 tonnes without DSM/SSE. Added grid diesel generation impacts (and related GHG
2 emissions) are linked mostly to the year round Victoria Gold and Carmacks Copper loads rather
3 than the WHCT summer-only load.

4 In summary, if the Scenario A or B new industrial loads did not connect to the grid, diesel requirements
5 on the grid and related grid GHG emissions would be reduced, as well as any related rate impacts to be
6 shared by Yukon ratepayers. However, if these same potential industrial loads develop using on site
7 diesel generation, overall Yukon GHG emissions under Scenario A and likely also Scenario B with off-grid
8 diesel generation will be higher than would otherwise occur with the mine connected to the grid
9 (reflecting the impact of grid access to available hydro generation during non-winter months as well at
10 other times during years with above average flows).

11 Figure 4-4 and the accompanying table illustrate the extent to which GHG emissions from grid generation
12 are a small portion of total GHG emission for the Yukon power generation sector. While utility cost
13 considerations and ratepayer impacts are focused only on grid load default diesel generation
14 requirements, considerations related to GHG emissions reductions in the power generation sector
15 (whether utility generation or industrial on site generation) must consider the whole of Yukon.

1 **Figure 4-4: Total Yukon Non-Renewable Generation (Grid & Off-Grid): 2011-2030**



2

	2011	2015	2020	2025	2030
Grid Diesel Generation - Base Case					
GHG Emissions (tonnes) DSM/SSE	1,062	10,635	6,079	1,255	5,273
GHG Emissions (tonnes) - No DSM/SSE	1,062	16,588	22,773	28,220	57,979
Grid Diesel Generation - Scenario A					
GHG Emissions (tonnes) DSM/SSE	1,062	59,420	50,776	1,255	5,273
GHG Emissions (tonnes) - No DSM/SSE	1,062	69,228	78,400	28,220	57,979
Grid Diesel Generation - Scenario B					
GHG Emissions (tonnes) DSM/SSE	1,062	99,999	84,414	1,255	5,273
GHG Emissions (tonnes) - No DSM/SSE	1,062	110,673	114,304	28,220	57,979
Off Grid Utility Diesel Community Generation					
Off Grid Utility Diesel Generation (GWh)	19.9	20.4	20.9	21.5	22.1
GHG Emissions (tonnes)	13,936	14,247	14,644	15,053	15,473
Off Grid Mine Diesel Generation					
Diesel or LNG Generation (GW.h)	37.0	332.0	1537.8	1389.8	1337.8
GHG Emissions (tonnes)	25,900	232,400	749,814	646,214	609,814
(assumes LNG at Casino with combined cycle power generation)					

3

4 **4.4 LONG-TERM DEVELOPMENT CONSIDERATIONS**

5 The Default Diesel Portfolio is not normally viewed as conducive to expanded grid development.

6 As noted in the 2006 Resource Plan, it may not be considered feasible to develop new transmission to
 7 service a mine (with associated transmission line losses) if the power is being largely generated via diesel
 8 at Whitehorse, when the same power could likely be generated at the mine site using diesel without the
 9 associated transmission losses. To the extent that a new mine load such as Victoria Gold is in fact
 Section 4 – Default Diesel Portfolio

1 supplied by diesel generation under the Default Diesel Portfolio (rather than surplus hydro or other lower
2 cost new supply options), the option of on-site diesel generation would serve to minimize the resulting
3 Yukon diesel generation requirement due to lower line losses leading to lower diesel generation-related
4 GHG emissions.

5 The above GHG emission analysis indicates that, at least under Scenario A, the connection of Victoria
6 Gold to the grid would result in some diesel generation savings with the Default Diesel Portfolio relative
7 to the option of diesel generation at the mine site. However, given the Charrette challenge to balance
8 considerations of environment and cost, there is a continuing requirement to find ways to supply new
9 mine loads with other "greener" grid generation supply options that can justify further grid connections
10 and work to lower costs in both the near-term and longer-term.

11 Over the longer-term, load opportunities affecting longer-term legacy planning for new generation to
12 start construction before 2021 remain highly uncertain and there are currently no assumed further grid
13 connections in the forecast.

- 14 • The existing and currently committed grid system capability is forecast between 2021 and 2030
15 to require generation for non-industrial loads, under long-term average water year conditions,
16 ranging from 8 to 83 GW.h/year (with and without DSM/SSE)¹⁴⁴.
- 17 • Aside from expected DSM/SSE activities during the planning period, these forecast diesel
18 requirements will also be reduced by any near-term resource supply developments such as Marsh
19 Lake Storage.
- 20 • Potential non-industrial sector electrification impacts to increase generation requirements are
21 highly uncertain today, and unlikely to have major impacts within the planning period.

22 The Default Diesel Portfolio could potentially be viewed in the near-term as a flexible approach to
23 accommodate the above uncertainties during a period when forecast grid loads do not easily facilitate
24 major new renewable generation resource development (see Section 5.4).

¹⁴⁴ However, there are obvious risks regarding the long-term sustainability of ongoing DSM/SSE reductions as assumed beyond the next 10 to 20 years, and the two projections (with and without DSM/SSE) might be viewed as an indication of forecast uncertainties.

1 However, on its own, the Default Diesel Portfolio approach would increase the pressure to constrain all
2 other utility costs to the extent that either Scenario A or Scenario B forecast loads materialize:

- 3 • As reviewed, the Default Diesel Portfolio under Scenario A or B would result in very large rate
4 increase pressures by 2014-15, with or without DSM/SSE. These rate increase impacts would be
5 over and above those otherwise required to recover ongoing cost increases, cost deferrals that
6 need to be brought into rates, or other rate changes directed by the YUB.
- 7 • During periods of material diesel generation requirement (i.e., under Scenario A and Scenario B
8 load scenarios), these fuel-related cost increases will act to place added pressure to constrain
9 other O&M and capital cost items that would exacerbate material diesel-related rate increase
10 impacts on ratepayers throughout Yukon. These pressures combined with uncertainty about
11 longer-term loads could materially constrain ongoing capital spending and planning costs on
12 other long-term resource planning options such as legacy greenfield hydro projects that could
13 help in future to reduce both costs and emissions.
- 14 • The Default Diesel scenario would increase pressures to constrain connection of new loads to the
15 grid in order to reduce overall near-term diesel requirements. Absent existing and potential future
16 industrial connections to the grid; however, there would be little if any basis to pursue spending
17 and planning costs related to other long-term resource planning options (i.e., without new
18 industrial connected loads, the increased grid loads required to support new legacy resource
19 developments would not be forecast during the current 20-year planning period).

1 **5.0 MINIMUM GREENHOUSE GAS EMISSIONS PORTFOLIO OPTIONS**

2 **5.1 DEFINING THE PORTFOLIO OPTIONS**

3 Portfolio options to yield minimum GHG emissions are examined below to address the near-term and
4 longer-term load scenarios, assuming the same DSM/SSE as included with the Default Diesel Portfolio.
5 These options focus primarily on potential renewable resource development responses to the forecast
6 increase in energy and capacity as one path to avoid reliance on default diesel generation, based on
7 hydro enhancement, wind and thermal-biomass or waste-to-energy (WTE) resource options as screened
8 in Section 3.2.

9 Each of the eligible resource options is intended to minimize GHG emissions as compared to diesel
10 generation. Each option is also constrained by a potential earliest in-service timing, potential level of
11 generation throughout the year at full utilization, estimated costs, and other distinctive features. Finally,
12 each option is capital intensive relative to diesel generation and therefore Forecast LCOE over its
13 economic life is sensitive to forecast utilization levels over the 20-year resource planning period.

14 **5.1.1 Available Near-Term Resource Options**

15 Available near-term renewable resource options for the minimum GHG portfolio are summarized as
16 follows based on the screening in Section 3.2:

- 17 • **Hydro Enhancements** – Marsh Lake Storage is assumed to be a likely option to be developed,
18 while Gladstone Diversion is considered to be more problematic due to regulatory risks:
 - 19 ○ **Marsh Lake Storage** – This is a relatively small project. Earliest in-service is assumed in
20 late 2014¹⁴⁵ (first full year 2015) at capital cost (2010\$) of \$10.5 million; annual
21 generation of 6.4 GW.h on average, focused in winter months at current Whitehorse
22 plant; annual operating cost (2010\$) of \$8/MW.h. Full Utilization LCOE (2010\$) at 8.5
23 cents/ kW.h. Marsh Lake Storage is assumed to provide 1 MW of added reliable peak
24 winter capacity.
 - 25 ○ **Gladstone in combination with Marsh Lake** – Consideration is given to Gladstone
26 Diversion being developed as soon as feasible after Marsh Lake Storage in order to
27 secure greatly increased hydro enhancement benefits. Earliest in-service for Gladstone

¹⁴⁵ Reflects time needed for YESAA, FAA and other permit processes and YWB licensing plus one construction season.

1 Diversion is assumed in late 2017¹⁴⁶ (first full year 2018) at capital cost (2010\$) of \$40
2 million; annual Gladstone Diversion generation of 36.6 GW.h on average, focused in
3 winter months at current Aishihik plant; Gladstone Diversion annual operating cost
4 (2010\$) of \$6/MW.h. Full Utilization LCOE (2010\$) at 5.7 cents/kW.h. The combined
5 Marsh Lake and Gladstone option Full Utilization LCOE (2010\$) is 6.2 cents/kW.h.
6 Gladstone Diversion is considered solely on the basis of potential diesel energy
7 displacement benefits¹⁴⁷.

- 8 • **Thermal-Wood Biomass** - Two sets of wood-biomass thermal plant options are considered for
9 in-service by late 2014¹⁴⁸ (2015 first full year of operation) with an assumed economic life of 20
10 years (reflects anticipated forest license tenure) - based on the assumed locations, full winter
11 peak capacity benefits are assumed for each wood biomass plant option:

- 12 ○ **25 MW plant located in Whitehorse:** This plant is assumed to have a capital cost
13 (2010\$) of \$4.56 million per MW (\$114 million), annual non-fuel operating cost of \$4
14 million (2010\$), and annual generation of 199.3 GW.h/year (91% annual capacity factor)
15 using 139,510 tonnes (oven dry tonnes or "ODT") of wood biomass feedstock delivered
16 from Haines Junction, the Fox Lake burn area and the Minto burn area at an average
17 delivered cost (2010\$) of \$150/ODT (\$105/MW.h). Full Utilization LCOE (2010\$) for the
18 25 MW wood biomass option is 16.6 cents/kW.h; including \$1.53 million of annual district
19 heat revenues (per Morrison Hershfield estimates) reduces the Full Utilization LCOE to
20 15.8 cents/kW.h.

- 21 ○ **10-15 MW plant located in the Minto burn area:** These plant options are smaller
22 than the reported optimum scale for a biomass plant of 20-30+ MW, and therefore are
23 assumed to incur greatly increased non-fuel costs per unit of output (i.e., capital cost
24 (2010\$) of \$6.38 million per MW (\$63.8 million) for the 10 MW plant and \$5.7 million per
25 MW (\$85.5 million) for the 15 MW plant); the same annual non-fuel operating cost of \$4
26 million (2010\$) is assumed for each plant. Annual generation at 91% annual capacity
27 factor (79.8 GW.h/year for 10 MW plant, 119.6 GW.h/year for 15 MW plant), with wood

¹⁴⁶ Reflects time needed for YESAA, FAA and other permit processes and YWB licensing plus two construction seasons; the YESAA and FAA applications are assumed to be delayed due to need for up to two years of further pathogen studies required by DFO and delays until YEC can resolve arrangements with the local First Nation.

¹⁴⁷ No peak winter capacity benefit is assumed for Gladstone Diversion given that all generation impacts occur at Aishihik and under the N-1 test no reliable capacity currently exists at this plant.

¹⁴⁸ Assumed timing only for purposes of this analysis, and further prefeasibility analysis required to assess feedstock supply and required forestry licence requirements, as well as timing requirements for feasibility studies, YESAB review and other permitting, and construction.

1 biomass requirements at 0.7 ODT/MW.h. At these smaller plant scales, wood biomass
2 feedstock costs are minimized by locating the plant in the wood supply area – and, based
3 on current feedstock supply estimates, the only such location that could meet this test on
4 a least cost basis is the Minto burn area near the Klondike Highway¹⁴⁹. Wood biomass
5 feedstock cost (2010\$) is estimated at \$96/ODT for a 10 MW plant and \$104/ODT for a
6 15 MW plant. Full Utilization LCOE (2010\$) is 17.5 cents/kW.h for the 10 MW plant and
7 15.8 cents/kW.h for the 15 MW plant.

- 8 • **Thermal - Municipal Solid Waste (MSW) or “Waste to Energy” (WTE)** – A 2.2 MW plant
9 in Whitehorse and generating 17.1 GW.h/year (89% annual capacity factor) for a 25 year life is
10 assumed in-service by late 2014¹⁵⁰ (2015 first full year) using 25,000 ODT/year of MSW feedstock
11 plus a small amount of wood biomass (3,800 ODT/year at an assumed cost of \$75/ODT), and
12 with district heat net revenues, tipping fees and other revenues of \$3.3 million/year (2010\$);
13 O&M costs excluding wood biomass of \$2.7 million/year (2010\$); and capital cost (2010\$) of
14 \$17.73 million per MW (\$39.0 million). Full Utilization LCOE (2010\$) is 13.5 cents/kW.h with the
15 assumed other revenues (23.7 cents/ kW.h with no district heat revenues, 31.4 cents/kW.h with
16 no tipping fees or district heat revenues). Full winter peak capacity benefits are assumed for this
17 plant.
- 18 • **Wind** – Two wind options are being considered, each with an earliest in-service in late 2014¹⁵¹
19 (first full year 2015) and an assumed operating life of 25 years (the 10.5 MW option would be
20 considered as a first stage of the 21 MW development):
 - 21 ○ **A 21 MW wind farm** is assumed at Ferry Hill (immediately north of Stewart Crossing),
22 with a 5 MW DRUPS included for grid reliability requirements and added capital cost of
23 \$10 million (see Section 3.1 for explanation of this screening). Capital cost (2010\$) of

¹⁴⁹ See Appendix E, Attachment E4 and the review therein of the Morrison Hershfield report. Haines Junction does not appear to have adequate biomass supply to sustain a 10 or 15 MW plant, whereas the Minto burn area alone could apparently sustain a 10 MW plant and, with some added feedstock from the Fox Lake burn area, a 15 MW plant. Wood feedstock costs for a Whitehorse plant reflect haul costs and are estimated (2010\$) at \$131/ODT for a 10 MW plant and \$138/ODT for a 15 MW plant. If district heat revenue potentially available only at Whitehorse is treated as a feedstock cost offset, net feedstock costs for a Whitehorse location are estimated at \$104/ODT for a 10 MW plant and \$120/ODT for a 15 MW plant (i.e., costs that are in each instance higher than for the same scale plant located at the Minto burn area).

¹⁵⁰ Assumed timing only for purposes of this analysis, and further prefeasibility analysis required regarding feedstock supply and district heat sale arrangements, as well as timing requirements for feasibility studies, environmental review/permitting, and construction.

¹⁵¹ An additional year of wind monitoring will be concluded at Ferry Hill site in spring 2012; following completion of satisfactory monitoring, three years are assumed to be required to come into service (one year for environmental review and approvals and two construction seasons).

- 1 \$93.4 million (includes DRUPS and transmission connection to the Stewart Crossing south
2 substation); annual average generation of 55.6 GW.h; annual operating cost (2010\$) of
3 \$38/MW.h. Full Utilization LCOE (2010\$) at 14.8 cents/kW.h. None of the plant's capacity
4 would provide reliable peak winter capacity (beyond the 5 MW assumed DRUPS facility
5 included in this option).
- 6 ○ **A 10.5 MW first stage development of the above Ferry Hill wind farm** is
7 assumed without the need for any DRUPS¹⁵² and with transmission connection only to
8 Stewart Crossing north substation. Capital cost (2010\$) of \$49.552 million; annual
9 average generation and operating cost at 50% of the 21 MW wind farm (27.8 GW.h/year
10 and \$1.05 million/year). Full Utilization LCOE (2010\$) at 15.5 cents/kW.h. None of the
11 plant's capacity would provide reliable peak winter capacity.

12 **5.1.2 Available Longer-Term Resource Options**

13 Available long-term renewable resource options for the minimum GHG planning portfolio as identified in
14 Section 3.2 consist primarily of greenfield hydro resource options potentially available to start
15 construction before 2021, provided that sufficient site specific planning processes are sustained as
16 required throughout the next five year period through 2015.

17 Hydro resource options provide renewable energy with low GHG emissions. Subject to adequate grid
18 loads to sustain high utilization for 30+ years, there are 17 medium to large hydro options that also offer
19 low costs per kW.h (i.e., below 15 cents/kW.h Full Utilization LCOE) plus additional small hydro sites with
20 costs below 25 cents/kW.h. These are summarized in Table 5.1 below.

21 • **Medium (11-60 MW) & Large (>60 MW) Hydro Options:**

- 22 ○ **Less than 10 cents/kW.h:** Nine sites or schemes are identified in Section 3.2 with
23 estimated Full Utilization LCOE's (2009\$) below 10 cents/kW.h and over 4,390 GW.h per
24 year of average annual sustainable energy (net of duplication among sites); four of these
25 sites are Medium scale (over 850 GW.h/year).
- 26 ○ **10-15 cents/kW.h:** A further eight sites or schemes are identified with Full Utilization
27 LCOE's between 10 and 15 cents/kW.h and over 2,000 GW.h of additional average
28 annual sustainable energy; five of these sites are medium scale (over 850 GW.h/year).

¹⁵² This assumes that no added DRUPS is required for reliability so long as the wind resource development is limited to this scale on the grid. It is assumed that approximately 5 MW of spinning reserve is currently available and that (regardless of wind resource use) about 10 MW of existing non-base loaded hydro units would be converted to synchronous condenser peaking units at a cost of approximately \$0.5 million per unit (see Appendix E, Attachment E5).

- 1 ○ **Other:** A further two medium scale sites located north of the Watson Lake area are
2 identified with Full Utilization LCOE's under 15 cents/kW.h if exceptionally high
3 transmission cost estimates to connect to the existing grid are excluded from
4 consideration. Together, these sites could provide over 375 GW.h per year of additional
5 average annual sustainable energy.
- 6 • **Small (<10 MW) Hydro Options:**
- 7 ○ **Southern Lakes (20-23 cents/kW.h):** Section 3.2 identifies up to 70 GW.h/year
8 potentially available small hydro in the Southern Lakes region at Moon Lake and Tutchi
9 River or Tutchi (Windy Arm), with annual energy potential for each site approximating 30
10 to 39 GW.h/year with Full Utilization LCOE (including transmission to Yukon grid) at 20-
11 23 cents/kW.h.
- 12 ○ **Pine Creek Hydro at Atlin:** Section 3.2 also identifies potential transmission connection
13 of the Yukon grid to the Taku River Tlingit owned Pine Creek Hydro Generating Station
14 near Atlin, B.C. to take advantage of underutilized existing capacity plus undeveloped
15 capability at the generating station¹⁵³. Options identified here include a 3.5 MW option
16 (utilize existing surplus hydro with a 2.2 MW expansion, annual potential of 23 GW.h)
17 and an 8 MW option that includes the expanded existing plant plus a new 4 MW
18 downstream plant with an overall annual load potential of 52 GW.h.

¹⁵³ Yukon Energy has engaged in very preliminary discussions with representatives of the First Nation Development Corporation and a mutual interest has been expressed to continue discussions.

1

Table 5-1: Summary of Potential Hydro Sites

		Installed Capacity (MW)	Annual Energy (GWh)	Capital Cost (Million \$2009)	Levelized Cost (c/kWh)
Small Hydro Projects <10MW					
20-23 c/kWh	Moon Lake	5.8	32.9	126.8*	19.9
	Tutshi River	4.2	30.3	135.5*	23.1
	Tutshi (Windy Arm)	5.9	39.4	164.9*	21.6
	Pine Creek at Atlin	3.5-8	23-52	NA	NA
Medium Hydro Projects (<60 MW)					
< 10 c/kWh	Hoole Canyon with Storage	40.4	275	460.1	8.6
	Granite Canyon Small	60.0	400	670.3	8.7
	Slate Rapids	41.6	266	505.6	9.8
	Finlayson	17.0	128.9	233.7**	9.4
10 to 15 c/kWh	Ross Canyon	30	181	495.0	14.1
	False Canyon	58	370	1,036.3**	14.5
	Two Mile Canyon	53.1	280	696.5	12.9
	Combined Slate Rapids ¹ & Hoole	50.1	351.1	728.9	10.7
	Slate Rapids ¹ (powerhouse at foot of dam)	22.3	156.3	441.4	14.6
Other ²	Middle Canyon	38.0	200	773.5***	20.0
	Upper Canyon	25.2	176.6	677.2***	19.8
Large Hydro Project (>60 mW)					
< 10 c/kWh	Granite Canyon High	254.0	1,783	1,680.7	4.9
	Fraser Falls Low	100.0	700	1,340.4	9.9
	Granite Canyon Low	80.0	600	934.8	7.3
	Fraser Falls High	300.0	2,100	2,540.6	6.3
	Combined Slate Rapids & Hoole	69.4	459	849.7*	9.6
10 to 15 c/kWh	Detour Canyon	65.0	435	1,057.0	12.6
	Detour Canyon w storage At Pelly Lakes	100.0	585	1,301.0	11.5
	Liard Canyon	93.5	659	1,554.6**	12.2

Notes:

1. Powerhouse at foot of dam

2. Excluding exceptionally high transmission costs to connect to existing grid, these sites would be under 15 cents per kW.h.

* Transmission costs to connect to grid are 18% of cost for Tutshi (Windy Arm), 21% of cost for Combined Slate Rapids & Hoole Canyon, and 26-27% of cost for Moon Lake & Tutshi River.

** Transmission costs are 33% of cost for Liard Canyon, 36% of cost for Finlayson, and 38% of cost for False Canyon.

*** Transmission costs to connect to existing grid are estimated at 54-55% of cost for these sites.

2

3 Geothermal and clean coal resource options were also identified in Section 3.2 as other long-term options
4 that might also provide in Yukon both low cost and low GHG emissions. For the reasons reviewed below,
5 neither of these options is currently considered as available to start construction before 2021:

- 6 • **Geothermal** opportunities in Yukon have been subject to high level review in order to ascertain
7 geologic and economic potential for development for heat and electricity production at the

1 following locations: Haines Junction, Volcano Mountain, Whitehorse, McArthur, Nash Creek and
2 Larson Creek. A preliminary resource assessment and prioritization of sites has been recently
3 undertaken for Yukon Energy by Borealis Geopower. This assessment indicates that, while
4 unconfirmed, there is clearly a material and significant potential at the sites identified.
5 Whitehorse is identified as a site with highest priority ranking compared to other sites¹⁵⁴, with its
6 main advantage being proximity to power infrastructure and markets. However, the report
7 indicates that all sites have some level of exploration risk, and that the information collected to
8 date is insufficient to substantiate a finding of the inferred geothermal resources at any of the six
9 sites.

10 Future consideration of geothermal is dependent on successful exploration that defines
11 appropriate opportunities close to the grid. Considerable costs would likely be required to carry
12 out the necessary ongoing exploration and confirmation drilling to locate and then develop
13 geothermal as a greenfield resource in Yukon. Funding for this type of development activity at
14 the scale likely to be needed is not typical for a regulated utility such as Yukon Energy.
15 Accordingly, the 2011 Resource Plan does not provide any specific major proposed activities for
16 geothermal beyond monitoring of related activities in Yukon.

- 17 • **Clean coal** opportunities exist in Yukon close to the grid, subject to development of a cost-
18 effective clean coal technology as well as proven and cost-effective small scale coal technology.
19 Given that development of such technologies will likely depend on activities in other major
20 jurisdictions, no Yukon-specific activities are identified in the 2011 Resource Plan regarding this
21 option beyond ongoing monitoring of indigenous Yukon coal resource development as well as
22 evolving clean and small scale coal technology in other jurisdictions.

23 **5.1.3 Near-Term Portfolio Options**

24 GHG emissions in Yukon power generation are linked directly to diesel generation. To provide a clear
25 reference point, it is assumed for the "Minimum GHG Emissions Portfolio" that the objective "to minimize
26 GHG emissions from power generation" is equivalent in Yukon today to minimizing diesel generation
27 through reliance only on renewable resource options. Section 5 explores the implications of relying only
28 on renewable resource options to displace 80% or more of the future default diesel generation forecast in
29 Section 4 under each load scenario.

¹⁵⁴ Estimates of potential capacity and cost per kW.h for the Whitehorse site ranged from 30-45 MW and 9.3 to 12.6 cents/kW.h. Other sites had lower potential capacity estimates and higher potential cost estimates (except for Larson Creek, located in the far southeast corner of Yukon, which had the same cost range as Whitehorse).

1 The current resource planning is focused only on preliminary assessments of possible portfolio options in
2 order to obtain guidance as to preferred resource options to be pursued at this time. Based on the
3 available renewable resource options, near-term portfolio options (i.e., combinations of the renewable
4 resource options) are defined to minimize diesel generation under each grid load scenario during the
5 2015-2019 period when forecast grid diesel generation is currently expected to be highest (i.e., averaging
6 (with DSM/SSE) about 15 GW.h/year under the Base Case load forecast, about 85 GW.h/year under the
7 Scenario A load forecast, and about 142 GW.h/year under the Scenario B load forecast).

8 **5.1.3.1 Base Case Portfolio Options**

9 Given the available renewable resource options, Base Case loads are not sufficient to merit examination
10 of any of the above renewable options other than the following:

- 11 • Marsh Lake Storage (which could displace 6 GW.h/year [about 40%] of the Base Case average
12 diesel generation during 2015-2019 with DSM/SSE) – Forecast LCOE (2010\$) of 12.1 cents/kW.h
13 for Base Case with DSM/SSE.
- 14 • Gladstone Diversion¹⁵⁵ combined with Marsh Lake Storage could displace 16-17 GW.h/yr [about
15 100%] of the Base Case average diesel generation during 2018-2019 with DSM/SSE); however,
16 the Gladstone Diversion is not assumed to be in-service until late 2017 – Forecast LCOE (2010\$)
17 of 15.2 cents/kW.h for Base Case with DSM/SSE.
- 18 • The 10.5 MW Wind option (which could displace 11-13 GW.h year [about 80%] of the Base Case
19 average diesel generation during 2015-2019 with DSM/SSE) – Forecast LCOE (2010\$) of 52.9
20 cents/kW.h for Base Case with DSM/SSE.
- 21 • The 2.2 MW WTE option (which could displace 7-8 GW.h year [about 50%] of the Base Case
22 average diesel generation during 2015-2019 with DSM/SSE) – Forecast LCOE (2010\$) of 44.7
23 cents/kW.h for Base Case with DSM/SSE.

¹⁵⁵ Gladstone Diversion provides more diesel displacement capability (maximum impact 35-38 GW.h/year) than is needed for the Base Case; however, this resource option offers much lower cost per kW.h (as well as lower capital cost) for Base Case loads than would occur with other non-WTE renewable options (wind or wood biomass) and it is therefore selected for assessment.

1 In summary, three Base Case portfolio options to minimize GHG emissions (each includes Marsh Lake
2 Storage) are defined for further assessment:

- 3 • Min GHG Portfolio - Base Case #1 - Marsh Lake Storage & Gladstone Diversion [2015-19 diesel
4 displacement with DSM/SSE: on average over 2015-2019: 62%; after 2017 when Gladstone
5 assumed in-service, 95-97%].
- 6 • Min GHG Portfolio - Base Case #2 - Marsh Lake Storage & 10.5 MW Wind [2015-19 diesel
7 displacement with DSM/SSE: on average over 2015-2019: 95%].
- 8 • Min GHG Portfolio- Base Case #3 - Marsh Lake Storage & 2.2 MW WTE [2015-19 diesel
9 displacement with DSM/SSE: on average over 2015-2019: 68%].

10 A summary of the annual diesel displaced by Base Case Portfolio Options 1 to 3 with DSM/SSE is provided
11 in Table 5-2A (Option BC #1), Table 5-3A (Option BC #2) and Table 5-4A (Option BC #3). Present Value
12 Costs for each of these Minimum GHG Portfolio Options are provided in Tables 5-2B (Option BC #1),
13 Table 5-3B (Option BC #2), and Table 5-4B (Option BC #3) - these costs are reviewed in Section 5.2.

1 **Table 5-2A: Minimum GHG Emissions Portfolio Option BC #1 - Forecast Grid Diesel Generation Displaced by Load Scenario**
2 **DSM/SSE, Marsh Lake Storage and Gladstone: 2011 -2030 (GW.h/year)**

Forecast Years	Base case				Scenario A				Scenario B			
	with DSM		without DSM		with DSM		without DSM		with DSM		without DSM	
	(GW.h/y)	(%)	(GW.h/y)	(%)	(GW.h/y)	(%)	(GW.h/y)	(%)	(GW.h/y)	(%)	(GW.h/y)	(%)
2011	0.0	0%	0.0	0%	0.0	0%	0.0	0%	0.0	0%	0.0	0%
2012	0.0	0%	0.0	0%	0.0	0%	0.0	0%	0.0	0%	0.0	0%
2013	0.0	0%	0.0	0%	0.0	0%	0.0	0%	0.0	0%	0.0	0%
2014	0.0	0%	0.0	0%	0.0	0%	0.0	0%	0.0	0%	0.0	0%
2015	5.3	35%	6.0	25%	6.4	7%	6.3	6%	6.6	5%	6.3	4%
2016	5.1	38%	6.1	24%	6.4	8%	6.3	6%	6.6	5%	6.3	4%
2017	5.3	36%	6.2	21%	6.4	8%	6.2	6%	6.6	5%	6.3	4%
2018	15.7	97%	25.3	71%	34.5	40%	36.4	31%	37.5	26%	38.6	22%
2019	16.7	95%	27.2	65%	34.7	39%	36.7	30%	37.3	27%	38.6	22%
2020	8.7	100%	24.2	74%	33.0	46%	36.2	32%	36.6	30%	38.2	23%
2021	0.0	0%	16.0	96%	0.0	0%	16.6	100%	2.0	100%	20.4	85%
2022	0.0	0%	19.2	89%	0.0	0%	19.2	89%	0.0	0%	19.2	89%
2023	0.3	100%	22.0	81%	0.3	100%	22.0	81%	0.3	100%	22.0	81%
2024	1.0	100%	24.6	73%	1.0	100%	24.6	73%	1.0	100%	24.6	73%
2025	1.8	100%	26.8	66%	1.8	100%	26.8	66%	1.8	100%	26.8	66%
2026	2.7	100%	28.8	60%	2.7	100%	28.8	60%	2.7	100%	28.8	60%
2027	3.7	100%	30.5	55%	3.7	100%	30.5	55%	3.7	100%	30.5	55%
2028	4.9	100%	31.9	50%	4.9	100%	31.9	50%	4.9	100%	31.9	50%
2029	6.1	100%	33.1	45%	6.1	100%	33.1	45%	6.1	100%	33.1	45%
2030	7.5	100%	34.1	41%	7.5	100%	34.1	41%	7.5	100%	34.1	41%

1 **Table 5-2B: Minimum GHG Emissions Portfolio Option BC #1 Present Value Costs: 2011-2030 (2010\$million)**

PV 2010\$ million ¹	PV Energy Costs ²	PV Capacity Capital Costs ³	DSM/SSE Cost	Total PV Costs	Change from Diesel Only (LOLE proxy) ⁴
No DSM/SSE					
Base Case	83.9	51.6		135.5	-29.1
Scenario A	193.4	54.6		248.0	-35.5
Scenario B	268.5	57.8		326.3	-37.4
With DSM/SSE					
Base Case	43.8	30.8	35.4	110.0	11.9
Scenario A	134.6	33.5	35.4	203.5	-0.5
Scenario B	205.8	37.2	35.4	278.4	-2.7

Notes:

1. Costs discounted at 6.56% per year YEC blended cost of capital.
2. Marsh Lake & Gladstone costs. Assumes diesel fuel & O&M units for all diesel not displaced by Project.
3. Includes present value (2010\$) capital cost of assumed LOLE-related added capacity requirements (based on mine loads in excess of 13 MW) as well as N-1 capacity requirements where these are prime requirement. Includes costs and benefits of new resource option impacts on reliable capacity requirements where relevant.
4. See Diesel Portfolio Option Present Value Costs.

2

1 **Table 5-3A: Minimum GHG Emissions Portfolio Option BC #2 - Forecast Grid Diesel Generation Displaced by Load Scenario**
2 **DSM/SSE, Marsh Lake Storage and 10.5 MW Wind: 2011 -2030 (GW.h/year)**

Forecast Years	Base case				Scenario A				Scenario B			
	with DSM		without DSM		with DSM		without DSM		with DSM		without DSM	
	(GW.h/y)	(%)	(GW.h/y)	(%)	(GW.h/y)	(%)	(GW.h/y)	(%)	(GW.h/y)	(%)	(GW.h/y)	(%)
2011	0.0	0%	0.0	0%	0.0	0%	0.0	0%	0.0	0%	0.0	0%
2012	0.0	0%	0.0	0%	0.0	0%	0.0	0%	0.0	0%	0.0	0%
2013	0.0	0%	0.0	0%	0.0	0%	0.0	0%	0.0	0%	0.0	0%
2014	0.0	0%	0.0	0%	0.0	0%	0.0	0%	0.0	0%	0.0	0%
2015	14.6	96%	19.3	82%	30.0	35%	31.8	32%	32.4	23%	32.8	21%
2016	13.0	97%	19.7	80%	29.5	36%	32.0	32%	32.3	23%	32.8	21%
2017	14.2	96%	21.3	71%	29.9	36%	32.6	30%	32.4	23%	32.8	20%
2018	15.3	95%	22.6	64%	30.2	35%	32.8	28%	32.5	22%	32.8	19%
2019	16.3	92%	23.6	57%	30.6	34%	32.3	26%	32.3	23%	32.8	19%
2020	8.7	100%	22.0	68%	28.1	39%	32.7	29%	32.6	27%	32.8	20%
2021	0.0	0%	15.6	94%	0.0	0%	15.6	94%	2.0	100%	19.4	81%
2022	0.0	0%	18.5	85%	0.0	0%	18.5	85%	0.0	0%	18.5	85%
2023	0.3	100%	20.6	75%	0.3	100%	20.6	75%	0.3	100%	20.6	75%
2024	1.0	100%	22.2	66%	1.0	100%	22.2	66%	1.0	100%	22.2	66%
2025	1.8	100%	23.4	58%	1.8	100%	23.4	58%	1.8	100%	23.4	58%
2026	2.7	100%	24.6	52%	2.7	100%	24.6	52%	2.7	100%	24.6	52%
2027	3.7	100%	25.7	46%	3.7	100%	25.7	46%	3.7	100%	25.7	46%
2028	4.9	100%	26.9	42%	4.9	100%	26.9	42%	4.9	100%	26.9	42%
2029	6.1	100%	28.2	39%	6.1	100%	28.2	39%	6.1	100%	28.2	39%
2030	7.5	100%	29.7	36%	7.5	100%	29.7	36%	7.5	100%	29.7	36%

1 **Table 5-3B: Minimum GHG Emissions Portfolio Option BC #2 Present Value Costs: 2011-2030 (2010\$million)**

PV 2010\$ million ¹	PV Energy Costs ²	PV Capacity Capital Costs ³	DSM/SSE Cost	Total PV Costs	Change from Diesel Only (LOLE proxy) ⁴
No DSM/SSE					
Base Case	106.1	51.6		157.8	-6.8
Scenario A	208.6	54.6		263.2	-20.3
Scenario B	284.4	57.8		342.2	-21.5
With DSM/SSE					
Base Case	63.8	30.8	35.4	130.0	31.9
Scenario A	147.4	33.5	35.4	216.3	12.3
Scenario B	217.3	37.2	35.4	289.9	8.7

1. Costs discounted at 6.56% per year YEC blended cost of capital.

2. Marsh Lake and 10.5 MW Wind costs. Assumes diesel fuel & O&M units for all diesel not displaced by Projects.

3. Includes present value (2010\$) capital cost of assumed LOLE-related added capacity requirements (based on mine loads in excess of 13 MW) as well as N-1 capacity requirements where these are prime requirement. Includes costs and benefits of new resource option impacts on reliable capacity requirements where relevant.

2 4. See Diesel Portfolio Option Present Value Costs.

1 **Table 5-4A: Minimum GHG Emissions Portfolio Option BC #3 – Forecast Grid Diesel Generation Displaced by Load Scenario**
2 **DSM/SSE, Marsh Lake Storage and 2.2 MW WTE: 2011 -2030 (GW.h/year)**

Forecast Years	Base case				Scenario A				Scenario B			
	with DSM		without DSM		with DSM		without DSM		with DSM		without DSM	
	(GW.h/y)	(%)	(GW.h/y)	(%)	(GW.h/y)	(%)	(GW.h/y)	(%)	(GW.h/y)	(%)	(GW.h/y)	(%)
2011	0.0	0%	0.0	0%	0.0	0%	0.0	0%	0.0	0%	0.0	0%
2012	0.0	0%	0.0	0%	0.0	0%	0.0	0%	0.0	0%	0.0	0%
2013	0.0	0%	0.0	0%	0.0	0%	0.0	0%	0.0	0%	0.0	0%
2014	0.0	0%	0.0	0%	0.0	0%	0.0	0%	0.0	0%	0.0	0%
2015	10.5	69%	12.9	54%	18.9	22%	19.5	20%	21.3	15%	21.9	14%
2016	9.8	73%	13.2	53%	18.7	23%	19.6	19%	21.2	15%	22.0	14%
2017	10.3	70%	14.2	47%	18.8	22%	19.9	18%	21.3	15%	22.2	13%
2018	10.8	67%	15.0	42%	18.9	22%	20.2	17%	21.4	15%	22.5	13%
2019	11.3	64%	15.8	38%	19.1	21%	20.6	17%	21.2	15%	22.5	13%
2020	7.5	87%	14.6	45%	18.2	25%	20.1	18%	20.4	17%	22.1	14%
2021	0.0	0%	10.9	66%	0.0	0%	10.9	66%	2.0	100%	13.0	54%
2022	0.0	0%	12.4	57%	0.0	0%	12.4	57%	0.0	0%	12.4	57%
2023	0.3	100%	13.7	50%	0.3	100%	13.7	50%	0.3	100%	13.7	50%
2024	1.0	100%	14.8	44%	1.0	100%	14.8	44%	1.0	100%	14.8	44%
2025	1.8	100%	15.7	39%	1.8	100%	15.7	39%	1.8	100%	15.7	39%
2026	2.7	100%	16.5	35%	2.7	100%	16.5	35%	2.7	100%	16.5	35%
2027	3.7	100%	17.1	31%	3.7	100%	17.1	31%	3.7	100%	17.1	31%
2028	4.8	99%	17.7	28%	4.8	99%	17.7	28%	4.8	99%	17.7	28%
2029	5.9	96%	18.3	25%	5.9	96%	18.3	25%	5.9	96%	18.3	25%
2030	6.8	91%	18.8	23%	6.8	91%	18.8	23%	6.8	91%	18.8	23%

3

1 **Table 5-4B: Minimum GHG Emissions Portfolio Option BC #3 Present Value Costs: 2011-2030 (2010\$million)**

PV 2010\$ million ¹	PV Energy Costs ²	PV Capacity Capital Costs ³	DSM/SSE Cost	Total PV Costs	Change from Diesel Only (LOLE proxy) ⁴
No DSM/SSE					
Base Case	105.5	49.0		154.5	-10.1
Scenario A	214.4	51.8		266.2	-17.3
Scenario B	288.3	55.1		343.4	-20.3
With DSM/SSE					
Base Case	48.0	28.4	35.4	111.9	13.8
Scenario A	140.5	30.7	35.4	206.6	2.6
Scenario B	210.7	34.4	35.4	280.5	-0.6

Notes:

1. Costs discounted at 6.56% per year YEC blended cost of capital.
2. Marsh Lake and WTE costs. Assumes diesel fuel & O&M units for all diesel not displaced by Projects.
3. Includes present value (2010\$) capital cost of assumed LOLE-related added capacity requirements (based on mine loads in excess of 13 MW) as well as N-1 capacity requirements where these are prime requirement. Includes costs and benefits of new resource option impacts on reliable capacity requirements where relevant.
4. See Diesel Portfolio Option Present Value Costs.

2

1 **5.1.3.2 Scenario A and B Portfolio Options**

2 For Scenario A and B loads, higher levels of forecast default diesel use prior to 2021 provide opportunities
 3 for consideration of all currently available renewable resource projects.

4 The initial challenge is to review the short list of resource options (see Table 5-5) to assess which would
 5 be optimum to include in a near-term renewable resource portfolio to minimize GHG emissions under
 6 Scenario A and B loads.

7 **Table 5-5: Diesel Displaced by Renewable Resource Option - 2015-2019**
 8 **Percent of Potential Annual Diesel Displacement (%)**

	Scenario A with DSM/SSE*	Scenario B with DSM/SSE**
25 MW Biomass Plant	100%	94%
15 MW Biomass Plant	85%	65%
10 MW Biomass Plant	64%	46%
Ferry Hill - Wind 21 MW	53%	36%
Ferry Hill - Wind 10.5 MW	28%	19%
Marsh Lake and Gladstone	21%	13%
2.2 MW WTE	16%	11%
Marsh Lake Storage	7%	5%

* Potential Annual Average Diesel Displacement = 85 GW.h/year

** Potential Annual Average Diesel Displacement = 142 GW.h/year

9
 10 Table 5-5 summarizes diesel displacement capability (ranked by scale of displacement) for each eligible
 11 resource option as a percent of forecast default diesel average annual generation for Scenario A load and
 12 Scenario B load with DSM/SSE during the 2015-2019 period (85 and 142 GW.h/year respectively). This
 13 analysis is provided as an aid to screening of these options – when combinations of these resource
 14 options are considered, the combined diesel displacement impact will typically be less than the sum of
 15 the percentages shown below for each individual project.

16 The 25 MW thermal wood biomass plant is the only near-term renewable resource option that could
 17 potentially on its own achieve minimum GHG emissions for both Scenario A and B loads. As suggested
 18 earlier in Section 2 (Figure 2-13), a 25 MW wood biomass facility could displace 100% of Scenario A
 19 forecast diesel generation during the 2015-2019 period even if there was no DSM/SSE. Under Scenario B
 20 loads during this same period, a 25 MW wood biomass plant would displace 94% of forecast diesel
 21 generation with DSM/SSE and over 85% of forecast diesel generation with no DSM/SSE. This resource
 22 option would also make available waste heat for district heat sales in Whitehorse.

1 Aside from timing and other issues related to feedstock supply, the major problem with selecting a 25
2 MW wood biomass option for the minimum GHG emissions portfolio is the high cost incurred per kW.h of
3 diesel displaced over the 20-year assumed life of the plant (see also Section 2.4 discussion of the
4 challenges related to the 2011 Resource Plan load forecasts and diesel displacement opportunities on the
5 Yukon hydro grid):

- 6 • Forecast LCOE (2010\$) per kW.h of diesel displaced for the 25 MW wood biomass option is 92.5
7 cents/kW.h for Scenario A with DSM/SSE (42.2 cents/kW.h with no DSM/SSE); for Scenario B,
8 Forecast LCOE remains high (60.5 cents/kW.h with DSM/SSE, and 35.4 cents/kW.h with no
9 DSM/SSE). Including estimated district heat net revenues potentially available in Whitehorse
10 would reduce these LCOE costs by only 2 to 4 cents/kW.h.
- 11 • This high cost per kW.h of diesel displaced in part reflects the extent to which a 25 MW plant
12 operating year round during the 2015-2019 period (when mine loads are connected under
13 Scenario A and B) would be in effect displacing a great deal of existing hydro generation over the
14 summer/fall seasons. As shown earlier in Figure 2-13 for a 2015-2016 time period example under
15 Scenario A with no DSM/SSE, on average the level of displaced hydro that is spilled (95.9
16 GW.h/year in the example) with this 25 MW wood biomass plant is almost as large as the diesel
17 displaced (101 GW.h in the example), resulting in only about 51% of the wood biomass
18 generation being used to displace diesel generation. This means that an annual cost in 2015 of
19 21 cents/kW.h with full utilization of all biomass plant generation to displace diesel (i.e., the full
20 utilization costing assumed in Table 3-1, adjusted for the initial year of operation rather than
21 overall life cycle average costs) would in reality become 41 cents/kW.h of diesel displaced in that
22 year.
- 23 • However, this high cost for Forecast LCOE per kW.h of diesel displaced mostly reflects the sharp
24 drop in forecast diesel generation after 2021. Forecast LCOE of 92.5 cents/kW.h of diesel
25 displaced under Scenario A loads with DSM/SSE is greatly reduced (but still more expensive than
26 diesel generation displaced) if forecast mine loads are extended by 5 to 10 years:
 - 27 ○ If assumed mine loads were to be extended sufficiently to maintain 89 GW.h/year of
28 diesel displacement (the forecast displacement in 2019) to the end of 2025, Forecast
29 LCOE would be lowered from 92.5 cents/kW.h to 55.4 cents/kW.h.
 - 30 ○ Extending the same level of diesel displacement to the end of 2030 would reduce
31 Forecast LCOE to 42.8 cents/kW.h.

32 Figure 5-1 demonstrates why Forecast LCOE per kW.h of diesel displaced is increased so much for the 25
33 MW wood biomass plant under Scenario A loads with DSM/SSE. As shown, the option would generate

1 199 GW.h/year for 20 years; however, over its 20-year life, over 85% of this biomass energy would play
2 no useful role in displacing diesel generation under Scenario A loads.

3 • When mine loads are on the grid (up to 2021), less than half of the biomass energy would be
4 used to displace diesel generation - reflecting the extent to which a 25 MW thermal plant is far
5 too large for the Yukon grid during this period.

6 • After 2021 (when no mine loads are assumed), the biomass energy from this plant would be
7 used almost entirely to displace hydro from existing hydro facilities (a situation where the plant
8 would presumably be closed to save feedstock and other O&M costs).

9 • In summary, the extent to which this 25 MW biomass plant over its life would in effect displace
10 hydro generation (rather than diesel generation) is the main factor accounting for a Forecast
11 LCOE of 92.5 cents/kW.h versus a Full Utilization LCOE of 16.6 cents/kW.h which assumes that
12 all biomass generation fully used to displace diesel generation.

13 Figure 5-2 demonstrates the extent to which the 25 MW wood biomass plant Forecast LCOE at Scenario A
14 load with DSM/SSE is materially higher than Forecast LCOE under the same load for the smaller 10 MW
15 and 15 MW wood biomass plants that are able to secure much lower feedstock costs. This figure also
16 shows for each biomass plant option the sensitivity of this Forecast LCOE under Scenario A load when
17 mine loads are extended to 2025 and 2030. The smaller plants (10 MW and 15 MW) show broadly similar
18 Forecast LCOE for Scenario A load with DSM/SSE and for each mine life sensitivity examined – Forecast
19 LCOE for these smaller plants are roughly two-thirds of the Forecast LCOE for the 25 MW plant, but
20 remain high, e.g. 29 cents/kW.h even under mine load Sensitivity #2 (mine life extended to 2030).

21 Based on the above information, the 25 MW wood biomass plant option is not considered further. Other
22 renewable resource options (including the smaller wood biomass plants) are examined to select the most
23 cost effective portfolio options to secure minimum GHG emissions (i.e., at least 80% diesel displacement
24 during the 2015-2019 period. Ongoing work is refining optimum options where appropriate and feasible).

25 Looking at diesel displacement capability during 2015-2019, the 10 MW and 15 MW wood biomass
26 options each displace more diesel than the wind, hydro or WTE resource options (see Table 5-5).

27 The 15 MW wood biomass plant on its own could displace over 80% of the potential diesel generation
28 under Scenario A, and 65% under Scenario B.

29 In contrast, the percent of potential annual diesel displacement under Scenario A with DSM/SSE during
30 2015-2019 is 53% with the 21 MW wind option, 21% with the Marsh Lake & Gladstone combination

1 option (reflects 5-year average - 40% diesel displacement by 2018 when Gladstone assumed in-service),
2 16% with the 2.2 MW WTE option, and 7% with Marsh Lake Storage option on its own.

3 As noted in Section 2.4, developing new generation that cannot displace diesel generation would be
4 wasteful – a factor which is demonstrated, for example, when explaining why long-term large hydro
5 resource developments in Yukon (which offer local renewable supply with minimal GHG emissions) would
6 not be economically feasible without first securing long-term diesel displacement loads to at least match
7 the new hydro generation to be developed. The same principles that apply at an annual load level also
8 apply at the seasonal load level, subject to the ability to facilitate enhanced hydro storage for use during
9 the winter season.


10 The underlying economic feasibility issues noted here are not resolved by resort to secondary sales
11 (interruptible sales) of the surplus hydro. The basic premise of secondary sales is that, at most, very
12 limited investment is made to facilitate such sales, and that such sales are incidental to the project's
13 primary objectives¹⁵⁶. On a seasonal basis, secondary sales opportunities in Yukon are also weakest in
14 summer (i.e., the season when diesel generation displacement opportunities are minimal). In summary,
15 while secondary sales would continue to be promoted during periods of hydro surplus in order to reduce
16 overall costs charged to firm service customers, such secondary sales cannot provide a sound economic
17 rationale for planned developments that create surplus hydro on the grid.

18 The concept of wood biomass thermal operation displacing generation from existing hydro resources, as
19 discussed above, assumes that the wood biomass operation is not suspended at such times as hydro
20 generation cannot be used (i.e., when water is spilled rather than used to run the generators). For the
21 purpose of highlighting the challenges related to the existing hydro grid, this concept was retained in this
22 analysis. However, where feasible, YEC would not in practice allow existing hydro generation to be
23 displaced by other more costly sources of generation (i.e., the wood biomass plant, which (as a thermal
24 option) can be shut down when so required, would not be operated in years (and perhaps during
25 seasons) when its generation fails to displace material diesel generation). In the following analysis,
26 options are noted when the wood biomass option has no O&M costs after the mine loads are shut down.
27 This facilitates savings in ongoing operating and maintenance costs (but the annual capital costs continue
28 to be included in the analysis).

¹⁵⁶ See response to YUB-YEC-1-44, YEC Mayo B Application for an Energy Project Certificate.


1
 2

Figure 5-1: Wood Biomass 25 MW Thermal Project Displacing Diesel & Hydro at Scenario A Load with DSM/SSE (current forecast mine life, no mine loads after 2021)



3

1 **Figure 5-2: Summary LCOE (2010\$) for Thermal Wood Biomass Plant Options at Scenario A Load with DSM/SSE**



1 In defining minimum GHG emission portfolio options for Scenario A and B loads, it is relevant to examine
2 whether certain renewable resource options merit consideration based simply on costs, notwithstanding
3 less impact than wood biomass plant options in displacing diesel generation under Scenario A or B loads.

4 Figure 5-3 provides Forecast LCOE [2010\$] at Scenario A load with DSM/SSE, and different sensitivity
5 cases for extending mine load, for 15 MW wood biomass, 21 MW Wind, 10.5 MW Wind, 2.2 MW WTE,
6 and Marsh Lake Storage combined with Gladstone Diversion. Figure 5-4 uses the 21 MW Wind option to
7 demonstrate why Forecast LCOE per kW.h of diesel displaced increases so much for capital intensive
8 options under Scenario A (i.e., over the 25 year life of the 21 MW Wind project, most of the 55.6 GW.h of
9 annual average generation is forecast to play no useful role in displacing diesel generation under Scenario
10 A loads with mine loads forecast not to extend beyond 2020). In differing ways, similar impacts occur for
11 each of the other renewable resource options examined.

12 The following considerations are noted:

- 13 • Marsh Lake Storage is assumed to be included in any minimum GHG emissions portfolio option,
14 reflecting its relatively low Forecast LCOE (e.g., 11.4 cents/kW.h under Scenario A with
15 DSM/SSE) and expected development timing.
- 16 • Gladstone Diversion combined with Marsh Lake Storage offers low costs per kW.h similar to the
17 Marsh Lake Storage alone option (Forecast LCOE 13.1 cents/kW.h under Scenario A with
18 DSM/SSE), as well as much greater diesel displacement capability once Gladstone comes into
19 service¹⁵⁷; however, Gladstone Diversion's regulatory risk and delayed earliest in-service timing
20 mean that it can be considered only as a possible added future development that likely cannot be
21 under construction by 2015.
- 22 • The 21 MW and 10.5 MW Wind options reflect different development staging for an initial wind
23 farm. Under Scenario A load with DSM/SSE, Forecast LCOE is 40 cents/kW.h for the 21 MW
24 larger scale development and 34.7 cents/kW.h for the smaller first stage development option
25 (i.e., costs per kW.h more than double costs for Marsh Lake and Gladstone).
 - 26 ○ These wind options offer notable diesel displacement with Forecast LCOE well below that
27 shown for the 10 and 15 MW wood biomass plant options (as provided in Figure 5-2).

¹⁵⁷ By 2018 the combined Gladstone and Marsh Lake projects would displace 40 % of Scenario A load with DSM/SSE, and 26% of Scenario B load with DSM/SSE.

- 1 ○ Development of the 10.5 MW first stage wind option would facilitate further future
2 development of this site's wind farm.
- 3 • The 2.2 WTE option Forecast LCOE of 31.5 cents/kW.h under Scenario A load with DSM/SSE¹⁵⁸
4 (including district heat revenues and tipping fees) does not offer either low cost or large scale
5 diesel displacement. Figure 5-3 notes that the Forecast LCOE of 31.5 cents/kW.h under Scenario
6 A reflects costs at 73.5 cents/kW.h before offset revenues for tipping fees (17.9 cents/kW.h) and
7 district heat revenues (24.1 cents/kW.h – this revenue source is also potentially available for
8 thermal generation options using other feedstock). The WTE resource option is considered
9 further only for Scenario A and B loads as a potential “extra” renewable resource to secure
10 greater GHG reduction.

11 In summary, four near-term Scenario A and B “min GHG” portfolio options are defined for further
12 assessment. As reviewed below, Marsh Lake Storage is included in each portfolio option. The first two
13 options compare combining Marsh Lake Storage with either a 15 MW wood biomass plant (which has
14 ample capacity for the forecast loads) or a 21 MW wind project plus 2.2 MW WTE project. The second
15 two options also include Gladstone Diversion (assuming that this project is permitted and in service by
16 late 2017) and compare combining Marsh Lake Storage and Gladstone Diversion plus a 21 MW wind
17 project with or without a 2.2 WTE project:

- 18 • **Min GHG Portfolio – Scenario A&B #1 (Marsh & Wood)** – Marsh Lake Storage & 15 MW
19 Wood Biomass [2015-19 diesel displacement with DSM/SSE: 90% for Scenario A and 70% for
20 Scenario B]; this portfolio optimizes the wood biomass resource option for Scenario A and B
21 loads. GHG reduction target is achieved without the need to add further resource options.
- 22 • **Min GHG Portfolio – Scenario A&B #2 (Marsh, Wind & WTE)** – Marsh Lake Storage, 21
23 MW Wind, & 2.2 WTE [2015-19 diesel displacement with DSM/SSE: 72% for Scenario A and 50%
24 for Scenario B]; this portfolio is the best GHG emission reduction available in the near-term from
25 eligible renewable resource options without resort to wood biomass or Gladstone Diversion.
- 26 • **Min GHG Portfolio – Scenario A&B #3 (Marsh-Gladstone & Wind)** – Marsh Lake Storage
27 & Gladstone Diversion, & 21 MW Wind [2015-19 diesel displacement with DSM/SSE: on average
28 over 2015-2019: 70% for Scenario A and 49% for Scenario B; after 2017 when Gladstone


¹⁵⁸ Forecast LCOE (2010\$) for the 2.2 MW WTE option is 28.8 cents/kW.h for Scenario B with DSM/SSE; with no DSM/SSE, Forecast LCOE is 17.6 cents/kW.h for Scenario A and 16.8 cents/kW.h for Scenario B. Full Utilization LCOE is 13.5 cents/kW.h.

1 assumed in-service, 84% for Scenario A and 61% for Scenario B]; this portfolio shows the benefit
2 without WTE if Gladstone Diversion is in service in 2018.

- 3 • **Min GHG Portfolio – Scenario A&B #4 (Marsh-Gladstone, Wind & WTE)** – Marsh Lake
4 Storage & Gladstone Diversion, 21 MW Wind, & 2.2 MW WTE [2015-19 diesel displacement with
5 DSM/SSE: on average over 2015-2019: 81% for Scenario A and 58% for Scenario B; after 2017
6 when Gladstone assumed in-service, 92% for Scenario A and 70% for Scenario B]; this portfolio
7 represents the best GHG emission reduction available in the near-term from the eligible
8 renewable resource options without resort to wood biomass.


9 A summary of the annual diesel displaced by Scenario A and B Portfolio Options #1 to #4 is provided in
10 Table 5-6A (Option A/B #1), Table 5-7A (Option A/B), #2 Table 5-8A (Option A/B #3), and Table 5-9A
11 (Option A/B #4). Present Value Costs for each of these Minimum GHG Portfolio Options are provided in
12 Tables 5-6B (Option A/B #1), Table 5-7B (Option A/B #2), Table 5-8B (Option A/B #3) and Table 5-9B
13 (Option A/B #4) - these present value costs are reviewed in Section 5.2.

Figure 5-3: Forecast LCOE (2010\$) - 15 MW Wood Biomass, 21 MW Wind, 10.5 MW Wind, 2.2 MW WTE and Marsh Lake & Gladstone - Scenario A Load with DSM/SSE



1
 2

Figure 5-4: Wind Project: Displacing Diesel and Hydro at Scenario A Load with DSM/SSE
 (current forecast mine life, no mine loads after 2021)



3

Table 5-6A: Minimum GHG Emissions Portfolio Option A/B #1 Forecast Grid Diesel Generation Displaced by Load Scenario DSM/SSE, Marsh Lake Storage & 15 MW Biomass: 2011-2030 (GW.h/year)

Forecast Years	Scenario A				Scenario B			
	with DSM		without DSM		with DSM		without DSM	
	(GW.h/y)	(%)	(GW.h/y)	(%)	(GW.h/y)	(%)	(GW.h/y)	(%)
2011	0.0	0%	0.0	0%	0.0	0%	0.0	0%
2012	0.0	0%	0.0	0%	0.0	0%	0.0	0%
2013	0.0	0%	0.0	0%	0.0	0%	0.0	0%
2014	0.0	0%	0.0	0%	0.0	0%	0.0	0%
2015	76.7	90%	83.9	85%	98.7	69%	102.0	65%
2016	74.8	92%	84.7	84%	97.9	70%	102.3	64%
2017	76.2	91%	88.0	81%	98.5	69%	103.8	62%
2018	77.6	90%	91.0	78%	99.2	69%	105.3	60%
2019	79.0	89%	93.7	75%	97.8	70%	105.3	60%
2020	68.9	95%	89.5	80%	92.5	77%	103.0	63%
2021	0.0	0%	16.6	100%	2.0	100%	24.0	100%
2022	0.0	0%	21.6	100%	0.0	0%	21.6	100%
2023	0.3	100%	27.3	100%	0.3	100%	27.3	100%
2024	1.0	100%	33.5	100%	1.0	100%	33.5	100%
2025	1.8	100%	40.3	100%	1.8	100%	40.3	100%
2026	2.7	100%	47.7	100%	2.7	100%	47.7	100%
2027	3.7	100%	55.7	100%	3.7	100%	55.7	100%
2028	4.9	100%	62.7	98%	4.9	100%	62.7	98%
2029	6.1	100%	69.4	95%	6.1	100%	69.4	95%
2030	7.5	100%	75.5	91%	7.5	100%	75.5	91%

Table 5-6B: Minimum GHG Emissions Portfolio Option A/B #1 Present Value Costs: 2011-2030 (2010\$million)

PV 2010\$ million ¹	PV Energy Costs ²	PV Capacity Capital Costs ³	DSM/SSE Cost	Total PV Costs	Change from Diesel Only (LOLE proxy) ⁴
No DSM/SSE					
Scenario A	253.1	36.8		289.9	6.5
Scenario B	310.2	39.1		349.3	-14.4
With DSM/SSE					
Scenario A	232.2	16.5	35.4	284.1	80.0
Scenario B	278.7	18.5	35.4	332.6	51.4

Notes:

1. Costs discounted at 6.56% per year YEC blended cost of capital.
2. Assumes diesel fuel & O&M units for all diesel not displaced by renewable resources.
3. Includes present value (2010\$) capital cost of assumed LOLE-related added capacity requirements (based on mine loads in excess of 13 MW) as well as N-1 capacity requirements where these are prime requirement. Includes costs and benefits of new resource option impacts on reliable capacity requirements where relevant.
4. See Diesel Portfolio Option Present Value Costs.

Table 5-7A: Minimum GHG Emissions Portfolio Option A/B #2 Forecast Grid Diesel Generation Displaced by Load Scenario DSM/SSE, Marsh Lake Storage & 21 MW Wind and 2.2 MW WTE: 2011-2030 (GW.h/year)

Forecast Years	Scenario A				Scenario B			
	with DSM		without DSM		with DSM		without DSM	
	(GW.h/y)	(%)	(GW.h/y)	(%)	(GW.h/y)	(%)	(GW.h/y)	(%)
2011	0.0	0%	0.0	0%	0.0	0%	0.0	0%
2012	0.0	0%	0.0	0%	0.0	0%	0.0	0%
2013	0.0	0%	0.0	0%	0.0	0%	0.0	0%
2014	0.0	0%	0.0	0%	0.0	0%	0.0	0%
2015	61.1	72%	64.7	65%	71.2	50%	72.4	46%
2016	60.2	74%	65.1	65%	70.9	51%	72.5	45%
2017	60.9	72%	66.6	62%	71.1	50%	72.9	43%
2018	61.6	71%	68.0	59%	71.4	49%	73.2	42%
2019	62.3	70%	69.2	56%	70.8	51%	73.2	42%
2020	57.2	79%	67.3	60%	68.6	57%	72.7	44%
2021	0.0	0%	16.6	100%	2.0	100%	24.0	100%
2022	0.0	0%	21.6	100%	0.0	0%	21.6	100%
2023	0.3	100%	27.3	100%	0.3	100%	27.3	100%
2024	1.0	100%	33.5	100%	1.0	100%	33.5	100%
2025	1.8	100%	40.3	100%	1.8	100%	40.3	100%
2026	2.7	100%	45.7	96%	2.7	100%	45.7	96%
2027	3.7	100%	50.0	90%	3.7	100%	50.0	90%
2028	4.9	100%	53.9	84%	4.9	100%	53.9	84%
2029	6.1	100%	57.4	78%	6.1	100%	57.4	78%
2030	7.5	100%	60.5	73%	7.5	100%	60.5	73%

Table 5-7B: Minimum GHG Emissions Portfolio Option A/B #2 Present Value Costs: 2011-2030 (2010\$million)

PV 2010\$ million ¹	PV Energy Costs ²	PV Capacity Capital Costs ³	DSM/SSE Cost	Total PV Costs	Change from Diesel Only (LOLE proxy) ⁴
No DSM/SSE					
Scenario A	212.2	45.7		257.9	-25.6
Scenario B	280.5	48.8		329.3	-34.4
With DSM/SSE					
Scenario A	178.0	24.6	35.4	238.0	34.0
Scenario B	238.7	28.1	35.4	302.3	21.1

Notes:

1. Costs discounted at 6.56% per year YEC blended cost of capital.
2. Marsh Lake, Wind and WTE costs. Assumes diesel fuel & O&M units for all diesel not displaced by Projects.
3. Includes present value (2010\$) capital cost of assumed LOLE-related added capacity requirements (based on mine loads in excess of 13 MW) as well as N-1 capacity requirements where these are prime requirement. Includes costs and benefits of new resource option impacts on reliable capacity requirements where relevant.
4. See Diesel Portfolio Option Present Value Costs.

Table 5-8A: Minimum GHG Emissions Portfolio Option A/B # 3 Forecast Grid Diesel Generation Displaced by Load Scenario DSM/SSE, Marsh Lake Storage & Gladstone Diversion, 21 MW Wind: 2011-2030 (GW.h/year)

Forecast Years	Scenario A				Scenario B			
	with DSM		without DSM		with DSM		without DSM	
	(GW.h/y)	(%)	(GW.h/y)	(%)	(GW.h/y)	(%)	(GW.h/y)	(%)
2011	0.0	0%	0.0	0%	0.0	0%	0.0	0%
2012	0.0	0%	0.0	0%	0.0	0%	0.0	0%
2013	0.0	0%	0.0	0%	0.0	0%	0.0	0%
2014	0.0	0%	0.0	0%	0.0	0%	0.0	0%
2015	50.7	60%	53.3	54%	57.4	40%	57.9	37%
2016	50.0	61%	53.5	53%	57.3	41%	58.0	36%
2017	50.5	60%	54.6	50%	57.4	40%	58.1	35%
2018	73.6	85%	83.0	71%	86.3	60%	88.3	50%
2019	74.8	84%	84.2	68%	85.8	62%	88.3	50%
2020	65.9	91%	82.2	73%	83.7	69%	87.5	54%
2021	0.0	0%	16.6	100%	2.0	100%	24.0	100%
2022	0.0	0%	21.6	100%	0.0	0%	21.6	100%
2023	0.3	100%	27.3	100%	0.3	100%	27.3	100%
2024	1.0	100%	33.5	100%	1.0	100%	33.5	100%
2025	1.8	100%	40.3	100%	1.8	100%	40.3	100%
2026	2.7	100%	47.7	100%	2.7	100%	47.7	100%
2027	3.7	100%	54.0	97%	3.7	100%	54.0	97%
2028	4.9	100%	60.5	94%	4.9	100%	60.5	94%
2029	6.1	100%	66.3	90%	6.1	100%	66.3	90%
2030	7.5	100%	71.6	86%	7.5	100%	71.6	86%

Table 5-8B: Minimum GHG Emissions Portfolio Option A/B # 3 Present Value Costs: 2011-2030 (2010\$million)

PV 2010\$ million ¹	PV Energy Costs ²	PV Capacity Capital Costs ³	DSM/SSE Cost	Total PV Costs	Change from Diesel Only (LOLE proxy) ⁴
No DSM/SSE					
Scenario A	202.1	48.3		250.5	-33.0
Scenario B	272.3	51.5		323.8	-39.8
With DSM/SSE					
Scenario A	173.3	27.3	35.4	236.0	32.0
Scenario B	234.0	30.9	35.4	300.4	19.2

Notes:

1. Costs discounted at 6.56% per year YEC blended cost of capital.

2. Assumes diesel fuel & O&M units for all diesel not displaced by renewable resources.

3. Includes present value (2010\$) capital cost of assumed LOLE-related added capacity requirements (based on mine loads in excess of 13 MW) as well as N-1 capacity requirements where these are prime requirement. Includes costs and benefits of new resource option impacts on reliable capacity requirements where relevant.

4. See Diesel Option Present Value Costs.

Table 5-9A: Minimum GHG Emissions Portfolio Option A/B #4 Forecast Grid Diesel Generation Displaced by Load Scenario DSM/SSE, Marsh Lake Storage & Gladstone Diversion & 21 MW Wind and 2.2 MW WTE: 2011-2030 (GW.h/year)

Forecast Years	Scenario A				Scenario B			
	with DSM		without DSM		with DSM		without DSM	
	(GW.h/y)	(%)	(GW.h/y)	(%)	(GW.h/y)	(%)	(GW.h/y)	(%)
2011	0.0	0%	0.0	0%	0.0	0%	0.0	0%
2012	0.0	0%	0.0	0%	0.0	0%	0.0	0%
2013	0.0	0%	0.0	0%	0.0	0%	0.0	0%
2014	0.0	0%	0.0	0%	0.0	0%	0.0	0%
2015	61.1	72%	64.7	65%	71.2	50%	72.4	46%
2016	60.2	74%	65.1	65%	70.9	51%	72.5	45%
2017	60.9	72%	66.6	62%	71.1	50%	72.9	43%
2018	80.2	93%	94.0	81%	100.1	69%	102.7	58%
2019	81.5	91%	96.6	78%	99.5	72%	102.6	58%
2020	72.5	100%	92.4	83%	95.5	79%	101.1	62%
2021	0.0	0%	16.6	100%	2.0	100%	24.0	100%
2022	0.0	0%	21.6	100%	0.0	0%	21.6	100%
2023	0.3	100%	27.3	100%	0.3	100%	27.3	100%
2024	1.0	100%	33.5	100%	1.0	100%	33.5	100%
2025	1.8	100%	40.3	100%	1.8	100%	40.3	100%
2026	2.7	100%	47.7	100%	2.7	100%	47.7	100%
2027	3.7	100%	55.7	100%	3.7	100%	55.7	100%
2028	4.9	100%	64.2	100%	4.9	100%	64.2	100%
2029	6.1	100%	73.2	100%	6.1	100%	73.2	100%
2030	7.5	100%	78.4	95%	7.5	100%	78.4	95%

Table 5-9B: Minimum GHG Emissions Portfolio Option A/B # 4 Present Value Costs: 2011-2030 (2010\$million)

PV 2010\$ million ¹	PV Energy Costs ²	PV Capacity Capital Costs ³	DSM/SSE Cost	Total PV Costs	Change from Diesel Only ⁴
No DSM/SSE					
Scenario A	211.8	45.7		257.5	-26.0
Scenario B	278.4	48.8		327.2	-36.5
With DSM/SSE					
Scenario A	188.7	24.6	35.4	248.8	44.8
Scenario B	243.6	28.1	35.4	307.2	26.0

Notes:

- Costs discounted at 6.56% per year YEC blended cost of capital.
- Marsh Lake&Gladstone, Wind and WTE costs. Assumes diesel fuel & O&M units for all diesel not displaced by Projects.
- Includes present value (2010\$) capital cost of assumed LOLE-related added capacity requirements (based on mine loads in excess of 13 MW) as well as N-1 capacity requirements where these are prime requirement. Includes costs and benefits of new resource option impacts on reliable capacity requirements where relevant.
- See Diesel Portfolio Option Present Value Costs.

1 **5.2 GRID ECONOMIC IMPACTS**

2 As reviewed in Section 4.2, grid economic impacts for Portfolio Options are compared based on Forecast
3 LCOE of non-diesel resource option package in each Portfolio and present value (PV) costs for each
4 Portfolio. The following assessment focuses on the Minimum GHG Emissions Portfolio Options, looking
5 separately in each instance at grid economic impacts for Base Case load options versus Scenario A and B
6 load options (i.e., minimum GHG emissions reduction is very different for these different near-term load
7 scenarios).

8 **Forecast LCOE - Non-Diesel Portfolio Options**

9 Forecast LCOE are provided in Table 5-10 (Base Case Load options) and Table 5-11 (Scenario A and B
10 Load options) for the non-diesel resource option package in each Minimum GHG Emissions Portfolio
11 Option in order to compare overall life cycle present value costs (i.e., includes costs beyond 2030 as
12 required) for the specific resource option package. The diesel default resource option cost for fuel and
13 O&M costs (2010\$ at approximate 28 cents/kW.h) is assumed for comparison.

14 Except for the hydro enhancement portfolios (Marsh Lake Storage and Gladstone Diversion), Forecast
15 LCOE for these Portfolio Options under loads with DSM/SSE at best approximate fuel and O&M costs for
16 diesel. Options such as BC #2 and A/B #1, which minimize GHG emissions without relying on Gladstone
17 Diversion, show forecast life cycle LCOE costs that are materially higher than diesel.

18 **Table 5-10: Forecast LCOE (cents/kW.h in 2010\$) for Minimum GHG Emissions Non-Diesel**
19 **Portfolio Options (excludes diesel costs) – Base Case Load Options**

	Diesel	Option BC #1 - Marsh Lake Storage & Gladstone Diversion	Option BC #2 - Marsh Lake Storage, & 10.5 MW Wind	Option BC #3 - Marsh Lake Storage and 2.2 MW WTE
No DSM/SSE				
Base Case	28.0	7.5	18.5	16.2
Scenario A	28.0	7.2	16.3	14.6
Scenario B	28.0	7.1	16.1	14.0
With DSM/SSE				
Base Case	28.0	15.2	42.2	31.7
Scenario A	28.0	13.1	28.9	24.2
Scenario B	28.0	12.8	27.3	22.5
Full Utilization	28.0	6.2	13.8	11.8

1 **Table 5-11: Forecast LCOE (2010\$) for Minimum GHG Emissions Non-Diesel**
2 **Portfolio Options (excludes diesel costs) – Scenario A and B Load Options**

	Diesel	Option A/B #1 - Marsh Lake Storage and 15 MW Biomass	Option A/B #1 - Marsh Lake Storage and 15 MW Biomass (No O&M after 2020)	Option A/B #2 - Marsh Lake Storage, 21 MW Wind, 2.2 MW WTE	Option A/B #3 - Marsh Lake Storage & Gladstone Div., 21 MW Wind	Option A/B #4 - Marsh Lake Storage & Gladstone Div., 21 MW Wind, 2.2 MW WTE
No DSM/SSE						
Base Case	28.0	NA	NA	NA	NA	NA
Scenario A	28.0	25.7	28.7	19.3	14.5	15.7
Scenario B	28.0	23.8	25.1	18.5	14.2	15.2
With DSM/SSE						
Base Case	28.0	NA	NA	NA	NA	NA
Scenario A	28.0	51.8	34.8	39.4	29.0	32.2
Scenario B	28.0	42.1	27.9	35.0	26.6	28.7
3 Full Utilization	28.0	15.2	NA	14.0	9.3	9.8

4 **Present Value (“PV”) Costs**

5 An overall present value cost assessment is provided in Table 5-12 for each Minimum GHG Emissions
6 Portfolio Option for Base Case loads, and in Table 5-13 for each Minimum GHG Emissions Portfolio Option
7 for Scenario A and B loads. In each table, Default Diesel Portfolio PV costs are also shown for
8 comparison. These assessments address total incremental generation costs during the planning period
9 (2011-2030) under the relevant near-term grid load scenarios, showing outcomes both with DSM/SSE
10 and no DSM/SSE.

11 Each portfolio option meets the forecast energy and capacity requirements for the grid over the planning
12 period, relying on diesel generation and capacity to supply any shortfalls not supplied by the assumed
13 new resource supply options.

- 14 • For example, diesel generation is assumed to be relied upon entirely before the new resource
15 supply option is in-service, as well as for any shortfalls in energy or capacity after the new option
16 is in service.
- 17 • Diesel is assumed to be relied upon to supply capacity as well as energy shortfalls. The present
18 value assessment for new capacity solely to meet reliability requirements (i.e., diesel capacity

1 additions) includes all capital costs (i.e., does not address only annualized costs over the planning
2 period). Capacity benefits are assumed as described for each resource option in Section 5.1¹⁵⁹.

3 • New resource option present value costs include all annualized costs over the planning period
4 (i.e., residual asset values that remain after 2030 are not addressed).

5 The analysis shows present values with and without the assumed DSM/SSE to facilitate assessment of the
6 extent to which uncertainty regarding the assumed DSM/SSE may affect the conclusions.

7 The present value costs for renewable resource portfolio options shown in Table 5-12 and 5-13 reflect (in
8 part) the assumption under all scenarios (based on best available information) that industrial loads drop
9 off the grid system in 2021. With planned aggressive non-industrial DSM measures over the planning
10 period, it is expected that there would be minimal diesel displacement opportunities under each load
11 scenario after 2021 until after 2030.

12 **Base Case Load PV Costs**


13 Figure 5-5 summarizes the PV cost changes for the Minimum GHG Portfolio Options selected for the Base
14 Case load scenario. Cost changes are shown in percentage terms relative to the Default Diesel Portfolio.
15 Under the Base Case load scenario, over the 20-year planning period each Minimum GHG Portfolio Option
16 PV cost is 12-33% higher (i.e., more costly) than the Default Diesel Option¹⁶⁰.

¹⁵⁹ Capacity contributions: Marsh Lake Storage (1 MW); 21 MW Wind (5 MW for DRUPS); 15 MW Wood Biomass (15 MW); WTE (2.2 MW). No capacity benefits contributed by Gladstone Diversion or 10.5 MW Wind resource options.

¹⁶⁰ Figure 5-5 shows in contrast very low percent change in PV costs for these option when assessed at the much higher Scenario A and B loads. This simply reflects the small scale of these options relative to these higher loads (i.e., most of the energy requirements in the pre-2021 period are met with diesel generation under these Portfolio Options and the higher load scenarios).

1
 2

Figure 5-5: Change in PV Costs (%) Minimum GHG Portfolio Options Compared to Default Diesel Portfolio – Base Case Load



3

4 Figure 5-5 shows that the least cost Minimum GHG Portfolio Option for Base Case load is Option Base
 5 Case #1 with Marsh Lake Storage & Gladstone Diversion (12% higher PV costs than diesel) – in contrast,
 6 if Gladstone Diversion is not available, Option Base Case #3 (Marsh Lake Storage and 2.2 MW WTE) is
 7 less costly than Option Base Case#2 (Marsh Lake Storage and 10.5 MW Wind) – Option Base Case #3
 8 PV cost increase over diesel is 33% while Option BC#2 PV cost increase over diesel is 14%.

9 Table 5-12 provides the comparative percent diesel displacement for each option during the key 2015-
 10 2019 period (when mine loads are still present), as well as PV costs for each option over the 20-year
 11 planning period.

Table 5-12: Present Value Costs (2010\$million) - Minimum GHG Portfolio Options & Diesel Base Case Load

	Default Diesel Portfolio	Option BC #1 - Marsh Lake Storage & Gladstone Diversion	Option BC #2 - Marsh Lake Storage, & 10.5 MW Wind	Option BC #3 - Marsh Lake Storage and 2.2 MW WTE
Diesel Displaced 2015-2019¹		62%/95-97% ²	95%	68%
Present Value Costs (2010\$million)				
No DSM/SSE				
Base Case	164.6	135.5	157.8	154.5
Scenario A	283.5	248.0	263.2	266.2
Scenario B	363.7	326.3	342.2	343.4
With DSM/SSE				
Base Case	98.1	110.0	130.0	111.9
Scenario A	204.0	203.5	216.3	206.6
Scenario B	281.2	278.4	289.9	280.5

1. Percentage GHG emissions displaced with assumed DSM/SSE.

2. Diesel displacement average is 62% for 2015-19; increases to between 95-97% in 2018-19 when Gladstone is in service.

Based on the objective for these Portfolio Options (i.e., to minimize GHG emissions), Option Base Case #2 (Marsh Lake Storage & 10.5 MW Wind) provides the greatest GHG displacement under Base Case load; however, it also requires much higher PV costs than either of the other two options. If Gladstone Diversion can be developed by 2018, after 2017 Option Base Case #1 provides much greater diesel displacement than Option Base Case #3 and also has lower PV costs.

In more detail, Table 5-12 and Figure 5-5 highlight the extent to which the Base Case load scenario would affect resource option selection. Overall, with the Base Case load it would be cost effective to develop Marsh Lake Storage plus only one of the other identified resource options. Reviewing the Base Case load scenario over the planning period with DSM/SSE, the following are indicated:

- **Option Base Case #1 (Marsh Lake and Gladstone)** – This option provides the largest potential future reduction in grid GHG emissions (up to 97% reduction after Gladstone Diversion is in-service) at the lowest overall PV cost compared to the other GHG reduction portfolio options. However, this overall reduction in GHG emissions and overall PV cost depends on the ability to secure Gladstone by 2018 (until 2018 there would be only 62% reduction in diesel requirement).
- **Option Base Case #2 costs (Marsh Lake and 10.5 MW Wind)** – This option has a higher overall PV cost compared to the other options but provides much higher grid GHG reductions that

1 can be feasibly secured by 2015 under these other options and with a lower level of regulatory
2 risk than applies to Option BC #1. Development of the 10.5 MW Wind resource option would
3 provide a first stage of a potentially much larger future wind project at the selected site.

4 • **Option Base Case #3 costs (Marsh Lake and 2.2 MW WTE)** – This option provides the
5 lowest GHG reduction benefit (at only 68% during the 2015-19 period). It has a 14% lower PV
6 cost than Option BC #2, but provides almost 30% less reduction of GHG emissions.

7 Without DSM/SSE, all options are less costly than the Default Diesel (Option BC #1 remains the lowest
8 cost option and Option BC #2 remains the highest cost option).

9 **Scenario A and B Load PV Costs**

10 Figure 5-6 summarizes the PV cost changes for the Minimum GHG Portfolio Options selected for Scenario
11 A and B loads with DSM/SSE. Percentage cost changes are shown relative to the Default Diesel Portfolio.

12 In summary, with DSM/SSE over the 20-year planning period each portfolio option PV cost under
13 Scenario A load is 16% or more higher (i.e., more costly) than the Default Diesel Option (7% or more
14 under Scenario B load), except for Option A/B #1 (Marsh & 15 MW Wood Biomass) with no Wood
15 Biomass O&M (operation) after 2020 – compared to the Default Diesel Option, the PV cost for this
16 exception is 8% more costly under Scenario A and 4% less costly under Scenario B. The exception
17 highlights the relevance of the Wood Biomass option's flexibility (relative to the other Min GHG options)
18 to shut down when mine loads are assumed to shut down.

19 Ignoring the shut down option for Wood Biomass, Figure 5-6 shows that the least cost Minimum GHG
20 Portfolio Option for Scenario A and B load is Option A/B#3 with Marsh Lake Storage & Gladstone
21 Diversion plus 21 MW Wind (18% higher PV costs than diesel under Scenario A). In contrast, if Gladstone
22 Diversion is not available, Option A/B #2 (Marsh Lake Storage, 21 MW Wind and 2.2 MW MTE) is less
23 costly than sustained operation of Option A/B #1 (Marsh Lake Storage and 15 MW Wood Biomass) – at
24 Scenario A load, the portfolio Option A/B#2 PV cost increase over the Default Diesel portfolio is 20%
25 while Option A/B#1 PV cost increase over diesel is 45%¹⁶¹.

¹⁶¹ Sensitivity tests with mine loads extended to 2025 indicate some PV cost savings relative to diesel for all options other than Option A/B #1 without provision for shut down (at Scenario B loads and/or extension of mine loads to 2030, even Option A/B#1 shows PV cost savings relative to diesel).

Figure 5-6: Change in PV Costs (%) Minimum GHG Portfolio Options Compared to Default Diesel Portfolio – Scenario A and B Loads




Table 5-13 provides the comparative percent diesel displacement for each option with DSM/SSE during the key 2015-2019 period (when mine loads are still present), as well as PV costs for each option over the 20-year planning period.

Based on the objective for these Portfolio Options (i.e., to minimize GHG emissions), Option A/B #1 (Marsh Lake Storage with 15 MW Wood Biomass) provides the greatest GHG displacement under Scenario A or B load; it also requires much higher PV costs than either of the other three options unless it is shut down after 2020. However, if the Wood Biomass plant is shut down after 2020 when mine loads are assumed to be shut down, Option A/B #1 with DSM/SSE has a lower PV cost than any of the other Min GHG Portfolio Options examined (under Scenario B loads, this PV cost is also slightly lower than the Default Diesel PV cost). Selection of Option A/B #1 would mean that development of the additional resource options (e.g., wind, Gladstone Diversion or 2.2 MW WTE) would not be cost effective. Option A/B #1 has less regulatory risk than options involving Gladstone Diversion (Options A/B #3 and #4).

If Option A/B #1 is not selected, the key issue affecting option selection becomes the availability of the Gladstone Diversion Project.

- If the Gladstone Diversion can be developed by 2018 along with Marsh Lake Storage by 2015, after 2017 Option A/B #4 (also includes 21 MW Wind and 2.2 MW WTE) provides diesel

1 displacement similar to Option A/B #1 (over 90% for Scenario A and 70% for Scenario B) at PV
 2 costs 22% higher than the Default Diesel portfolio under Scenario A load and 9% under Scenario
 3 B.

- 4 • If the Gladstone Diversion cannot be developed by 2018, the only remaining option is Option A/B
 5 #2, with Marsh Lake Storage, 21 MW Wind and 2.2 MW WTE, that provides 70% diesel
 6 displacement under Scenario A during 2015-2019 at 17% higher PV cost than the Default Diesel
 7 portfolio.

8 **Table 5-13: Present Value Costs (2010\$million) - Minimum GHG Portfolio Options**
 9 **& Diesel Scenario A and B Loads**

	Default Diesel Portfolio	Option A/B #1 - Marsh Lake Storage and 15 MW Biomass	Option A/B #1 - Marsh Lake Storage and 15 MW Biomass (No O&M after 2020)	Option A/B #2 - Marsh Lake Storage, 21 MW Wind, 2.2 MW WTE	Option A/B #3 - Marsh Lake Storage & Gladstone Div., 21 MW Wind	Option A/B #4 - Marsh Lake Storage & Gladstone Div., 21 MW Wind, 2.2 MW WTE
Diesel Displaced 2015-2019¹						
Scenario A		90%	90%	72%	70%/84% ²	81%/92% ²
Scenario B		70%	70%	50%	49%/61% ²	58%/70% ²
Present Value Costs (2010\$million)						
No DSM/SSE						
Scenario A	283.5	289.9	277.1	257.9	250.5	257.5
Scenario B	363.7	349.3	337.6	329.3	323.8	327.2
With DSM/SSE						
Scenario A	204.0	284.1	220.4	238.0	236.0	248.8
Scenario B	281.2	332.6	269.0	302.3	300.4	307.2

1. Percentage GHG emissions displaced with assumed DSM/SSE.

2. Lower diesel displacement is average for 2015-19, assuming Gladstone in-service by 2018.

The higher displacement value occurs when Gladstone in service (assumed 2018-19).

10

11 If no DSM/SSE is assumed all options have lower PV values compared to the default diesel scenario with
 12 the exception of Option A/B#1 under Scenario A loads which has a PV cost \$6.4 million higher than
 13 diesel. Cost savings compared to diesel under Scenario A loads with no DSM/SSE range from \$33 million
 14 (Option A/B #3 under Scenario A loads) to \$6.4 million (for Option A/B#1 if Wood Biomass plant shut
 15 down after 2020). Cost savings compared to diesel under Scenario B loads with no DSM/SSE range from
 16 \$40 million (Option A/B#3) to \$14.4 million (Option A/B#1). The PV cost information suggests that
 17 without DSM/SSE (which implies higher diesel displacement opportunities), Option A/B #1 would be less
 18 competitive with diesel than the other Min GHG Portfolio options examined.

1 **5.3 YUKON GREENHOUSE GAS EMISSIONS IMPACT**


2 As reviewed in Section 4.3, overall Yukon Energy GHG emissions from grid power generation under the
3 Default Diesel Portfolio vary a great deal depending on the load forecast.

- 4 • During 2012-2014 with assumed DSM/SSE starting from 2013, emissions range from 8,100
5 tonnes/year to 9,700 tonne/year under the Base Case, 57,800 tonnes/year under Scenario A, and
6 71,700 tonnes/year under Scenario B.
- 7 • During the 2015-2020 period with DSM/SSE, Base Case grid GHG emissions are small relative to
8 Scenario A and B emissions (i.e., peak annual emissions during this period under the Base Case
9 load (12,400 tonnes/year) are only 20% of those under Scenario A load (62,400 tonnes/year)
10 and 12% of peak emissions under Scenario B load (101,300 tonnes/year)).
- 11 • As a result of off-grid mine developments, grid-related power generation emissions are expected
12 to constitute a declining share of overall Yukon power generation emissions (e.g., during the
13 2015-2020 period), peak Scenario A (with DSM/SSE) emissions from grid power generation under
14 the Default Diesel Portfolio could fall from approximately 26% to about 7% of off-grid mine-site
15 power generation emissions (which are projected potentially at 232,400 tonnes/year by 2015 and
16 749,800 tonnes/year by 2020).

17 Under all non-diesel resource options there is assumed to be no ability to displace diesel and GHG
18 emissions until 2015 (as no potential resource options are assumed to be in service prior to that date).

19 Figure 5-7 provides for each Minimum GHG Emissions Portfolio Option with Base Case load the percent of
20 grid GHGs emissions displaced each year relative to the Default Diesel Portfolio. Option BC #2 (Marsh
21 Lake Storage and 10.5 MW Wind) achieves the highest GHG emissions reduction (over 90%) on a
22 consistent basis after 2014. Option BC #1 (Marsh Lake Storage and Gladstone Diversion) achieves high
23 levels of GHG emission reduction after 2017 (when Gladstone Diversion is assumed to come into service).
24 All options achieve high percent GHG emissions reduction after 2020 simply due to the very low levels of
25 diesel generation forecast during this period (no diesel is forecast in 2021 or 2022).

Figure 5-7: Grid GHG Reductions: Minimum GHG Emissions Portfolio Options
– Base Case Load 2012-2030




GHG's (tonnes/yr) Displaced- Base Case with DSM/SSE

	2012	2015	2020	2025	2030
Total Grid GHGs available to be displaced	8,067	10,635	6,079	1,255	5,273
Option BC #1 - Total GHG's Displaced	-	3,737	6,079	1,255	5,273
Option BC #2- Total GHG's Displaced	-	10,185	6,079	1,255	5,273
Option BC #3 - Total GHG's Displaced	-	7,324	5,273	1,255	4,794

Figure 5-8 provides for each Minimum GHG Emissions Portfolio Option with Scenario A load the percent of grid GHGs displaced each year relative to the Default Diesel Portfolio. Option A/B #1 (Marsh Lake Storage and 15 MW Biomass) achieves the highest GHG emissions reduction (90%) on a relatively consistent basis after 2014. Prior to 2017 this option achieves reductions 25% higher than Option A/B #2 and Option A/B #4 and 50% higher than Option A/B #3. After 2017, both Option A/B #3 and Option A/B #4 are assumed to have Gladstone Diversion in service and achieve higher overall levels of GHG emissions reductions. All options achieve high percent GHG emissions reduction after 2020 simply due to the very low levels of diesel generation forecast during this period (no diesel is forecast in 2021 or 2022).

Figure 5-8: Grid GHG Reductions: Minimum GHG Emissions Portfolio Options – Scenario A Load 2012-2030




GHG's (tonnes/yr) Displaced - Scenario A with DSM/SSE

	2012	2015	2020	2025	2030
Total Grid GHG's available to be displaced	8,067	59,420	50,776	1,255	5,273
Option A/B #1 - Total GHG's Displaced	-	53,683	48,225	1,255	5,273
Option A/B #2 - Total GHG's Displaced	-	42,801	40,009	1,255	5,273
Option A/B #3 - Total GHG's Displaced	-	35,498	46,103	1,255	5,273
Option A/B #4 - Total GHG's Displaced	-	42,801	50,776	1,255	5,273

Figure 5-9 provides for each Minimum GHG Emissions Portfolio Option with Scenario B load the percent of grid GHG emissions displaced each year relative to the Default Diesel Portfolio. The comparison of GHG reduction benefits for each Portfolio Option is very similar with the analysis for Scenario A load, with Option A/B #1 achieving highest GHG emissions reductions over the period from 2015 to 2020 and Option A/B #3 and Option A/B #4 seeing materially increased GHG emissions reductions after Gladstone Diversion comes into service after 2017. The key difference under Scenario B loads is the overall lower percentage reductions in GHG emissions reduction compared to Scenario A loads (i.e., under Scenario A Option A/B #1 reduces up to 90% of GHG emissions starting in 2015 while under Scenario B loads Option A/B#1 only reduces 70% of GHG emissions over the same period. As with other load scenarios, all options achieve high percent GHG emissions reduction after 2020 simply due to the very low levels of diesel generation forecast during this period (no diesel is forecast in 2021 or 2022).

Figure 5-9: Grid GHG Reductions: Minimum GHG Emissions Portfolio Options – Scenario B Load 2012-2030




GHG's (tonnes/yr) Displaced - Scenario B with DSM/SSE

	2012	2015	2020	2025	2030
Total Grid GHGs available to be displaced	8,067	99,999	84,414	1,255	5,273
Option A/B #1- Total GHG's Displaced	-	69,115	48,046	1,255	5,273
Option A/B #2- Total GHG's Displaced	-	49,852	48,046	1,255	5,273
Option A/B #3- Total GHG's Displaced	-	40,196	58,591	1,255	5,273
Option A/B #4- Total GHG's Displaced	-	49,852	66,874	1,255	5,273

As noted in Section 2 and Section 4.3, off-grid mines (at a distance that makes interconnection infeasible) are projected to develop using either on site diesel or LNG, increasing overall Yukon GHG emissions by an additional 232,400 tonnes in 2015 and 749,814 tonnes by 2020. Under each of the Minimum GHG Emissions Portfolio Options for the grid, these off-grid GHG emissions are not affected. Figure 5-10 below shows the percentage of total GHG reductions for each of the Minimum GHG Portfolio Options relative to total Yukon GHG emissions due to power generation (both grid and off-grid generation). This illustrates that on grid GHG reductions achieved through any Minimum GHG portfolio option (assuming DSM/SSE) only displace a small percentage of total Yukon GHG emissions related to power generation. After on grid mines are forecast to leave the grid in 2020 the percentage GHG reductions from Minimum GHG portfolio options declines and is minimal thereafter compared to total Yukon GHG emissions from the power generation sector (excludes GHG emissions from any new pipeline compressor stations).

1 **Figure 5-10: GHG Reductions – Minimum GHG Portfolio Options (Scenario A with DSM/SSE)**
2 **Relative to Total Yukon GHGs for Power Generation (grid and off-grid)**



3 **GHG's (tonnes/yr) Displaced - Scenario A with DSM/SSE**

	2012	2015	2020	2025	2030
Total Grid GHG's available to be displaced	8,067	59,420	50,776	1,255	5,273
Option A/B #1 - Total GHG's Displaced	-	53,683	48,225	1,255	5,273
Option A/B #2 - Total GHG's Displaced	-	42,801	40,009	1,255	5,273
Option A/B #3 - Total GHG's Displaced	-	35,498	46,103	1,255	5,273
Option A/B #4 - Total GHG's Displaced	-	42,801	50,776	1,255	5,273
Off Grid - Industrial	25,900	232,400	749,814	646,214	609,814
Off Grid - Utility Non-Industrial	14,013	14,247	14,644	15,053	15,473
Total Potential Yukon GHG Emissions (Power Generation Sector)	47,981	306,067	815,235	662,522	630,560

4

5 The Yukon Government Energy Strategy has identified as a priority increasing the renewable energy
6 supply by 20% by the year 2020 to reduce fossil fuel use and related greenhouse gas emissions. While
7 Minimum GHG Portfolio options are successful in displacing the majority of grid GHG emission over the
8 resource planning period, grid GHG emissions are expected after the next few years to represent a
9 declining share of overall Yukon GHG emissions from power generation. Further, aside from Wood
10 Biomass, none of the proposed Minimum GHG Portfolio options is at a scale that fully addresses grid
11 generation requirements over the period from 2014 to 2020, nor can any of the non-biomass Minimum
12 GHG Portfolio options feasibly be considered for much larger potential grid loads.

13 The above analysis, however, addresses only near-term options that typically can be committed prior to
14 2015 (and includes consideration of Gladstone as a longer term option that can be committed by 2016 to

1 address potential loads by 2018). In contrast to these near term grid-focused options, development of
2 larger greenfield hydro sites for an expanded grid may provide for a source of clean energy supply that
3 could more effectively reduce GHG emissions from power generation in Yukon over the longer-term.

4 **5.4 LONG-TERM DEVELOPMENT CONSIDERATIONS**

5 Section 5.1.2 and Table 5-1 identified long-term renewable hydro resource options for the Minimum GHG
6 Emissions Portfolio that are potentially available to start construction before 2021 and that could provide
7 low costs as well as low GHG emissions¹⁶².

8 In summary, 17 medium to large greenfield hydro options offer both low GHG emissions and low costs
9 per kW.h, i.e., each option has costs below 15 cents/kW.h Full Utilization LCOE, including provision for
10 transmission connection to the current grid – nine of the options have costs below 10 cents/kW.h.
11 Additional small hydro sites have costs below 25 cents/kW.h. These potential hydro projects constitute
12 defined long-term legacy resource opportunities. Once developed, such opportunities could provide
13 sustaining benefits for many decades, in the same way that past hydro developments at Whitehorse,
14 Aishihik and Mayo benefit Yukoners today (as well as provided benefits in earlier decades when initially
15 developed).

16 The challenge is to assess what basis, if any, exists today to consider long-term planning during the next
17 five years (and if so, what specific planning) regarding such potential hydro resource developments.

- 18 • Given a list of screened hydro resource options, the key initial issue is to confirm potential ability
19 within the next 10 years to connect loads that could fully utilize the specific resource options over
20 a reasonable sustained number of years.
- 21 • As discussed in Section 3.2.2 and Table 3-1, medium to large scale greenfield hydro generation
22 options with full utilization LCOEs of 5 to 11 cents/kW.h can be characterized with high
23 affordability (i.e., low cost)¹⁶³; however, generation from these medium to large scale greenfield
24 hydro projects would clearly not come close to being fully utilized under current forecast grid
25 loads; and, until reasonable levels of utilization are forecast over 20-30 or more years, such
26 capital intensive resource options would in reality remain highly unaffordable in Yukon.

¹⁶² Geothermal and clean coal resource options were noted as potential future options to provide both low costs and low GHG emissions but, for the reasons noted, for planning purposes today were not considered to be available to start construction before 2021.

¹⁶³ Such cost estimates remain subject to considerable risk and uncertainty until more detailed site and feasibility study work provides updated assessments for specific short-listed options, including updated review of all relevant potential regulatory and approval considerations.

1 In order to meet these challenges, specific hydro developments that could come into service by 2021 will
2 need to be identified that would justify expansion of the grid to connect one or more new longer-term
3 (i.e., 20-30 year) off-grid mine developments. As noted, such expansion and extension of grid mine loads
4 would help to reduce Forecast LCOE and adverse annual cost impact for all feasible renewable resource
5 options.

6 The following example outlines the potential cost impacts of a new hydro project that is fully utilized with
7 LCOE cost of 10 cents/ kW.h (2010\$) that comes into service in 2019:

- 8 • Assuming 2% inflation, the initial year cost in 2019 would approximate 19.7 cents/kW.h¹⁶⁴; this
9 cost would then decline in subsequent years (so that, in \$2010\$, the levelized lifetime cost over
10 65 years would be 10 cents per kW.h).
- 11 • Marsh and Gladstone hydro costs projected to 2019 would be lower (around 14 cents per kW.h
12 with inflation and assuming the in-service dates in the earlier analysis as well as Scenario A loads
13 with DSM/SSE and mine loads still connected).
 - 14 ○ Under the same assumptions, other near-term renewable resource options examined
15 earlier would have average costs in 2019 as follows:
 - 16 ▪ Wind and WTE – costs at 26-27 cents/ kW.h; these costs tend to decline as
17 capital cost depreciates.
 - 18 ▪ Wood biomass (15 MW at \$104/tonne feedstock cost) - costs at 33 cents/kW.h;
19 these costs are affected by ongoing cost inflation for the feedstock and staffing
20 components.
 - 21 ○ Diesel fuel and O&M costs (for a new unit) in 2019 are assumed in earlier projections at
22 31.1 cents/kW.h. In contrast, as reviewed in the following section (Section 6), LNG-based
23 power supply could be approaching 17 cents/kW.h by 2019 and would likely be subject
24 to ongoing escalation at rates faster than inflation.
- 25 • The key to overall impacts on rates and GHG emissions is the extent to which the new hydro
26 resource, in addition to being of relatively low cost compared to available supply options, is also
27 sufficiently large in scale to have a material impact in displacing non-renewable power
28 generation.

¹⁶⁴ Initial year costs per kW.h for a fully utilized hydro project will be approximately 65% higher than the levelized cost, assuming a 65 year economic life (all costs in the same constant dollars, i.e., no inflation impacts considered). By way of example, a hydro project with a levelized cost (2010\$) of 10.0 cents/kW.h over 65 years would have a year one operation cost of 16.5 cents/ kW.h (2010\$). This cost would decline in future years (even in “real” term, net of inflation) as the rate base is depreciated.

1 Potential off-grid load opportunities during the period to 2021 and related potential hydro development
2 prospects are reviewed below, followed by an overview of related planning required during the next five
3 years to protect the opportunity to start construction on any of these hydro projects prior to 2021.

4 **Potential Off-Grid Load & Hydro Resource Opportunities**

5 Figure 2-4 indicated potential off-grid mine developments before 2021 that could provide challenging
6 opportunities for major new legacy generation projects to displace up to 1,000 to 1,500 GW.h/year of
7 ongoing fossil fuel equivalent generation. This potential scale of new power use, with opportunities for 20
8 to 30 or more year life, provides justification for assessing appropriate near-term planning activities to
9 protect Yukon ability to start construction prior to 2021 of new renewable greenfield hydro projects.

10 A first step in such planning is to identify specific off-grid diesel displacement opportunities that would
11 need to be pursued in order to secure the type of sufficiently large and sustained load to justify
12 development of new lower cost legacy assets. The following is an overview of relevant load opportunities
13 (see Figures 1-2 and 3-1 for maps showing the location of these projects):

- 14 • Fossil fuel generation for off-grid mines by 2021 could potentially exceed 1,500 GW.h/year and
15 remain above 1,300 GW.h/year through 2045 in the event that three of these multi-decade off-
16 grid mines are developed (i.e., the Casino Property west of the CSTP grid (940 GW.h/year), the
17 Selwyn project to the east of the WAF grid close to the border with NWT (147 GW.h/year), and
18 the Northern Dancer project located near the Alaska Highway east of Teslin (250 GW.h/year)).
- 19 • If the Alaska Highway Pipeline project proceeds, the six gas compressors for this project could
20 potentially add up to 1,470 GW.h/year of additional equivalent energy requirement
21 opportunities¹⁶⁵ by approximately 2020/21 that would also be sustained over 25 years in the
22 event that GHG emission concerns support electrification initiatives.
- 23 • In each instance, development of the above loads will apparently be contingent on factors
24 external to Yukon Energy's ability to supply grid generation. In addition, none of these
25 developments appear to be contingent on access to grid power in Yukon (i.e., each mine project
26 currently plans to rely on either diesel or LNG fuel for onsite power generation and the Alaska

¹⁶⁵ This estimate includes only an initial four compressor stations (assumes approximately 245 GWh/year per compressor station for an approximate 33 MW equivalent peak load per station. Six compressor stations are planned in Yukon. An additional heater station with a similar load is also planned.

- 1 Highway Pipeline project compressor stations is currently planned to rely on natural gas¹⁶⁶). To
2 the extent that these “off-grid” energy loads materialize in Yukon before 2021, overall energy
3 sector GHG increases would dwarf any gains otherwise from on grid DSM or other measures.
- 4 Table 5-14 provides a summary of major potential off-grid industrial load opportunities over the resource
5 planning period and the potential greenfield hydro development opportunities that such loads may
6 support to provide new low cost legacy assets over the long-term.

¹⁶⁶ Based on YEC discussion with the proponent, grid power will be sought where feasible only for compressor station service (1.5 MW for first station, and 300 kW for four other stations, and 350 kW for the sixth station) and the gas heater station (150 MW). Potential co-generation of up to 5 MW might occur at each compressor station for sale to YEC. Discussion is possible on YEC providing grid power to compressor stations - and this could be done on a station-by-station basis.

1

Table 5-14: Yukon Industrial Load Opportunities and Potential Hydro Sites

POTENTIAL INDUSTRIAL LOAD OPPORTUNITIES		POTENTIAL HYDRO DEVELOPMENT OPPORTUNITIES				
<p><i>Developing low cost/low emission hydro options depends on connecting new grid loads that could adequately utilize the resource for 20-30 years</i></p> <p>DEVELOP SOUTHERN LAKES GRID CONNECTIONS</p> <p><i>Timing for development of these projects in the next decade will depend on whether or not Gladstone is developed, future grid loads and definition of distinct hydro project opportunities</i></p> <p>DEVELOP GRID TO EAST OF ROSS RIVER</p> <p>SELWYN (147 GWh/yr) & (MACTUNG) 30+ year load in service 2014/15 - A medium hydro project in the 17-30 MW range (129 to 181 GWh/yr) to the east of the northern WAF grid could match all or most of the Selwyn load</p> <p>DEVELOP SOUTHERN GRID TO EAST NEAR ALASKA HWY</p> <p>NORTHERN DANCER (200-300 GWh/yr) - a 30 year load in service in 2017 to east of Teslin. A medium hydro project to serve this load could provide basis for extension of grid in south-east portion of Yukon</p> <p>PIPELINE COMPRESSOR - Marsh Lake - 245 GWh/yr load per compressor in service in 2020/21 - Could provide anchor load for a medium hydro project in 266-280 GWh range (25 year load)</p> <p>PIPELINE COMPRESSOR - Alaska Hwy - 245/GWh/yr load per compressor in service in 2020/21; May provide an opportunity to develop sites and transmission in east Yukon such as Liard Canyon (25 year load); Liard Canyon may also support development of NORTHERN DANCER</p> <p>DEVELOP CENTRAL & WESTERN YUKON GRID</p> <p>CASINO MINE (940.8 GWh/yr) 20-30 year load in service in 2018-19 - A large hydro project in the 69-100 MW range (450-700 GWh/yr) reasonably near the CSTP grid could match a large share of the Casino Load</p>		Installed Capacity (MW)	Annual Energy (GWh)	Levelized Cost (c/kWh)		
				Small Hydro Projects (<10MW)		
		<i>Southern Lakes Projects</i>				
		20-23 c/kWh	Moon Lake	5.8	32.9	19.9
			Tutshi River	4.2	30.3	23.1
			Tutshi (Windy Arm)	5.9	39.4	21.6
			Pine Creek at Atlin	3.5 to 8	23-52	N/A
		Medium Hydro Projects (<60 MW)				
		< 10 c/kWh	Hoole Canyon with Storage	40.4	275	8.6
			Slate Rapids	41.6	266	9.8
			Finlayson	17	128.9	9.4
		10-15 c/kWh	Ross Canyon	30	181	14.1
		Medium Hydro Projects (<60 MW)				
		10 to 15 c/kWh	False Canyon	58	370	14.5
			Middle Canyon*	38	200	20.0
			Upper Canyon*	25.2	176.6	19.8
			Two Mile Canyon	53.1	280	12.9
		8.7 10 to 15 c/kWh	Combined Slate Rapids & Hoole	50.1	351.1	10.7
			Granite Canyon Small	60	400	8.7
			Slate Rapids	22.3	156.3	14.6
		Large Hydro Project (> 60 MW)				
		10-15 c/kWh	Liard Canyon	93.5	659	12.2
		*Transmission costs to connect to existng grid are 54-55% of leveled cost.				
		Large Hydro Project (> 60 MW)				
		< 10 c/kWh	Granite Canyon Low	80	600	7.3
			Fraser Falls Low	100	700	9.9
			Granite Canyon High	254	1783	4.9
			Fraser Falls High	300	2100	6.3
			Combined Slate Rapids & Hoole	69.4	459	9.6
		10 to 15 c/kWh	Detour Canyon	65	435	12.6
			Detour Canyon w storage	100	585	11.5

2

1 Each of the major potential load opportunities is outlined below:

- 2 • **Casino Mine Opportunity (940 GW.h/yr for 20-30 years):** A large hydro project in the 69
3 to 100 MW range (450 to 700 GW.h/year) reasonably near the CSTP grid could match a large
4 share of the Casino load, i.e., Fraser Falls Low (700 GW.h/year), Granite Canyon Low (600
5 GW.h/year) and Slate Rapids/Hoole (459 GW.h/year) would be potential candidates. Other large
6 hydro options are either too large (Fraser Falls High at over 2,000 GW.h/year or Granite Canyon
7 High at over 1,780 GW.h/year), or too far away (Detour Canyon or Liard Canyon). Development
8 of such hydro opportunities would require further development of the central and western grid.
9 To be competitive, hydro options would need to be less costly than LNG/natural gas generation.

- 10 • **Northern Dancer Mine Opportunity (200-300 GW.h/yr for 30 years):** This load creates
11 opportunities for eastern Yukon medium-scale hydro sites in the Watson Lake area (e.g., False
12 Canyon at 370 GW.h/year) and could provide the basis for developing the southern grid east
13 along the Alaska Highway. In the event that the Alaska Highway Pipeline is also developed,
14 development of larger hydro sites in this area (e.g., Liard Canyon at 659 GW.h/year) could be
15 considered. Levelized cost estimates for hydro sites in this area (e.g., Middle Canyon, Liard
16 Canyon, False Canyon and Upper Canyon) currently reflect extensive transmission costs to
17 connect to the current grid; emergence of major local loads such as those noted here would
18 reduce the estimated cost of delivered power from these hydro sites. To be competitive in
19 serving these load opportunities, hydro options would need to be less costly than LNG/natural
20 gas generation.

- 21 • **Selwyn Mine Opportunity (147 GW.h/yr for 30+ years):** Based on location and expected
22 mine load scale, a medium hydro project in the 17 to 30 MW range (129 to 181 GW.h/year) to
23 the east of the northern WAF grid could match all or most of the Selwyn load and contribute to
24 supply of the MacTung load (i.e., Finlayson River (129 GW.h/year), Slate Rapids (small) (266
25 GW.h/year), or Ross Canyon (181 GW.h/year) would be potential candidates). There are a
26 number of other slightly larger potential medium hydro options in the 266 to 280 GW.h/year
27 range that might merit consideration for the overall grid (particularly if Casino is connected),
28 including Hoole Canyon with Storage (275 GW.h/year) or Slate Rapids (266 GW.h/year). Other
29 medium hydro options in this target location might also merit consideration under some load
30 combinations, even though they are much larger (Combined Slate Rapids [with powerhouse at

1 foot of dam] and Hoole at 361 GW.h/year would likely be preferred today over False Canyon at
2 370 GW.h/year, given location proximity to the grid plus current level of information¹⁶⁷).

- 3 • **Pipeline Compressor Loads:** Based on the location for such stations along the Alaska Highway
4 plus expected load, a range of hydro projects sizes located as close as possible to the southern
5 WAF grid could be considered.

- 6 ○ For example, supply to only one compressor station near Whitehorse¹⁶⁸ would suggest
7 medium sized hydro projects in the 266-280 GW.h/year range (Hoole Canyon with
8 Storage or Slate Rapids); consideration of two compressor loads would indicate the need
9 for a larger project such as Combined Slate Rapids/Hoole scheme (459 GW.h/year) or
10 Granite Canyon Small (400 GW.h/year). If two or more compressor options are looked at
11 in combination with Casino loads, consideration might be given to bigger scale options.

- 12 ○ Pipeline development along the Alaska Highway would also create opportunities to
13 develop hydro sites and related transmission in the east end of the Yukon route (e.g.,
14 False Canyon, Middle Canyon, Upper Canyon or Liard Canyon to supply power to one or
15 two compressor stations)¹⁶⁹.

16 In summary, an unprecedented range of potential hydro development opportunities exist during the next
17 five to ten years in association with major new mine and other loads currently under active consideration
18 in southern Yukon.

19 In order to provide legacy benefits for Yukoners, new hydro site opportunities will likely need to be
20 assessed in light of overall grid development considerations and the ability to ensure that a reasonable
21 portion of new hydro supply is available to serve growing non-industrial power needs on the Yukon grid.

22 Even under favourable circumstances, it would likely not be feasible to pursue all of these opportunities
23 during the 2011 Resource Plan planning period, i.e., some of the new industrial loads (if they emerge)
24 will likely need to rely on a continuing basis upon fossil fuels (e.g., LNG or natural gas, if not diesel fuel)
25 for onsite power generation. There are also likely to be practical constraints (e.g., planning costs and
26 timing, overall financial risks and costs) regarding how many such hydro projects could be developed
27 concurrently during the planning period.

¹⁶⁷ Due to its distance from the grid, False Canyon's levelized cost to connect to the grid is estimated at 14.5 cents/kW.h.

¹⁶⁸ For example, preliminary locations indicated for a station northeast of Mendenhall Landing and a station near Jake's Corner.

¹⁶⁹ For example, preliminary locations indicated for a station about 68 km west of Watson Lake on the highway (south of Allegretto Lake); another station is indicated to be located southeast of Helen Lake (about 140 km west of Allegretto Lake along the highway, and east of Teslin).

1 Connection to the grid of any of the new off-grid mine loads identified in Table 5-14 is unlikely to occur
2 until after the mine is developed and operating with reliance on fossil fuel power generation (i.e., new
3 hydro site development will likely require the security of established long-term mine loads), and, to be
4 feasible, new hydro power will need to clearly provide sustained costs savings for such mine customers to
5 justify connection to the grid. In contrast, connection to the grid of any new pipeline compressor loads
6 noted above may need to be planned to occur on or before the pipeline comes into service.

7 **Required Planning Activities**

8 If Yukon Energy is to protect opportunities to start construction before 2021 on any of the above hydro
9 projects, considerable planning will be required through the next five years (2011-2015). Figure 5-11
10 provides an overview of the potential timing and key planning stages required to develop greenfield
11 hydro project options during this period, highlighting actions needed during 2011-2015 to protect the
12 ability to bring any such hydro option into service within the next decade and identifying currently
13 identified potential off-grid load and development opportunities that are likely to affect hydro option
14 planning.

15 The above off-grid load opportunities are each clearly subject to project-specific negotiation and joint
16 planning with each developer to determine if mutually acceptable arrangements and opportunities can be
17 concluded, including appropriate risk management and mitigation measures to protect all other grid-
18 served customers from unacceptable rate-related risks.

19 Focusing on the above short listed hydro sites, the following overview of staging of activities provides an
20 initial indication of near-term planning potentially needed to protect the opportunity for such
21 developments to proceed before 2021 in response to the identified longer-term load opportunities:

- 22 • **Step 1 - Prefeasibility activities (1-2 years):** A range of activities is required to be
23 completed by fall 2012, including further summer field investigations, to confirm technical and
24 other feasibility, ranking and staging for potential development by 2021. These activities include
25 (for selected sites as noted above and all related transmission requirements - it is assumed that
26 these activities are coordinated for all sites as one set of prefeasibility planning work focused on
27 selecting and developing one or more legacy hydro projects within the planning period):
 - 28 a) An initial pre-planning stage review during winter 2011/12 in time to allow 2012 field
29 season activities, to confirm planning and priorities. The following suggested activities
30 would be reviewed and modified as required during this pre-planning review.
 - 31 b) Complete coordinated engineering pre-feasibility work as required for this package of
32 sites to provide adequate baseline information on water flows and site concept options
33 (including transmission access and/or upgrades to existing transmission) to enable

- 1 confirmation of technical feasibility and planning schedules for specific preferred
2 concepts, including potential staging where relevant (and assessment of cumulative
3 impacts as regards storage and water regime controls for multiple potential projects on
4 the same river system).
- 5 c) Complete any baseline environmental studies deemed critical to project feasibility
6 assessment.
- 7 d) Initiate consultations and joint reviews with First Nations having traditional territories
8 impacted by any of these short listed projects (as regards possible partnership
9 arrangements), and also initiate discussions and joint planning with potential off-grid
10 mine customers (as regards potential PPA or other arrangements) and with government
11 (as regards possible funding support), to confirm potential understandings as required to
12 justify proceeding to the next stage of feasibility and environmental assessment work for
13 specific sites.
- 14 e) Plan the above activities to allow an interim review in winter of 2011/12 to confirm the
15 short listed sites and ongoing work plans for the next summer; in the event that
16 information surfaces to suggest that any of the short-listed sites are not likely to be
17 feasible for development by 2021, identify other hydro site options to be examined
18 instead.
- 19 f) At the end of Step 1, a work plan (including budget arrangements) will be provided for
20 Step 2 activities for remaining short listed sites that are justified for proceeding to the
21 next planning stage. This work plan will set out risk management and staging for each
22 remaining short listed site, including funding requirements. Based on Mayo B experience,
23 cost requirements for Step 2 activities for any specific site could approximate 2% of final
24 project capital costs (e.g., \$10 million order-of-magnitude for a medium hydro site and
25 \$20 million order-of-magnitude for a large hydro site). Specific cost estimates relevant to
26 the short listed hydro sites would be developed as part of the Stage 1 work.
- 27 • **Step 2 - Feasibility and Environmental/Socio-Economic Assessment and other related**
28 **activities (2 years for a site):** After completion of Step 1, at least two years is likely to be
29 needed (with another two field seasons) to complete feasibility engineering, environmental and
30 socio-economic assessment studies, consultations and agreements as needed for each site
31 selected (including related transmission requirements) to proceed with the required regulatory
32 filings. This work may potentially involve multiple sites, each with different timelines for
33 investigations, agreements and YESAA-related filings.

1 The following would be carried out for each selected site (includes related transmission
2 requirements):

3 a) In addition to engineering and regulatory work for each selected site, related
4 arrangements required for power purchase agreements, First Nation or other
5 partnerships, and overall project financing/funding would also proceed as required to
6 enable the project to proceed to Stage 3 below.

7 b) The approach to be undertaken for design, procurement, construction and owner
8 administration would be finalized along with any specific risk management measures
9 required for the project to proceed.

10 c) At the end of Step 2 for any specific hydro site, a project proposal would be filed with
11 YESAB and any funding submissions and/or agreements (PPAs, partnerships, etc) that
12 may be required for that hydro site development would also be finalized. A workplan
13 (including budget arrangements) would be provided (and summarized in the YESAB
14 filing) for Step 3 and subsequent activities for that hydro site's development.

- 15 • **Step 3 – YESAB Screening and Related Permitting & other pre-construction activities**
16 **(2-3 years):** Given the scale of these developments, 2 to 3 years may be required to conclude
17 Step 3 regulatory review and permitting activities plus other pre-construction activities:

18 a) Regulatory reviews will include YESAB, YWB, a Part 3 review by YUB, and DFO.

19 b) Other pre-construction activities will include final design and tendering, any special
20 procurement arrangements required for long lead equipment, all related contracting for
21 owner administration, and financing and any agreement arrangements required for the
22 project to proceed.

23 Step 3 would conclude with a decision by YEC's Board of Directors to proceed with construction.


- 24 • **Step 4 – Project Construction (minimum 2 years):** Based on the above, the earliest that a
25 new greenfield hydro project might come into service would be later 2018. This timing could be
26 affected by a wide range of factors.

27 The Minimum GHG emissions portfolio options available in the near-term are capital intensive and
28 inflexible, resulting in higher present value costs than diesel generation during the planning period unless
29 major new additional loads are connected to the grid. Without a clear longer-term planning approach as
30 discussed above, the near-term options could (as with the Default Diesel Portfolio) provide pressure to
31 constrain costs in order to constrain rate increase impacts on ratepayers throughout Yukon, with resulting
32 pressures to constrain connection of new loads to the grid as well as key ongoing capital spending on the
33 longer-term resource planning options identified above. Without connection of new loads to some form of

- 1 grid development, opportunities to develop new legacy renewable generation resources are likely to
- 2 remain very limited.

1

Figure 5-11: Overview of Planning Activities for Greenfield Hydro Supply Option Development - 2011-2021



2

1 **5.5 CONCLUSIONS**

2 Renewable Minimum GHG emissions portfolio options for the near term (i.e., committed by 2015) focus
3 on displacing grid GHG emissions over the planning period, and do not address the expected major
4 increase in GHG emissions from new off-grid industrial power generation prior to 2020. Beyond the
5 near-term grid-focused options, development of larger greenfield hydro sites for an expanded grid could
6 potentially provide for a source of clean energy supply that would more effectively reduce GHG
7 emissions from power generation in Yukon over the longer-term.

8 In the near-term, the relative attractiveness of Minimum GHG emissions portfolio resource options is
9 affected by the range of potential load forecasts (after consideration of potential DSM/SSE) and
10 uncertainties related to the ability to secure the resource option within the near-term, i.e., ability to
11 commit by 2015 and be in-service by 2017 at the latest. Summary conclusions from Section 5 regarding
12 near-term Minimum GHG emissions portfolio resource options include:

- 13 • Although hydro options are the least cost renewable resource options identified, new hydro
14 resource options are very limited in the near-term due to the time needed to plan, licence and
15 develop new greenfield sites. These options also face uncertainty and risk regarding regulatory
16 permitting time requirements and outcomes:
 - 17 ○ Marsh Lake Storage could potentially be in-service by 2015; due to its small scale and
18 low costs, it has been assumed in each resource portfolio.
 - 19 ○ Gladstone Diversion could potentially be in-service by late 2017; however, this project is
20 subject to considerable regulatory uncertainty as to securing local First Nation support
21 and necessary regulatory approvals.
 - 22 ○ If and when approved, Gladstone Diversion is large enough in scale in combination with
23 Marsh Lake Storage to displace up to 97% of pre-2020 Base Case load grid GHG annual
24 emissions from diesel - however, its economic impacts relative to diesel are sensitive to
25 grid load risks (i.e., in combination with Marsh Lake, Gladstone Diversion has a lower PV
26 cost than Default Diesel over the planning period only if grid loads exceed Scenario A
27 levels with DSM/SSE).
- 28 • Under Scenario A or B grid loads, all portfolio options have higher PV costs over the planning
29 period than diesel under the Scenario A loads with DSM/SSE, and prior to 2021 provide only
30 limited potential to reduce annual cost impacts relative to diesel (after 2020 and assumed mine
31 closure, these options have materially higher annual cost impacts than diesel).

- 1 ○ **Option A/B #1 (Marsh Lake Storage with 15 MW Wood Biomass - No O&M**
2 **after 2020)** – The Wood Biomass plant allows this portfolio to provide high GHG
3 emissions displacement on the grid (e.g., 90% displacement under Scenario A with
4 DSM/SSE prior to 2021) while also providing the flexibility to shut the plant down (i.e.,
5 cut off O&M costs) when grid loads are assumed to drop after 2020 due to assumed
6 mine closures. If and when loads drop significantly, there is no benefit in assuming
7 continued operation of the wood biomass plant.
 - 8 ▪ This portfolio has a lower PV cost over the planning period than any other
9 Minimum GHG emissions portfolio option under Scenario A and B load cases
10 with DSM/SSE; however, it has higher PV costs than the other options under
11 Scenario A and B loads with no DSM/SSE, with extension of mine loads under
12 Scenario A with DSM/SSE to 2025 or 2030 and with extension of mine loads
13 under Scenario B with DSM/SSE to 2030.
 - 14 ▪ The PV comparative cost advantages for the Wood Biomass plant derive from its
15 flexibility to shut down when appropriate and thereby save O&M costs; when
16 operating during the period prior to 2020, this portfolio option typically has
17 annual cost impacts that are equal to or higher than the other Minimum GHG
18 portfolio options.
- 19 ○ **Option A/B#3 (Marsh Lake Storage with Gladstone Diversion and 21 MW**
20 **Wind)** – This portfolio provides high GHG emissions displacement on the grid (e.g.,
21 84% displacement with Gladstone Diversion under Scenario A with DSM/SSE prior to
22 2020); this option also has a lower PV cost during the planning period than Option A/B
23 #4 (same portfolio with 2.2 MW WTE added) under all Scenario A and B load cases
24 examined with and without DSM/SSE. [Accordingly, Option A/B #4 is not considered
25 further in Sections 6 or 7].
 - 26 ▪ Prior to mine closures (regardless as to sensitivity tests for mine load extensions
27 to 2025 or 2030) and under Scenario A loads with or without DSM/SSE, this
28 portfolio option has lower annual cost impacts than any of the other Minimum
29 GHG Emissions Portfolio options (under Scenario B loads, Option A/B #4 has
30 slightly lower annual cost impacts prior to mine closures, but higher annual cost
31 impacts after mine closures).
- 32 ○ If Gladstone Diversion is not available, **Option A/B #2 (Marsh Lake Storage with**
33 **21 MW Wind and 2.2 MW WTE)** – Excluding wood biomass or Gladstone Diversion,
34 this portfolio provides the maximum feasible near-term GHG emissions displacement on
35 the grid (e.g., 72% displacement prior to 2021 under Scenario A with DSM/SSE);

1 compared to Option A/B #3, it has a slightly higher PV cost over the planning period,
2 slightly higher annual cost impacts prior to the assumed mine closures, and slightly
3 lower annual cost impacts after the assumed mine closure.

4 Looking at the longer term (i.e., start project construction before 2021), new hydro resource
5 developments currently offer the best opportunities to reduce costs as well as GHG emissions – subject
6 to adequate long-term loads being connected to the grid to sustain such new hydro developments.

7 During the next five to ten years an unprecedented range of potential hydro development opportunities
8 exist in association with major new mine and other loads currently under active consideration off the
9 grid in southern Yukon. In particular, several major new long-term load opportunities (e.g., 20 to 30 or
10 more years) located in different areas are relevant during this planning period (e.g., the Selwyn,
11 Northern Dancer and Casino mine projects and the Alaska Highway Pipeline project). Opportunities to
12 start construction before 2021 on any of these hydro developments will require major hydro-resource
13 planning activities through the next five years (2011-2015) as well as confirmation that one or more of
14 these new loads is in fact being developed. Connection to the grid of any of these major new loads is
15 also likely to be dependent on new hydro generation being less costly than LNG or natural gas fuelled
16 generation that is expected to be available to these off-grid loads (see Section 6).

1 **6.0 LNG TRANSITION PORTFOLIO OPTIONS**

2 **6.1 DEFINING THE PORTFOLIO OPTIONS**

3 LNG Transition Portfolio options aim to use LNG or natural gas to displace diesel fuel as the on grid and
4 off-grid default electricity supply source throughout most Yukon areas while facilitating concurrent
5 development of longer-term legacy grid renewable resource options as soon as is appropriate.

6 LNG options in the 2011 Resource Plan are focused primarily on displacing near-term diesel grid loads
7 under Scenarios A or B along with off-grid diesel generation at Watson Lake and industrial mine sites.
8 Potential LNG opportunities to displace grid diesel under Base Case loads are also examined. In each
9 instance, the LNG option is directed at immediate and material near-term reductions in costs and GHG
10 emissions in Yukon relative to the Default Diesel Portfolio. Overall, LNG and/or natural gas is examined as
11 a new fuel option that retains flexibility for power generation as well as diversity for energy use
12 opportunities (e.g., for electricity generation locations and for end use sectors such as transportation)
13 similar to that provided today by diesel fuel.

14 LNG Transition portfolio options also encourage planning for, and pursuit of, cost effective and
15 environmentally responsible hydro, wind or other renewable legacy resource development over the
16 longer-term planning horizon to secure sustained and larger reductions in costs and GHG emissions as
17 soon as economically feasible in the future.

18 **6.1.1 Background on Current LNG Supply Opportunities for Yukon**

19 The key features potentially offered by liquefied natural gas (LNG) as a near-term option include flexibility
20 similar to diesel generation, but with reduced costs and reduced GHG emissions.

21 Near-term supply of LNG in Yukon is facilitated by abundant natural gas supplies in BC and Alberta being
22 used to develop LNG liquefier facilities that can supply cost competitive LNG by truck to Yukon. Longer-
23 term development of natural gas supplies in Yukon (e.g., through the Alaska Highway Pipeline Project,

1 Eagle Plains gas development, or any other source¹⁷⁰) would allow direct access to natural gas in some
2 Yukon locations plus development of local Yukon LNG liquefier facilities to supply LNG to other locations.

3 New opportunities to consider LNG as a major fuel option to displace oil products in Yukon reflect recent
4 natural gas supply softness that has driven gas prices to historically low levels relative to oil prices, and
5 new shale gas supplies that are expected to contribute to ongoing low prices¹⁷¹. Uncertainty is noted
6 about environmental issues regarding shale gas development as well as the timing of development of
7 new shale gas reserves¹⁷².

8 LNG opportunities today in Yukon are confirmed and facilitated by major new LNG facility development
9 currently planned in BC and Alberta (including facilities for LNG sale into higher priced Asian export
10 markets). The business case for such new LNG export confirms the expectation that it is profitable on a
11 sustained basis (i.e., for the economic life of the new LNG facilities) to buy inexpensive gas in BC/Alberta
12 indexed to lower 48 pipeline gas cost (Henry Hub and NYMEX), and cover the capital and operating costs
13 for liquefying the gas to LNG and transporting the LNG to market by ship for sale at world export market
14 prices. The expected sales margin (i.e., the difference in prices for gas between the North American and
15 Asian markets) for such LNG exports confirms an expectation that natural gas prices in North America will
16 remain significantly depressed relative to oil prices.

¹⁷⁰ Proponents of the Alaska Pipeline Project provided a project schedule in September 2011 meetings in Alaska indicating first gas in 2020 and full gas in 2021, assuming an October 2012 FERC filing and project sanction before mid-2015. Based on YEC discussion with the proponent, if the pipeline does its own compression the Yukon power requirement will be for station service (1.5 MW for first station near Beaver Creek, and 300-350 kW for the other five stations). Potential co-generation of up to 5 MW might occur at each compressor station for sale to YEC. Discussion is possible on YEC providing grid power to compressor stations - and this could be done on a station-by-station basis. There is currently no timing or plan for development of Eagle Plains, but potential options may emerge tied to development of a major new load such as the Casino mine.

¹⁷¹ BC Hydro's January 2011 Integrated Resource Plan natural gas price forecast notes that supply softness has driven gas prices to historically low levels; shale gas is expected to contribute to ongoing low prices although uncertainty about environmental issues and timing of development of new shale gas reserves means BC Hydro is considering different scenarios with relatively large price ranges. BC Hydro's High gas price scenario assumes prices around \$10/MMBTU escalating to about \$13/MMBTU by 2027 (\$2010); assumes shale gas either cannot be developed due to environmental concerns or is very slow to develop. BC Hydro's Low gas price scenario assumes prices (\$2010) around \$4/MMBTU escalating to about \$5.5/MMBTU by 2027. BC Hydro's Mid gas price scenario assumes prices (\$2010) start around \$4/MMBTU and escalate to about \$7/MMBTU by about 2020 and about \$7.5/MMBTU by 2027.

¹⁷² Production from shale gas may involve hydraulic fracturing - this practice has come under international scrutiny due to environmental and health safety concerns and has been suspended or banned in some countries. Such concerns relate to uncertainty regarding the extent to which this process pollutes fresh water zones, contaminates surface or near-surface water supplies, impacts rock shelf causing seismic events or leads to surface subsidence.

1 The following are noted in regard to the development of specific LNG facilities in BC and Alberta:

- 2 • The BC Government has noted (see The BC Jobs Plan¹⁷³) that LNG exports have the potential to
3 replace coal-fired generation in China and other energy hungry countries, and that the BC
4 Government is committed to working with LNG export proponents to bring at least one LNG
5 pipeline and terminal online by 2015 and have three in operation by 2020, assuming all
6 environmental and permitting applications are granted.
- 7 • Kitimat LNG has announced plans to develop an LNG facility at Kitimat for operation in 2015 with
8 an initial capacity of 32,000 m³/day LNG (about 5 million metric tonnes per year) for marine
9 transport by ship, i.e. by comparison, total future Yukon peak daily demand at all potential on
10 and off-grid locations after 2018 (including the Casino mine project) would be less than 10% of
11 this capacity. The project is being developed by Encana Corp. (30%), Apache Corp of Houston
12 (40%) and EOG Resources Ltd. of Houston (30%), with an estimated project cost of \$3.5 billion
13 for the first train and \$1.5 billion for an equivalent scale second train. Required federal and
14 provincial approvals have been secured, including an NEB 20-year export licence granted in
15 October, and a land lease has been arranged with the Haisla First Nation. Construction is planned
16 to begin in the first quarter of 2012 and first LNG exports in 2015.
- 17 • BC LNG Export Co-operative has applied to the NEB for a 20 year export license for 1.8 million
18 tonne LNG/year produced on a grounded barge at Kitimat starting in 2013¹⁷⁴. The project is a
19 50/50 partnership between the LNG Partners (Houston) and the Haisla Nation Douglas Channel
20 LNG Limited Partnership, and has arrangements to take advantage of unused capacity on the
21 existing Pacific Northern Gas Pipeline.
- 22 • Royal Dutch Shell Plc is reported¹⁷⁵ to have filed for regulatory approval to build a small-scale
23 LNG plant to produce 0.3 megatonnes per year at its existing Jumping Pound gas plant about 30
24 km west of Calgary. Work is expected to be completed by 2013. The project is to promote LNG
25 as a transportation fuel (especially for trucks) in Alberta and eventually in BC.
- 26 • The Fort Nelson area in BC is recognised to have major gas reserves. A potential LNG facility
27 developed today in this area could, for example, receive pipeline quality natural gas at high
28 pressure from the send-out pipeline from the Spectra Energy's 250-MMcfd natural gas plant near

¹⁷³ The BC Jobs Plan (http://www.bcjobsplan.ca/wp-content/uploads/2011/09/CSH_BCJobsPlan_web.pdf).

¹⁷⁴ The facility will be built on a barge off site and then floated to Kitimat. The front end engineering and design (FEED) contract was awarded in September 2011 for expected completion in January 2012.

¹⁷⁵ See Financial Post (Sept 7, 2011) <http://business.financialpost.com/2011/09/07/shell-plans-alberta-lng-plant-to-supply-truck-fuel>.

1 Fort Nelson¹⁷⁶, pre-treat the gas to remove unwanted components (primarily water and CO₂) and
2 then refrigerate the clean gas to LNG for transportation and supply. Gas supplies for LNG
3 production in the Fort Nelson area are expected to be indexed to lower 48 pipeline gas cost
4 (Henry Hub and NYMEX), which are expected to be at least \$3 MMBTU lower than Kitimat-based
5 LNG production that will be indexed to world LNG prices.

6 **6.1.2 Background on LNG Opportunities in Yukon**

7 Section 3.2 identified LNG as one of the potential near-term thermal resource options to be considered,
8 noting (as with other near-term thermal options) that current pre-feasibility information on supply options
9 is preliminary, particularly as regards to feedstock supply development or arrangements for use in Yukon.
10 Trucked-in LNG is assumed as the supply source of Yukon LNG until local natural gas supplies are
11 available – for initial costing, an LNG supply is assumed to be secured from facilities developed at Kitimat
12 or at Fort Nelson, B.C., with the LNG then shipped to Whitehorse (for YEC grid power use), Watson Lake
13 (for YECL utility generation) and potentially off-grid mine sites (for generation at each mine site).
14 Finalizing the preferred sourcing of LNG fuel supply is a significant issue to be addressed if this option is
15 pursued.

16 During the Charrette it was noted that due to the isolated nature of the Yukon grid and the potential for
17 large industrial loads to come on and off the system, resource planning must ensure supply options are
18 sufficiently flexible and robust to address the markedly different load scenarios that may exist on the grid
19 from time to time. Changes in load may adversely impact grid diesel generation requirements and related
20 GHG emissions, as well as the cost effectiveness and rate impacts for any capital intensive supply options
21 pursued in the near-term. Similarly, new capital intensive renewable resource developments may create
22 new increases in supply that need to be accommodated concurrently with changes in load. Finally, as
23 reviewed in Section 2.4, flexible and reliable resource options with low capital costs will continue to play a
24 key role on the Yukon hydro grid to address winter peak capacity as well as emergency reserve
25 requirements, seasonal load/hydro supply fluctuations, and annual hydro supply fluctuations.

26 Subject to securing LNG supply (see Section 6.1.1), LNG/Natural Gas has been recognized as a reliable
27 resource option for power generation that offers many of the same attributes as diesel generation, but at

¹⁷⁶ This plant is located about 75 km northeast of Fort Nelson, is the largest sour gas processing plant in North America and is the only facility currently processing Horn River gas. Spectra Energy has firm commitments of 760 MMcf from seven producers operating in the Horn River basin for gathering and processing capacity, and may expand gathering and processing in this area to accommodate as much as 830 MMcf of incremental gas from Horn River producers.

1 lower overall cost than diesel and (at simple cycle operation) with 30 to 34% lower overall GHG
2 emissions than diesel. Key related features include:

- 3 • Natural gas power plants are intended to be operated only when required and (subject to
4 securing fuel supply) can be relatively easily integrated into the Yukon system as conversion or
5 replacement of the current diesel generation plant. New equipment and retrofit of existing diesel
6 engines can provide a range of options for LNG/natural gas use, including options for dual fuel
7 (diesel/natural gas) operation.
- 8 • Natural gas power plants require relatively low capital costs, with options for scalable generation
9 over a wide range of sizes, as well as options for combined cycle and cogeneration (with
10 associated higher capital costs).
- 11 • Natural gas power plant operating costs are mostly composed of fuel cost that is subject to
12 ongoing inflation and market price uncertainty.
- 13 • Natural gas power units can be permitted, purchased and installed within reasonably short time
14 periods (i.e., usually well under 2 years) , as well as be reliably operated over an economic life of
15 20-25 years; units can also be located at load centres (minimize transmission requirements).

16 A gas co-generation facility installed in Whitehorse would also provide an opportunity for waste heat
17 application, in much the same way (and for the same markets) as reviewed in Section 5 regarding the 2.2
18 MW WTE resource option.

19 As previously noted in Section 2.3, the developer of Casino mine has identified LNG as the preferred
20 energy source to reduce costs related to this mine's future large-scale baseload power generation,¹⁷⁷ and
21 the developer of the Northern Dancer mine¹⁷⁸ is also considering LNG as a source of supply. Use of LNG
22 in a combined cycle power facility at the Casino project is expected to reduce costs at this mine site to
23 within an 11-15 cents/kW.h range (versus the 30+ cents/kW.h range for diesel). Under this approach,
24 Casino (as well as Northern Dancer) would also retain flexibility to further reduce operating costs by
25 converting the power generation to natural gas when/if local natural gas becomes available (e.g., power
26 generation costs estimated for Casino at <10 cents/kW.h with access to Alaska Highway Pipeline Project
27 natural gas).

¹⁷⁷ The Casino mine developers (Western Copper and Gold) currently plan to secure LNG by truck and/or ship/truck from Kitimat or to secure LNG from a new LNG facility at Fort Nelson, BC. The Casino mine is expected to have a large scale power requirement starting in 2018 of 130 MW and 940 GW.h/year potentially sustained over several decades.

¹⁷⁸ With a power requirement of 30-35 MW (200 to 300 GW.h/year) for up to 30 years, potentially starting by 2017.

1 Based on the preliminary analysis to date, Yukon Energy has participated with Western Copper and Gold
2 retaining Braemar Wavespec and Berger ABAM to evaluate the LNG & Natural Gas supply chain in lieu of
3 diesel for electrical power generation fuel at the proposed Casino mine and process facility starting in
4 2018, and at Yukon Energy facilities at Whitehorse and YECL facilities at Watson Lake potentially starting
5 in 2014 as well as at other off-grid existing and potential mine facilities (Wolverine, Selwyn and Coffee
6 Creek were assumed for this purpose). The Braemar Wavespec studies are considering potential LNG
7 supply chain options to secure LNG by trucking from either the proposed Kitimat LNG new facility at
8 Kitimat BC or from pipeline gas at Fort Nelson BC¹⁷⁹ to reduce costs and emissions in Yukon by using LNG
9 to displace diesel generation. Preliminary conclusions from studies to date include the following (see
10 Figure 6-1):

- 11 • Under assumed diesel and natural gas price conditions (e.g., LNG cost at \$9/MMBTU at Kitimat,
12 natural gas cost at \$6/MMBTU at Fort Nelson, and diesel fuel cost at \$26/MMBTU or 89 cents/
13 litre), an LNG supply chain from either Kitimat or Fort Nelson is more cost effective than diesel
14 for the various Yukon power generation use options and locations examined:
 - 15 ○ At lower supply level requirements typical of utility diesel power generation requirements
16 (e.g., Scenario A or B for the grid diesel generation in 2015 as per the 2011 Resource
17 Plan plus YECL Watson Lake diesel generation), including full consideration of grid diesel
18 load fluctuations due to hydro generation seasonal and annual water flow fluctuations¹⁸⁰,
19 LNG supply from Kitimat LNG tends to have better project economics for delivered LNG
20 unit cost compared to Fort Nelson LNG (reflecting lower capital cost requirements for the
21 option using an assumed Kitimat LNG export facility [rather than a new Yukon-dedicated
22 LNG liquefaction facility at Fort Nelson] offsetting longer truck distances and higher gas-
23 equivalent prices).
 - 24 ▪ Estimated unit power generation costs¹⁸¹ with simple cycle generation range
25 from 17.0 cents/KW.h (Scenario A) to 15.7 cents/kW.h (Scenario B) with supply

¹⁷⁹ Braemar Wavespec also examined options for the Casino plant shipping LNG from Kitimat LNG by barge or small carrier to Skagway, Alaska and from there by truck to the mine site – based on review of this alternative, the studies related to other potential Yukon uses by Yukon Energy or others focused on the trucking option from either Kitimat LNG or from a new LNG facility using pipeline gas at Fort Nelson BC. An Eagle Plains option was also examined simply to assess potential future cost savings at such time as natural gas production is available from Eagle Plains.

¹⁸⁰ To accommodate these factors, LNG supply chain peak capability for grid power use assumed in the Braemar Wavespec study at 25 MW for Scenario A and 30 MW for Scenario B. At the assumed grid loads (84.9 GW.h/year for grid Scenario A and 142.9 GW.h/year for grid Scenario B), average annual grid use assumed at only 39% of capacity for Scenario A and 54% for Scenario B.


¹⁸¹ All costs estimated assuming 8% annual cost of capital and 20 year economic life – annual costs reflect the assumed fuel prices and operation at current day dollars. The capital portion of these costs assumes 20 years of operation at the assumed loads.

- 1 from Kitimat - in contrast, with supply from Fort Nelson the estimated unit costs
2 range from 17.9 cents/kW.h (Scenario A) to 15.8 cents/ kW,h (Scenario B).
- 3 ▪ Estimated unit power generation cost with combined cycle generation is lower
4 than with simple cycle generation (15.6 to 14.2 cents/kW.h with Kitimat supply
5 and 16.4 to 14.2 cents per kW.h with Fort Nelson supply).
 - 6 ▪ Capital cost requirements are lower with the Kitimat supply option than with the
7 Fort Nelson supply option (e.g., for the assumed Scenario A grid plus Watson
8 Lake diesel displacement loads and combined cycle power generation), estimated
9 capital costs for the LNG supply chain (excluding costs for new generating units)
10 range from approximately \$13 million for the Kitimat option to approximately \$37
11 million for the Fort Nelson option (of which liquefaction facility costs approximate
12 \$26 million).
 - 13 ○ LNG supply chain economics improve if additional LNG deliveries for off-grid mine power
14 generation are assumed (beyond YEC and YECL loads assumed above). With the higher
15 and more steady state load profile, Fort Nelson with new LNG facility costs dedicated
16 only to Yukon loads has lower estimated delivered costs than LNG purchases from a
17 Kitimat LNG export facility.
 - 18 ▪ This conclusion applies with or without the Casino mine (although higher loads
19 with the Casino mine tend to result in lower overall average supply chain costs
20 per MMBTU than cases without the Casino mine load, notwithstanding impacts
21 on increasing overall average trucking distance).
 - 22 ▪ Combined cycle generation continues to offer cost savings compared to simple
23 cycle generation.
 - 24 • Overall, increases in the LNG supply chain load requirement act to maintain and improve supply
25 chain economics; delivered unit cost with all users examined is lower than would occur with only
26 utility grid and Watson Lake loads. With appropriate planning, supply chain additions are very
27 scalable through addition of added trucking units and liquefaction trains. There are a number of
28 processes for small and mid-sized LNG liquefiers from a number of vendors who produce turnkey
29 solutions.
 - 30 • The cost of gas from Fort Nelson will likely sustain a lower unit cost than reliance on an LNG
31 export facility at Kitimat overtime; trucking distances are also considerably reduced under the
32 Fort Nelson supply option compared with the Kitimat supply option. Although not reviewed in
33 detail, an Eagle Plains commercial gas supply would enable reduced LNG trucking distances on
34 average for the Yukon loads considered.

- 1 • Due to the long LNG supply chain for all concepts, project risks need to be identified and
2 examined for the real world challenges to provide the level of reliability and sustainability of
3 energy supply needed.
- 4 • Potential optimization measures to address grid load seasonality and other annual hydro
5 fluctuations include increased LNG receiving terminal storage, retaining some existing diesel
6 generation capacity for peaking in lieu of requiring LNG supply chain design capacity for such
7 peaking, and use of LNG fuelled power generation during non-winter months in low water years
8 in order to facilitate hydro storage for winter use. Waste heat recovery from power generation
9 provides an excellent source of free heat to displace fuel gas otherwise needed for LNG
10 vaporization at receiving facilities (this is the largest operating expense for this operation),
11 assuming a backup source of heat is available during short periods that waste heat is not
12 available.
- 13 • Construction of the supply chain (including a liquefaction facility for the Fort Nelson option) will
14 take at least 2 years including detailed engineering, permitting, construction, start-up and
15 commissioning (excluding new power generators) - this schedule is based on having a site
16 selected for the LNG supply, budgetary approval and no major problems with permitting.
- 17 ○ When considering risks that natural gas supplies will emerge in Yukon and displace the
18 need to transport LNG from BC, it is noted that the proposed LNG liquefaction equipment
19 is modular, and relocation to another location (i.e., in Yukon) can be performed at
20 relatively low cost compared to the cost of a new facility (and assuming production
21 downtime during the relocation is also considered).
- 22 ○ Assuming that off-grid mine loads continue to develop, emergence of Yukon gas sources
23 will likely not displace the ongoing need for LNG liquefaction in Yukon to supply off-grid
24 power generation as well as transport uses.

25 Subject to successful planning for power uses of LNG in Yukon, consideration will be given by Yukon
26 Energy for a wider range of potential LNG end use sectors in Yukon (including transportation and heating
27 sectors). The LNG supply chain examined by Braemar Wavespec assumes LNG-fuelled trucks.

1 **Figure 6-1: Comparison of LNG Supply Options (Kitimat & Fort Nelson) with Diesel**



2

Weighted Av. \$/kW.h	Simple Cycle ^{1, 3, 4}			Combined Cycle ^{2, 3, 4}		
	Kitimat LNG ⁵	Fort Nelson LNG ⁵	Diesel Generation ⁵	Kitimat LNG ⁵	Fort Nelson LNG ⁵	Diesel Generation ⁵
Grid/ Watson Lake	\$0.170	\$0.179	\$0.251	\$0.156	\$0.164	\$0.251
Add Mines	\$0.151	\$0.143	\$0.251	\$0.134	\$0.127	\$0.251
Add Casino	\$0.147	\$0.136	\$0.251	\$0.130	\$0.121	\$0.251

- Notes: 1 LNG generating with new units at \$1,500 per kW capital cost (40% energy efficiency).
 Diesel generating with existing simple cycle units (no capital cost - same efficiency as LNG simple cycle unit).
 2 LNG generating with new units at \$1,830 per kW capital costs (50% energy efficiency).
 Diesel generating with existing simple cycle units (no capital cost - same efficiency as LNG simple cycle unit).
 3 Power generation for all units assumes 1.5 cents/kW.h O&M cost.
 4 Annual costs of capital assume 8% discount rate and economic life of 20 years.
 5 LNG cost at \$9/ MMBTU; Natural gas cost at \$6/ MMBTU; Diesel fuel cost at \$26/ MMBTU (89 cents/litre).

3

1 **6.1.3 Assumed Near-term Resource Options**

2 As part of the 2011 Resource Plan, LNG is initially examined as a near-term and flexible supply option
3 that could potentially be available as early as late 2014¹⁸². For simplicity, LNG/natural gas options are
4 assumed to be developed at a scale sufficient to displace all grid diesel generation forecast under each
5 load scenario. Cost estimates for LNG conversion, trucking and related costs are assumed based on the
6 Braemar Wavespec studies to date and are considered adequate for initial pre-feasibility assessments. If
7 the LNG option is to be pursued for near-term development for power generation in Yukon by late 2014,
8 immediate further feasibility work will be required to determine the optimum way to secure the LNG, the
9 required timing and all related costs.

10 In developing LNG Transition Portfolio Options, the following development approach was considered as
11 regards Scenario A or B grid loads:

- 12 • A 20-30 MW LNG/natural gas power plant at Whitehorse (scale considered necessary to displace
13 diesel under near-term loads with mines connected to the grid as assumed in Scenario A and B
14 load forecasts).
 - 15 ○ Natural gas power plant scales required to displace all diesel generation requirements are
16 assumed for this initial analysis at 22 MW for Scenario A loads and 30 MW for Scenario B
17 loads¹⁸³. Base Case load plant scales are assumed at 4 MW with DSM/SSE and 8 MW with
18 no DSM/SSE.
 - 19 ○ Given these assumed plant scales, average annual plant capacity factors in 2015 with
20 DSM/SSE approximate 44% for Scenario A and 54% for Scenario B. (Without DSM/SSE,
21 these capacity factors are 51% with Scenario A and 60% with Scenario B).

¹⁸² The schedule required to secure the necessary LNG facilities and arrangements in time for potential in-service in late 2014 assumes that long-lead equipment orders would likely need to be placed in spring 2013 with actual construction/installation starting in spring/summer 2014. Pre-feasibility and feasibility assessments, along with related arrangements for securing LNG supplies, would accordingly likely need to be completed well before the end of 2012.

¹⁸³ Under either Scenario A or B, LNG thermal plant operation to displace diesel generation will typically be concentrated almost entirely in seven months (November to May); however, as noted in the Attachment E2 review of the diesel option, off-peak and summer generation is expected to be used during extreme low water years in order to meet non-hydro generation requirements with the available non-hydro plant capacity. Under an extreme low water year (average of load years) for the 2015 load forecast with DSM/SSE the annual capacity factor would approximate 79% for Scenario A (with 22 MW) and 81% for Scenario B (with 30 MW) - these capacity factors would increase to 87% with the 2015 grid load for each scenario without DSM/SSE.

- 1 ○ Simple cycle new gas turbines or internal combustion units are assumed with a 20 year
2 life and a capital cost (\$2010) of \$1.5 million per MW; natural gas heat rate for the
3 simple cycle units is assumed at 8.204 Mcf per MW.h (40% efficiency).
- 4 ○ Combined cycle units are also examined with a 20 year life and a capital cost (\$2010) of
5 \$1.83 million per MW; natural gas heat rate for the combined cycle units is assumed at
6 6.562 Mcf per MW.h (50% efficiency).
- 7 ○ Non-fuel O&M costs for power generation assumed at \$15 per MW.h plus fixed cost of
8 \$2.5 per kW.
- 9 ○ Natural gas prices (\$2010) are assumed at \$5.5 per MMBTU in 2015, increasing to \$6.60
10 per MMBTU in 2020 and \$7.45 per MMBTU in 2030¹⁸⁴. After inflation assumed at 2% per
11 year, these natural gas prices equal \$6.07 per MMBTU in 2015, \$8.05 per MMBTU in
12 2020 and \$11.07 per MMBTU in 2030¹⁸⁵.
- 13 • The LNG resource option assessment assumes that YEC would source supply from a third party
14 through a contract arrangement (rather than itself develop an LNG processing plant or provide
15 the relevant trucking and other LNG-related supply chain facilities). For initial assessments (prior
16 to more detailed review and optimization studies), the following options for LNG supply and
17 trucking to Whitehorse are assumed (natural gas purchase costs are added to these based on the
18 assumed gas requirements per MWh and assumed natural gas prices)¹⁸⁶.
- 19 ○ **Fort Nelson area supply option:** A new small scale LNG plant established only for YEC
20 loads with incremental costs for LNG conversion, trucking and related costs (e.g., truck

¹⁸⁴ BC Hydro's January 2011 Integrated Resource Plan natural gas price forecast notes that supply softness has driven gas prices to historically low levels; shale gas is expected to contribute to ongoing low prices although uncertainty about environmental issues and timing of development of new shale gas reserves means BC Hydro is considering different scenarios with relatively large price ranges. BC Hydro's High gas price scenario assumes prices around \$10/MMBTU escalating to about \$13/MMBTU by 2027 (\$2010); assumes shale gas either cannot be developed due to environmental concerns or is very slow to develop. BC Hydro's Low gas price scenario assumes prices (\$2010) around \$4/MMBTU escalating to about \$5.5/MMBTU by 2027. BC Hydro's Mid gas price scenario assumes prices (\$2010) start around \$4/MMBTU and escalate to about \$7/MMBTU by about 2020 and about \$7.5/MMBTU by 2027.

¹⁸⁵ See NRC natural gas price forecast showing strong agreement among industry experts regarding expected gradual rise in Henry Hub wholesale price over the period 2010 through 2015, 2020 and 2025 (forecast price [US\$/MMBTU] with inflation approximates \$6/MMBTU by 2015, approximately \$8/MMBTU by 2020 and just under \$10/MMBTU by 2025); (<http://www.nrcan.gc.ca/eneene/sources/natnat/shocou-eng.php>).

¹⁸⁶ Cost estimates based on the Braemar Wavespec studies to date adjusted to reflect the assumed peak scale of installed gas generation facilities (22 MW for Scenario A and 30 MW for Scenario B) and excluding gas generating plant (which is assumed to be owned and operated by YEC) and excluding costs related to LNG supply to Watson Lake or any other Yukon users, i.e., all costs assigned to YEC fuel supply. Capital related costs for LNG supply are treated as per the Braemar Wavespec study (annual charges based on 8% assumed cost of capital and economic life of 20 years).

- 1 loading/unloading facilities, storage at the power plant, a vaporizer or re-gasifier and all
2 related indirect) assumed as follows (\$2010):
- 3 ▪ Simple cycle generation: 6.4 cents/ kW.h for Scenario A and 5.8 cents/ kW.h for
4 Scenario B (capital costs of approximately \$37 to \$47 million (2010\$) reflect 60%
5 of these Scenario A costs and 53% of these Scenario B costs; liquefaction facility
6 capital costs approximate \$28 to \$36 million of these capital costs).
 - 7 ▪ Combined cycle generation: 5.2 cents per kW.h Scenario A and 4.7 cents per
8 kW.h for Scenario B (capital costs of approximately \$30 to \$38 million (2010\$)
9 reflect 60% of these Scenario A costs and 53% of these Scenario B costs;
10 liquefaction facility capital costs approximate \$22 to \$29 million of these capital
11 costs).
 - 12 ○ **Kitimat area supply option:** supply from an LNG export facility with incremental costs
13 for LNG purchase, trucking and related costs (e.g., truck loading/unloading facilities,
14 storage at the power plant, a vaporizer or re-gasifier and all related indirect) assumed as
15 follows (\$2010):
 - 16 ▪ An added cost for assumed gas purchase costs (above the assumed price at Fort
17 Nelson) of \$3 per MMBTU (2010\$) to reflect LNG conversion costs and impact of
18 export market pricing.
 - 19 ▪ Simple cycle generation: 3.3 cents/ kW.h for all other supply costs for Scenario A
20 and Scenario B (capital costs of approximately \$10 to \$13 million (2010\$) reflect
21 31% of these Scenario A costs and 26% of these Scenario B costs).
 - 22 ▪ Combined cycle generation: 2.7 cents/ kW.h for all other supply costs for
23 Scenario A and Scenario B (capital costs of approximately \$9 to \$11 million
24 (2010\$) reflect 34% of these Scenario A costs and 27% of these Scenario B
25 costs).

26 Figure 6-2 provides Forecast LCOE (2010\$) for YEC grid generation with the above LNG supply options at
27 Scenario A grid load with DSM/SSE and different sensitivity cases for extending mine load, for simple
28 cycle and combined cycle generation with LNG supply from Fort Nelson and from Kitimat.

1 The following conclusions are noted:

- 2 • Combined cycle Forecast LCOE are consistently lower than simple cycle Forecast LCOE,
3 notwithstanding the low annual utilization level (44%) assumed for average annual generation.
4 Combined cycle Forecast LCOE for Scenario A with DSM/SSE are 19.0 cents/ kW.h for Fort Nelson
5 LNG supply and 18.4 cents/ kW.h for Kitimat LNG supply.

- 6 • Kitimat LNG supply LCOE are consistently lower than Fort Nelson LNG supply LCOE (difference of
7 0.7 cents/kW.h for all simple cycle generation cases examined in Figure 6-2 and 0.6 cents per
8 kW.h for combined cycle generation cases examined in Figure 6-2). This gap reflects the low
9 average utilization assumed (which adversely impacts the much more capital intensive Fort
10 Nelson LNG supply options) plus the absence of any other assumed loads to share in the
11 assumed non-scalable portion of the Fort Nelson liquefaction plant capital cost (this portion
12 represents 29% of the estimated liquefaction capital costs for the Scenario A load case, or about
13 0.84 cents/kW.h for the simple cycle option).

- 14 • LNG supply Forecast LCOE are 35-38% higher than Full Utilization LCOE for simple cycle options,
15 and 52-53% higher than Full Utilization LCOE for combined cycle options. Seasonal and annual
16 hydro fluctuations adversely impact LNG supply capacity average utilization and LCOE costs are
17 adversely impacted to the extent that generation unit and LNG supply chain capital costs are
18 underutilized. Full Utilization LCOE range from 13.7 to 14.5 cents/ kW.h for simple cycle options,
19 and from 12 to 12.5 cents/ kW.h for combined cycle options¹⁸⁷.

- 20 • LNG supply Forecast LCOE are somewhat sensitive to extending mine loads after 2021 to 2025
21 and 2030 (the biggest sensitivity is an extension to 2025, reducing Forecast LCOE by 2.6
22 cents/kW.h for simple cycle options and by 3.2 cents/ kW.h for combined cycle options).


23 Based on the above analysis, LNG Transition Portfolio Options are assessed for the 2011 Resource Plan
24 based on combined cycle generation for Scenario A and B loads (simple cycle is assumed to be all that is
25 feasible for Base Case loads) with LNG supply costs for an assumed Kitimat area supply option.

¹⁸⁷ These LCOE are indicative of the cost savings relative to diesel that are potentially provided by LNG to off grid mine loads having high annual load factors.

1 Although Kitimat area LNG supply costs are used for assessments in the 2011 Resource Plan, it is
2 recognized that the LCOE costs in Figure 6-2 fail to consider the implications of the broader LNG supply
3 options for all Yukon loads. The Kitimat area provides an upper level near-term cost that a Fort Nelson
4 area LNG supply option must not exceed; however, as demonstrated by the Braemar Wavespec studies,
5 development of new LNG from the Fort Nelson area to supply various potential Yukon off-grid users as
6 well as Yukon Energy grid use would likely provide lower LNG-based power costs for the grid and other
7 Yukon users than reliance on the Kitimat LNG supply option. The Fort Nelson LNG supply option also
8 offers lower long-term risks than the Kitimat LNG supply options as regards LNG-related fuel prices and
9 shorter supply chain trucking distances to Yukon. Based on current information, securing LNG supply by
10 late 2014 may also have greater likelihood of being feasible at Fort Nelson than at Kitimat.

11 The assumed use of combined cycle power units will provide the opportunity for waste heat sales for
12 district heating in Whitehorse similar to such sales projected for wood biomass or WTE generation at
13 Whitehorse (see Section 5). Based on potential district heat revenues examined in Section 5 (e.g., up to
14 about \$1.8 million per year), such sales could reduce Forecast LCOE costs by up to about 2 cents/ kW.h
15 under Scenario A loads with DSM/SSE when mine loads remain connected to the grid. Given uncertainties
16 regarding the life of connected mine loads and the sustainability of district heat supplied from LNG fuelled
17 generation (which would be shutdown when grid loads do not require LNG generation due to surplus
18 hydro generation), no district heat revenues are included at this time in the 2011 Resource Plan
19 assessment of LNG supply options.

1 **Figure 6-2: Forecast LCOE (2010\$) – Fort Nelson LNG Supply and Kitimat LNG Supply – Scenario A Load with DSM/SSE**




2

1 **6.1.4 Near-Term Portfolio Options**

2 The LNG/natural gas option as assessed for the LNG Transition Portfolio Options is similar to diesel in that
 3 it is fuel intensive with relatively low capital cost requirements - and accordingly provides flexibility in
 4 operation (i.e., it can be economically operated only when required to supply grid load).

5 Figure 6-3 shows costs per kW.h for new diesel plants and a 22 MW LNG/natural gas thermal plant
 6 during the brief period 2015-2020 under Scenario A load when the Victoria Gold mine load is assumed to
 7 be connected to the grid – in each year, diesel costs for fuel and O&M are well above the LNG/natural
 8 gas thermal plant costs (including capital as well as fuel and other O&M for the LNG power plant). Fuel
 9 and O&M costs account for 64% to 71% of LNG total annual costs in Figure 6-3 (capital costs in this
 10 analysis reflect YEC combined cycle generating unit capital costs).

11 **Figure 6-3: LNG Thermal Plant vs. Diesel Fuel & O&M Costs per kW.h – 2015-2020**




12

Annual Cost (cents/kW.h)	2015	2016	2017	2018	2019	2020
Diesel Fuel & O&M - new	28.8	29.3	29.9	30.5	31.1	31.8
LNG - total costs - Scenario A (fuel, O&M and Capital-related)	16.6	17.0	17.1	17.1	17.2	18.6
LNG - fuel & O&M -Scenario A	10.6	11.0	11.4	11.8	12.2	12.6

13

1 Reflecting the flexibility of the LNG option, Figure 6-4 shows that Forecast LCOE (2010\$) over the
 2 assumed 20-year plant economic life remains relatively unchanged (i.e., between 14.0 cents and 18.4
 3 cents/ kW.h) over a wide range of load scenarios (i.e., Base Case, Scenario A and Scenario B with and
 4 without DSM/SSE). The demonstrated variations in Forecast LCOE (and between Forecast LCOE and Full
 5 Utilization LCOE) reflect differences in annual plant capacity factors throughout the assumed plant life.


6 **Figure 6-4: Forecast LCOE (2010\$) for LNG Resource Option – Various Load Scenarios**



7

8 In order to assess possible portfolio options with LNG that might be cost effective, Figure 6-5 compares
 9 annual costs for various resource options during the 2015-2020 period for Scenario A with DSM/SSE.
 10 Overall, LNG annual costs per kW.h during this period remain well below annual costs for all renewable
 11 resource options other than the Marsh Lake Storage and Gladstone Diversion hydro enhancements.
 12 Accordingly, LNG portfolio options eligible for review (beyond LNG on its own without any other resource
 13 options) include LNG with Marsh Lake Storage and LNG with the combination of Marsh Lake Storage &
 14 Gladstone Diversion.

1 **Figure 6-5: Annual Costs per kW.h for LNG & Other Resource Options – 2015-2020**



2

Annual Cost (cents/kW.h)	2015	2016	2017	2018	2019	2020
Wood biomass 15 MW at \$104/t						
Total Costs	34	35	34	34	33	38
Fuel + O&M	19	20	20	20	20	24
21 MW Wind	29	29	28	27	26	28
2.2 MW WTE	31	30	29	28	27	28
LNG - total costs with capital	17	17	17	17	17	19
LNG - fuel & O&M	11	11	11	12	12	13
Marsh & Gladstone	16	15	15	14	14	15

3

4 In summary, three near-term LNG Transition Portfolio Options are defined for further assessment (for
5 each option, thermal plant size varies by load scenario with 4 MW for Base Case with DSM/SSE, 8 MW for
6 Base Case with no DSM/SSE, 22 MW for Scenario A and 30 MW for Scenario B):

- 7
- LNG Transition Portfolio Option #1 - LNG on its own;
 - 8 • LNG Transition Portfolio Option #2 – LNG and Marsh Lake Storage; and
 - 9 • LNG Transition Portfolio Option #3 – LNG and Marsh Lake Storage & Gladstone Diversion.

1 Present Value Costs for each of these options are provided in Tables 6-1 (LNG Option #1), Table 6-2
 2 (LNG Option #2), and Table 6-3 (LNG Option #3) - these costs are reviewed in Section 6.2. Each option
 3 is assumed to displace all Default Diesel Portfolio generation forecast each year after 2014.

4 **Table 6-1: LNG (2015) LNG Transition Portfolio Option #1 (LNG on its own) Present**
 5 **Value Costs: 2011-2030 (2010\$million)**

PV 2010\$ million ¹	PV Energy Costs ²	PV Capacity Capital Costs ³	DSM/SSE Cost	Total PV Costs	Change from Diesel Only ⁵
No DSM/SSE					
Base Case ⁴	66.0	43.7		109.7	-54.9
Scenario A ⁴	134.9	30.7		165.6	-117.9
Scenario B ⁴	177.7	23.8		201.5	-162.2
With DSM/SSE					
Base Case ⁴	23.6	31.9	35.4	90.9	-7.2
Scenario A ⁴	98.1	11.4	35.4	145.0	-59.1
Scenario B ⁴	139.6	5.2	35.4	180.2	-100.9

Notes:

1. Costs discounted at 6.56% per year YEC blended cost of capital.
2. Assumes diesel fuel & O&M units for all diesel not displaced by Projects.
3. Includes present value (2010\$) capital cost of assumed LOLE-related added capacity requirements (based on mine loads in excess of 13 MW) as well as N-1 capacity requirements where these are prime requirement. Includes costs and benefits of new resource option impacts on reliable capacity requirements where relevant.
4. LNG estimates assume 4 MW for Base Case with DSM/SSE, 8 MW for Base Case w/o DSM/SSE, 22 MW for Scenario A and 30 MW for Scenario B.
5. See Diesel Portfolio Option Present Value Costs.

6
 7 **Table 6-2: LNG (2015) LNG Transition Portfolio Option #2 (LNG & Marsh Lake) Present**
 8 **Value Costs: 2011-2030 (2010\$million)**

PV 2010\$ million ¹	PV Energy Costs ²	PV Capacity Capital Costs ³	DSM/SSE Cost	Total PV Costs	Change from Diesel Only ⁵
No DSM/SSE					
Base Case ⁴	65.7	42.6		108.3	-56.3
Scenario A ⁴	135.8	29.7		165.5	-118.0
Scenario B ⁴	178.5	22.9		201.4	-162.3
With DSM/SSE					
Base Case ⁴	26.9	26.6	35.4	88.9	-9.2
Scenario A ⁴	101.5	10.6	35.4	147.6	-56.5
Scenario B ⁴	142.7	4.5	35.4	182.7	-98.5

Notes:

1. Costs discounted at 6.56% per year YEC blended cost of capital.
2. Marsh Lake and LNG costs. Assumes diesel fuel & O&M units for all diesel not displaced by Projects.
3. Includes present value (2010\$) capital cost of assumed LOLE-related added capacity requirements (based on mine loads in excess of 13 MW) as well as N-1 capacity requirements where these are prime requirement. Includes costs and benefits of new resource option impacts on reliable capacity requirements where relevant.
4. LNG estimates assume 4 MW for Base Case with DSM/SSE, 8 MW for Base Case w/o DSM/SSE, 22 MW for Scenario A and 30 MW for Scenario B.
5. See Diesel Portfolio Option Present Value Costs.

1 **Table 6-3: LNG (2015) LNG Transition Portfolio Option #3 (LNG and Marsh & Gladstone)**
 2 **Present Value Costs: 2011-2030 (2010\$million)**

PV 2010\$ million ¹	PV Energy Costs ²	PV Capacity Capital Costs ³	DSM/SSE Cost	Total PV Costs	Change from Diesel Only ⁵
No DSM/SSE					
Base Case ⁴	68.8	42.6		111.4	-53.2
Scenario A ⁴	139.6	29.7		169.3	-114.1
Scenario B ⁴	181.8	22.9		204.6	-159.1
With DSM/SSE					
Base Case ⁴	44.9	26.6	35.4	107.0	8.9
Scenario A ⁴	116.2	10.6	35.4	162.2	-41.8
Scenario B ⁴	156.8	4.5	35.4	196.7	-84.4

Notes:

1. Costs discounted at 6.56% per year YEC blended cost of capital.
2. Marsh Lake, Gladstone Diversion and LNG costs. Assumes diesel fuel & O&M units for all diesel not displaced by Projects.
3. Includes present value (2010\$) capital cost of assumed LOLE-related added capacity requirements (based on mine loads in excess of 13 MW) as well as N-1 capacity requirements where these are prime requirement. Includes costs and benefits of new resource option impacts on reliable capacity requirements where relevant.
4. LNG estimates assume 4 MW for Base Case with DSM/SSE, 8 MW for Base Case w/o DSM/SSE, 22 MW for Scenario A and 30 MW for Scenario B.
5. See Diesel Portfolio Option Present Value Costs.

3

4 **6.2 GRID ECONOMIC IMPACTS**

5 As reviewed in Section 4.2, grid economic impacts for Portfolio Options are compared based on Portfolio
 6 present value (PV) costs and Forecast LCOE of non-diesel resource option package in each Portfolio. The
 7 following assessment focuses on the LNG Transition Portfolio, looking separately in each instance at grid
 8 economic impacts for Base Case load options and Scenario A and B load options. The analysis looks only
 9 at present value costs – Forecast LCOE assessment is not carried out given the flexibility of the LNG
 10 Transition Portfolio Options.

11 **Present Value Costs**

12 An overall present value cost assessment is provided for each LNG Transition Portfolio Option in Table 6-4
 13 for Base Case loads as well as for Scenario A and B loads. The Default Diesel Portfolio is also shown for
 14 comparison. This assessment addresses total incremental generation costs during the planning period
 15 (2011-2030) under the relevant near-term grid load scenarios, showing outcomes both with DSM/SSE
 16 and no DSM/SSE. Default Diesel is assumed to be retained for 2011-2014 (before the LNG plant is
 17 established).

1 **Table 6-4: Present Value Costs (2010\$million) - LNG Transition Portfolio Options & Diesel**

	Default Diesel Portfolio	Option #1 - LNG on its own	Option #2 - LNG and Marsh Lake Storage	Option #3 - LNG and Marsh Lake Storage & Glastone Diversion
Diesel Displaced 2015-2019¹		100%	100%	100%
Present Value Costs (2010\$million)				
No DSM/SSE				
Base Case	164.6	109.7	108.3	111.4
Scenario A	283.5	165.6	165.5	169.3
Scenario B	363.7	201.5	201.4	204.6
With DSM/SSE				
Base Case	98.1	90.9	88.9	107.0
Scenario A	204.0	145.0	147.6	162.2
Scenario B	281.2	180.2	182.7	196.7

2 1. LNG estimates assume 4 MW for Base Case with DSM/SSE, 8 MW for Base Case w/o DSM/SSE, 22 MW for Scenario A and 30 MW for Scenario B.

3 Figure 6-6 summarizes the percentage PV cost changes for the LNG Transition Portfolio Options
4 compared to the Default Diesel Portfolio.


5 The LNG Transition Portfolio Option #1 (LNG on its own) yields 7% to 45% lower present value costs
6 than the Default Diesel Portfolio, depending on the load scenario. Present value cost savings relative to
7 the Default Diesel Portfolio for Scenarios A and B respectively range from \$59 to \$100 million with
8 DSM/SSE (29% and 36% savings) and from \$118 to \$162 million with no DSM/SSE (42% to 45%
9 savings).

10 LNG Transition Portfolio Option #2 (LNG & Marsh Lake) yields PV cost savings relative to diesel similar to
11 Option #1. However, LNG Transition Portfolio Option #3 (LNG, Marsh & Gladstone) has higher PV costs
12 than Options #1 and #2, and under Base Case load also has PV costs that are 9% higher than the Diesel
13 Portfolio costs with DSM/SSE.

14 In summary, to the extent that LNG can be made available in Yukon it would appear that it could displace
15 diesel as the default option. Similar to diesel, LNG offers flexibility – but in addition, based on current
16 information, it also offers materially lower costs through a range of load conditions as demonstrated for
17 the various load forecasts during the planning period. Furthermore, an LNG Transition Portfolio that

1 includes Marsh Lake and (except for Base Case loads) Gladstone Diversion can continue to show PV costs
 2 savings relative to the Default Diesel Portfolio.

3 **Figure 6-6: Change in PV Costs (%) LNG Transition Portfolio Options**
 4 **Compared to Default Diesel**



5

6 **6.3 YUKON GREENHOUSE GAS EMISSIONS IMPACT**

7 LNG has lower overall GHG emissions than diesel generation, e.g., GHG for simple cycle operation with
 8 natural gas (LNG) at approximately 36% less than diesel fuel (about 451 tonnes per GW.h)¹⁸⁸; and for
 9 combined cycle at approximately 48% less than diesel fuel (about 361 tonnes/kW.h¹⁸⁹), regulated health
 10 air emission effects re: NOx, SO2 and particulates are also typically materially lower than diesel fuel
 11 emissions, with reduced potential concerns related to fuel spills effects (including storage tank leaks)
 12 compared with diesel fuel.

¹⁸⁸ See Section 2 (footnote 59 and 60) for detailed calculation - the 36% estimate (and 451 tonnes GHG emissions per GW.h estimate) is calculated using emissions factor data provided in National Inventory Report and efficiency of 8.204 Mcf/MWh for simple cycle combustion.

¹⁸⁹ See Section 2 (footnote 59 and 60) for detailed calculation - the 48% estimate (and 361 tonnes GHG emissions per GWh estimate) is calculated using emissions factor data provided in National Inventory Report and an efficiency of 6.562 Mcf/MWh for combined cycle combustion.

1 Under all non-diesel resource options there is assumed to be no ability to displace diesel and GHG
2 emissions until 2015 (as no potential resource options are assumed to be in service prior to that date).

3 GHG emissions reduction impacts from LNG Transition portfolio option #1 (LNG on its own) are estimated
4 at 30% of diesel emissions displaced. LNG Transition portfolio options for loads that include additional
5 generation from Marsh Lake Storage (Option #2) and Marsh Lake Storage & Gladstone Diversion (Option
6 #3) would further reduce GHGs. Percentage GHG emissions under each option and load scenario with
7 DSM/SSE are estimated as follows between 2015 and 2030:

8 • LNG Transition Portfolio Option #1 (LNG on its own):

9 ○ Base Case (4 MW LNG using Simple Cycle) – Displaces 36% of Default Diesel grid GHG
10 emissions.

11 ○ Scenario A (22 MW LNG using Combined Cycle) – Displaces 48% of Default Diesel grid
12 GHG emissions.

13 ○ Scenario B (30 MW LNG using Combined Cycle) – Displaces 48% of Default Diesel grid
14 GHG emissions.

15 • LNG Transition Portfolio Option #2 (LNG and Marsh):

16 ○ Base Case (4 MW LNG using Simple Cycle) – Displaces 58-67% of Default Diesel grid
17 GHG emissions during 2015-2020, and 69-100% of annual GHG emissions during 2021-
18 2030.

19 ○ Scenario A (22 MW LNG using Combined Cycle) – Displaces 52-53% of Default Diesel
20 grid GHG emissions during 2015-2020, and 75-100% of annual GHG emissions during
21 2021-2030.

22 ○ Scenario B (30 MW LNG using Combined Cycle) – Displaces 51% of Default Diesel grid
23 GHG emissions during 2015-2020, and 75-100% of annual GHG emissions during 2021-
24 2030.

25 • LNG Transition Portfolio Option #3 (LNG, Marsh and Gladstone):

26 ○ Base Case (4 MW LNG using Simple Cycle) – Displaces 58-60% of Default Diesel grid
27 GHG emissions during 2015-2017, 97-100% of annual GHG emissions during 2018-2020
28 (after Gladstone in service), and 100% of annual GHG emissions during 2021-2030.

29 ○ Scenario A (22 MW LNG using Combined Cycle) – Displaces 52% of Default Diesel grid
30 GHG emissions during 2015-2017, 69-72% of annual GHG emissions during 2018-2020
31 (after Gladstone in service), and 100% of annual GHG emissions during 2021-2030.

- 1 ○ Scenario B (30 MW LNG using Combined Cycle) – Displaces 51% of Default Diesel grid
2 GHG emissions during 2015-2017, 62-64% of annual GHG emissions during 2018-2020
3 (after Gladstone in service), and 100% of annual GHG emissions during 2021-2030.

4 Overall, with equivalent hydro enhancements, GHG emissions reductions on the grid during 2015-2020
5 under LNG Transition Portfolio Option #3 would be less than would occur with Minimum GHG Emissions
6 Portfolio Option A/B #3 (Marsh Lake Storage & Gladstone Diversion, and Wind), e.g., under Scenario A
7 about 4,425 tonnes less emissions reduction in 2015, and (with Gladstone in service) 9,697 tonnes less
8 emissions reduction in 2018.

9 The above assessments consider only grid loads. As reviewed in Section 4.3, absent new LNG supply
10 development it is expected that diesel generation for off-grid industrial loads will increase dramatically in
11 the near-term if the many mine projects are developed as planned, increasing power-related GHG
12 emissions in Yukon and changing perspectives as to the adequacy of relying only on DSM/SSE and non-
13 diesel resource options related to utility customer grid loads. The Casino mine load's use of LNG, for
14 example, would provide over 300,000 tonnes per year of GHG emission reductions relative to use of
15 diesel in Yukon. Similar off-grid opportunities have not been identified for other resource supply options.


16 When off-grid industrial load opportunities are fully considered along with other potential LNG
17 applications to displace oil fuel use, near-term LNG supply development in Yukon as part of the LNG
18 Transition approach has the potential to achieve greater overall GHG emissions reduction than can be
19 secured by the grid-focused Minimum GHG Emissions Portfolio Options reviewed in Section 5. For
20 example, if (along with Marsh Lake Storage) use of LNG combined cycle generation in 2015 rather than
21 diesel occurred for only 15 GW.h/year of the projected 352 GW.h/year of off-grid mine and utility loads
22 (which exclude Casino), GHG emissions reduction in Yukon with LNG Transition Portfolio Option #2 and
23 off-grid LNG use would exceed grid-based emissions reduction under Minimum GHG Emissions Portfolio
24 Options A/B #2, #3 or #4.

25 In reality, the Braemar Wavespec studies and other available information indicate that LNG will likely be
26 the preferred fuel source for onsite generation for all new off-grid mines using combined cycle units.

27 Figure 6-7 demonstrates that when off-grid industrial and utility diesel community load opportunities are
28 fully considered, near-term LNG supply development in Yukon as part of the LNG Transition approach has
29 the potential to achieve far lower overall GHG emission levels from power generation in Yukon during the
30 next 5-10 years than can be secured by grid-focused Minimum GHG Emissions Portfolio Options.

1
2

**Figure 6-7: Portfolio Option Yukon GHG (tonnes/year) – 2015-2030:
Grid Scenario A with DSM/SSE, Off-Grid Diesel Community, & Off-Grid Mines**



3

Total Yukon GHG Emissions (Tonnes/Year)¹

	2015	2020	2025	2030
Marsh & Biomass	252,384	767,010	661,267	625,287
Marsh, Wind & WTE	263,266	775,226	661,267	625,287
Marsh, Gladstone, Wind	270,569	769,132	661,267	625,287
Marsh, LNG Transition ²	158,844	582,266	505,355	488,089
Default Diesel (Casino with LNG)	306,067	815,235	662,522	630,560

1. Grid Scenario A with DSM/SSE, Off Grid Diesel Communities, & Off Grid Mines

2. Assumes LNG simple cycle at Watson Lake, LNG combined cycle at all mines.

4

5 Introduction of LNG into the territory would also create opportunities to enable fuel switching (e.g., for
6 use in vehicles on a territory wide basis and for heating applications in Whitehorse), helping establish
7 additional ways to reduce overall Yukon GHG emissions. Such additional uses of LNG to displace oil fuel
8 use in Yukon non-power generation sectors offer additional potential GHG emission reduction
9 opportunities.

10 **6.4 LONG-TERM DEVELOPMENT CONSIDERATIONS**

11 LNG offers a near-term opportunity to materially reduce both costs and GHG emissions and can assist
12 Yukoners through a transition period until such time as new legacy renewable supply resource options
13 can be cost effectively pursued. In this way, LNG can be used to facilitate desired longer-term legacy
14 resource development.

1 The LNG Transition Portfolio Option is designed as a potential transition response to current grid load
2 forecasts and the impacts expected to be associated with the Default Diesel Portfolio as well as various
3 Minimum GHG Emissions Portfolio Options relying on renewable resource development. LNG is not
4 considered as a long-term legacy resource option for Yukon. The intent would remain to displace LNG use
5 with appropriate renewable resource options when it is cost effective to do so (i.e., when sustained high
6 utilization can be effectively achieved for renewable electricity generation options over most of their
7 economic life so as to secure Forecast Utilization LCOEs that are equivalent to or less than LNG costs).

8 More specifically, LNG Transition Portfolio Options are expected to show escalating costs through future
9 years as natural gas prices are expected to increase at a rate faster than general inflation. Although the
10 precise timing and extent of such price increases is uncertain today, analysis in Section 5.4 indicates how
11 by 2020 the initial year costs for a new hydro development might correspond to the then current costs
12 for LNG-supplied generation - in which case, the transition from LNG to new hydro could occur relatively
13 smoothly, subject to the overriding need for sustained long term load to appropriately utilize the new
14 hydro on a sustainable basis.

15 At such time as new hydro develops, LNG generating unit capacity no longer needed for baseload energy
16 generation can be retained for peaking, low water and emergency/grid reliability use. These units are
17 flexible as to the range of such uses - and will likely be dual fuel in nature such that they can also use
18 diesel fuel if so required. Furthermore, when new hydro is developed LNG supplies are expected to
19 continue to be provided in Yukon to meet remaining off-grid power loads as well as other sector loads
20 such as transportation¹⁹⁰.

21 As discussed in Section 5, and particularly in Section 5.4, longer-term development if feasible before 2021
22 of medium and/or large scale hydro options offer potential to establish sustainable lower cost electricity
23 as well as low GHG emissions in a way similar to that secured by earlier legacy hydro developed in
24 response to earlier major Yukon industrial mine developments. Near-term planning to protect such hydro
25 development opportunities is outlined in Section 5.4. Near-term cost savings provided by an LNG
26 Transition Portfolio could facilitate ability to proceed with such planning for the next major legacy
27 renewable resource developments.

¹⁹⁰ These same considerations apply in the event that natural gas supplies come to be available directly in Yukon through the Alaska Highway Pipeline Project and/or Eagle Plains gas development. LNG liquefaction facilities may need to be moved to (or developed in) Yukon - but ongoing LNG requirements are anticipated to remain for off grid power uses and other sectors.

1 **6.5 CONCLUSIONS**

2 The LNG Transition Portfolio Option is designed as a potential transition response to current grid load
3 forecasts and the impacts expected to be associated with the Default Diesel Portfolio as well as various
4 Minimum GHG Emissions Portfolio Options relying on renewable resource development. Near-term cost
5 savings provided by an LNG Transition Portfolio could facilitate ability to proceed with such planning for
6 the next major legacy renewable resource developments.

7 LNG is not considered as a long-term legacy resource option for Yukon. The intent remains to displace
8 LNG use with appropriate renewable resource options such as greenfield hydro options discussed in
9 Section 5.4 when it is cost effective to do so (i.e., when sustained high utilization can be effectively
10 achieved for renewable electricity generation options over most of their economic life so as to secure
11 Forecast Utilization LCOEs that are equivalent to or less than LNG costs). When developed, such legacy
12 hydro projects will also further reduce GHG emissions and help to stabilize overall longer-term power
13 costs in Yukon.

14 LNG thermal generation involves relatively low capital costs, and retains the flexibility and reliability that
15 characterize the diesel thermal option. In effect, natural gas power plants are intended to be operated
16 only when required and (subject to securing fuel supply) can be relatively easily integrated today into the
17 Yukon system as conversion or replacement of the current diesel generation plant.

18 Under each of the assumed forecast load scenarios, the LNG Transition Portfolio Options provide over the
19 20-year planning period for materially lower present value (PV) costs than Default Diesel, as well as
20 materially lower GHG emissions compared to diesel. In contrast, near-term capital intensive renewable
21 resource portfolio options which minimize GHG emissions on the grid (Minimum GHG Portfolio Options)
22 provide over the 20-year planning period for materially higher overall PV costs and annual cost compared
23 to LNG options.

24 • **Under Base Case load scenarios with DSM/SSE**, LNG Transition portfolio options #1 (4 MW
25 LNG) and #2 (4 MW with Marsh Lake Storage) typically provide from 2015 to 2030 for lower
26 annual cost impacts than the Default Diesel Portfolio. Over the 20-year planning period, these
27 LNG options provide 7-29% lower PV costs compared to the Default Diesel portfolio. In contrast,
28 Minimum GHG option Base Case #1 (Marsh Lake Storage and Gladstone Diversion) provides 12%
29 higher PV costs compared to Default Diesel.

30 ○ Without DSM/SSE these LNG options maintain lower annual cost impacts compared to
31 both Default Diesel and the Minimum GHG Portfolio Options.

- 1 ○ A PV cost assessment of options without DSM/SSE provides that while all options
2 examined have PV cost savings compared to diesel, LNG-based portfolio options have
3 materially greater cost savings compared to all other portfolio options.
- 4 • **Under either Scenario A or Scenario B loads with DSM/SSE**, including with Scenario A or
5 B sensitivity tests for mine load extensions to 2025 or 2030 (with DSM/SSE or without DSM/SSE),
6 LNG Transition Portfolio Options are the only options that provide material PV cost savings over
7 the 20-year planning period compared to the Default Diesel Portfolio¹⁹¹.
- 8 ○ All three LNG Transition Portfolio Options over the period from 2015 to 2020 provide
9 lower incremental annual cost impacts compared to the Default Diesel Portfolio.
- 10 ○ After 2020, diesel combined with DSM/SSE has lower overall annual cost impacts
11 compared to all other portfolio options - slightly lower than LNG and LNG with Marsh in
12 2015. Absent DSM/SSE, after 2020 all LNG Transition Portfolio Options have lower annual
13 cost impacts compared to diesel.
- 14 ○ Assessment of LNG with Marsh and Gladstone (LNG Transition Option #3) indicates that
15 Gladstone at best makes little difference to PV costs and annual cost impacts when it is
16 combined with LNG and Marsh, even with higher loads such as Scenario B¹⁹².
- 17 ▪ Of the LNG Transition Portfolio Options, with Scenario A or B loads this option
18 provides the lowest PV cost savings compared to diesel with or without
19 DSM/SSE; however, the differences are relatively small if no DSM/SSE is
20 assumed.
- 21 ▪ LNG with Marsh and Gladstone has higher annual cost impacts than other LNG
22 Transition Options when mine loads are shut down with DSM/SSE.
- 23 ▪ With mine loads extended to 2025 or 2030, Gladstone with LNG and Marsh
24 provides for generally the same overall PV cost savings compared to LNG with
25 Marsh, both with and without DSM/SSE.

¹⁹¹ Under Scenario A loads, LNG Transition Portfolio Options #1 and #2 provide over the planning period between 23% and 24% PV cost savings compared to Default Diesel with DSM/SSE. Under Scenario B loads these LNG options provide 29-30% PV cost savings with DSM/SSE. In contrast, Minimum GHG Portfolio Options with Scenario A loads provide for PV cost increases compared to diesel with DSM/SSE in the range of 18% (\$35 million for Option A/B #3 with Marsh, Gladstone and Wind) to 13% (\$25 million for Option A/B#1 with Marsh and Wood biomass with no O&M cost after 2020 due to shut down of the wood biomass plant in response to the lack of connected mine loads). Slightly lower cost increases relative to Default Diesel occur for these Minimum GHG Portfolio Options with Scenario B loads with DSM/SSE, with the exception of a small PV cost saving (\$4.4 million) shown for Option A/B#1 assuming no O&M cost after 2020.

¹⁹² Gladstone in combination with LNG and Marsh provides for a 15% PV cost reduction compared to diesel under Scenario A loads with DSM/SSE and 24% PV cost reduction compared to diesel under Scenario B loads with DSM/SSE.

1 In summary, the LNG/natural gas option provides a range of benefits relative to the other available near-
2 term grid generation options:

3 • Where established, LNG would displace diesel as the default option in Yukon (although dual fuel
4 units could also cost effectively retain flexibility to use diesel if and when that would be
5 advantageous). Lower cost LNG fuel would affect the assessment of future resource choices and
6 also incremental pricing and rate setting in the rate zones where it is utilized (i.e., run out rates
7 for higher use levels could be set based on LNG costs rather than diesel fuel costs).

8 • Other potential development benefits include:

9 ○ LNG is the only option to offer material reductions in near-term annual cost impacts
10 under Scenario A or B loads, as well as the non-diesel option with the lowest annual cost
11 impacts in the event that currently assumed mine closures reduce grid loads after 2020.

12 ○ LNG provides a cost effective contribution to grid capacity planning requirements, and
13 the planned retirements of all of YEC's diesel plant over the 20-year planning period.

14 ○ As a result of the above impacts, LNG is the only option to offer opportunity to reduce
15 present value diesel costs during the planning period under Scenarios A and B (projected
16 reductions at 29% under Scenario A and 36% under Scenario B).

17 ○ Overall, this option offers high flexibility and ability to accommodate load changes; it can
18 also be cost effectively developed concurrently with hydro enhancements such as Marsh
19 Lake Storage and Gladstone Diversion.

20 ○ The LNG Transition Option can accommodate optimum timing for Gladstone diversion,
21 other potential hydro enhancements or greenfield developments, and wind development
22 in response to confirmation of longer-term grid loads needed to secure reduced Forecast
23 LCOE for these various renewable resource options.

24 Looking at GHG emissions reductions, LNG with combined cycle generation provides a 48% reduction in
25 grid GHG emissions not otherwise displaced by concurrent near-term hydro projects such as Marsh Lake
26 Storage and potentially Gladstone Diversion.

27 • Under Base Case Load scenarios during 2015-2019 LNG alone (Option #1) provides for a 36%
28 reduction in grid GHG emissions, and the combination of LNG and Marsh (Option #2) provides for
29 a 56-60% reduction (compared to a 35-38% reduction were only Marsh Lake pursued). If
30 Gladstone can be committed with LNG and Marsh (Option #3), this portfolio option would
31 increase the reduction in grid GHG emissions after 2017 to 97- 98% under Base Case loads with
32 DSM/SSE.

- 1 • Under Scenario A or B loads with DSM/SSE the LNG Transition Option #2 (with Marsh) reduces
2 grid GHG emissions during 2015-2019 by 51-52%. If Gladstone can be committed with LNG and
3 Marsh (Option #3), the reduction in grid GHG emissions after 2017 increases to 69% with
4 Scenario A and 62% with Scenario B.

5 LNG is the only portfolio option that can be used off-grid to reduce reliance on diesel (i.e., either off-grid
6 communities or industrial customers). This option can also be used to reduce GHG emissions in other
7 sectors where GHG emissions impacts are more significant (e.g., transportation). When off-grid industrial
8 and community load opportunities are fully considered along with other potential LNG applications to
9 displace diesel or other oil-based fuel use, near-term LNG supply development in Yukon as part of the
10 LNG Transition approach has the potential to achieve far greater overall GHG emission reduction during
11 the next 5-10 years than can be secured by grid-focused Minimum GHG Emissions Portfolio Options.

- 12 • Recent studies and other available information reviewed in Section 6.1 indicate that LNG will
13 likely be the preferred fuel source for onsite generation for all new off-grid mines.

- 14 • Additional uses of LNG to displace oil fuel use in Yukon non-power generation sectors (e.g.,
15 transportation and heating) offers additional potential GHG emission reduction opportunities.

16 In order to pursue the LNG option for near-term development for power generation in Yukon by late
17 2014, immediate further feasibility work is required to determine the optimum way to secure the LNG,
18 the required timing and all related costs (including assessment of potential options for LNG supply chain
19 development jointly with other interests to meet broader near and longer-term Yukon opportunities).
20 Feasibility work is also required to optimize the specific Yukon Energy generation capacity and technology
21 for power generation using LNG (including assessment of the optimum combination of combined cycle
22 and simple cycle units in response to different potential load scenarios).

1 **7.0 RESOURCE PLAN SUMMARY CONCLUSIONS**

2 Yukon Energy's 2011 Resource Plan addresses updated generation and transmission priorities in Yukon
3 for the 20-year planning period (2011-2030), focusing on resource planning options for implementation
4 over the next five years (2011-2015).

5 Consistent with the 2006 Resource Plan, this planning level assessment is based on currently available
6 information regarding forecast and potential energy and capacity requirements (Section 2) and available
7 resource supply alternatives (Sections 3 to 6). Several planning stages are required after the 2011
8 Resource Plan prior to any YEC decision to proceed with construction for any preferred project.

9 Summary conclusions are provided for the following:

- 10 • Challenges and Opportunities;
- 11 • Forecast Yukon Requirements – Default Diesel Portfolio Option;
- 12 • Portfolio Options to Default Diesel; and
- 13 • Summary Conclusions and Next Steps.

14 **7.1 CHALLENGES AND OPPORTUNITIES**

15 Reflecting the March 2011 Charrette outcomes, the challenge for the 2011 Resource Plan is to determine
16 how the forecast Yukon wide energy and capacity electricity requirements driven by economic growth can
17 be turned into an opportunity during the planning period to create an enhanced supply of clean or
18 sustainable energy that Yukoners can agree to and can afford.

- 19 • Higher costs to secure safe and reliable new resource supplies from utility operations on or off
20 the grid will increase rates throughout Yukon.
- 21 • Higher greenhouse gas (GHG) emissions from increased electricity generation in Yukon,
22 regardless as to whether these occur on or off the grid or derive from utility or non-utility
23 operations, will challenge Yukon's ability to secure overall GHG emission reductions.
- 24 • Flexibility is needed in all circumstances to address the challenges related to the isolation of
25 Yukon's electricity system, including challenges related to expected seasonal fluctuations in grid
26 requirements for new generation, potential changes in connected mine and other grid loads, and

1 potential changes in competitive generation option costs due to new resource supplies becoming
2 available, e.g., development of accessible natural gas in Yukon.

3 To address this challenge, near and longer-term options are assessed concurrently in the context of
4 current forecasts for overall Yukon energy and capacity requirements (i.e., off-grid as well as on grid for
5 all major power loads), agreed upon resource planning principles¹⁹³, and the assumption that Yukon
6 Energy is proceeding with a robust and aggressive Demand Side Management/Supply Side Enhancement
7 (DSM/SSE) program in response to Yukon Utilities Board Directives, government policy considerations and
8 stakeholder comments.

9 The 2011 Resource Plan confirms that forecast growth on and off-grid in Yukon will lead in the near as
10 well as longer term to high costs and high GHG emissions during the 20-year planning period if diesel is
11 relied upon to meet new generation requirements. The potential extent of new generation requirements
12 in Yukon over the next decade is unprecedented – and highlights a resource planning requirement to
13 address extensive rather than marginal new generation requirements.

14 Near-term grid generation resource portfolio options to diesel are identified for possible commitment
15 before 2015. The near-term challenge is to move quickly to meet new grid requirements emerging today,
16 while assessing the capability of new near-term resource portfolio options to meet the range of potential
17 forecast energy and capacity requirements on the grid over the 20-year planning period (2011-2030).

18 Longer-term resource options throughout Yukon for potential start of construction before 2021 are also
19 identified and examined in order to define appropriate planning activities during 2011-2015 to protect
20 these options and to confirm that near-term portfolio options remain attractive after consideration of
21 other longer-term resource options.

22 Overall, while near-term grid requirements and resource options define immediate challenges, the off-
23 grid load growth and longer-term resource options define major opportunities in Yukon today.

24 **7.2 FORECAST YUKON REQUIREMENTS – DEFAULT DIESEL PORTFOLIO OPTION**

25 The 2011 Resource Plan recognizes diesel as the current default generation option in Yukon (i.e., the
26 established and available supply option against which other new supply options must be assessed today
27 for both on grid and off-grid power requirements beyond those that can be supplied by current and

¹⁹³ The four key planning principles agreed to by Charrette participants are reliability, affordability, flexibility and environmental responsibility.

1 committed hydro and wind renewable generation). Accordingly, the Default Diesel Portfolio option relies
 2 solely on established diesel generation capacity on and off the grid, and ability to secure easily new diesel
 3 capacity as required at relatively low capital costs, in order to provide reliable and flexible generation to
 4 meet all forecast electrical energy and capacity requirements beyond those that can be supplied by
 5 currently existing or committed hydro and wind generation¹⁹⁴.

6 **Forecast Yukon Diesel Generation Requirements**

7 The grid and off-grid diesel and other non-renewable generation load requirements define important
 8 elements of the GHG emissions and legacy resource development challenges to be addressed today for
 9 the 20-year planning period. Forecast Yukon diesel energy generation requirements under the Default
 10 Diesel Portfolio option for the 20-year 2011 Resource Plan planning period are summarized in Table 7-1.

11 **Table 7-1 Forecast Yukon Diesel Energy Generation Requirements: 2011-2030**
 12 **(Potential Off-Grid Mine Generation includes LNG & Diesel)**

Diesel* Energy Requirement	2011	2015	2020	2025	2030
Base Case (GWh - Grid)					
with DSM/SSE	1.5	15.2	8.7	1.8	7.5
without DSM/SSE	1.5	23.7	32.5	40.3	82.8
Scenario A (GWh - Grid)	-	-	-	-	-
with DSM/SSE	1.5	84.9	72.5	1.8	7.5
without DSM/SSE	1.5	98.9	112.0	40.3	82.8
Scenario B (GWh - Grid)	-	-	-	-	-
with DSM/SSE	1.5	142.9	120.6	1.8	7.5
without DSM/SSE	1.5	158.1	163.3	40.3	82.8
Off Grid Diesel Community (GWh)	19.9	20.4	20.9	21.5	22.1
Potential Off Grid Mine Diesel* (GWh)	37.0	332.0	1,537.8	1,389.8	1,337.8


13 * Includes LNG for Casino mine

14 Figure 7-1 shows over a longer 40-year period (2011-2050) the existing Yukon grid system capability to
 15 supply potential grid load in the near-term (with Scenario B grid loads as shown in Table 7-1) and in the
 16 longer term with non-industrial grid load growing at an annual rate of 2.26% as assumed in the 2011
 17 Resource Plan based on recent trends. Forecast grid diesel generation reflects the extent to which grid
 18 loads exceed long-term average generation from existing and committed grid hydro and wind generation.

¹⁹⁴ In these assessments, long-term average annual generation capability is assumed for existing hydro and wind resources (annual hydro generation capability is adjusted as required to reflect higher capability at higher annual grid load levels).

1 Figure 7-1 also shows potential off-grid mine loads over the 40 year period, highlighting the potential
 2 extent to which mine load growth not connected to the grid could radically change Yukon power
 3 generation activities starting as soon as the 2015-2020 time period. As noted in Table 7-1, off-grid mine
 4 power generation is expected to rely upon diesel or LNG resource supply options.

5 **Figure 7-1: Existing System Capability to Supply Potential Grid Load &**
 6 **Potential Off-Grid Mine Loads: 2011-2050**



7
 8 **Forecast Grid Diesel Generation Requirements**

9 Forecast utility grid (integrated WAF and MD grids) diesel generation requirements in Table 7-1 are
 10 provided for three grid scenarios focused on near-term (i.e., to 2015) mine load connection prospects¹⁹⁵.

- 11 • **Base Case** – Includes non-industrial loads growing at recent rates (2.26%/year) and current
 12 connected mines (Minto and Alexco – current forecasts assume these mines remain on grid until
 13 around 2020). With and without DSM/SSE, forecast Base Case diesel generation ranges as

¹⁹⁵ See Section 4, Figure 4-1 for summary of forecast diesel energy requirements [grid and off grid utility loads] and Figure 4-2 for new diesel grid capacity requirements. Forecast diesel generation fuel and O&M costs reflect approved 2009 incremental diesel generation costs by rate zone escalated at inflation (2% per year) after 2010. Forecast new default diesel capacity requirements by year on the grid for each load scenario reflect forecast peak loads under the grid load scenarios, forecast generation unit retirements, and Yukon Energy's grid capacity planning requirements to meet peak winter loads.

1 follows: 15 to 24 GW.h/year in 2015, 9 to 32 GW.h/year in 2020, 2 to 41 GW.h/year in 2025 and
2 8 to 83 GW.h/year in 2030.

- 3 • **Scenario A** – Adds Victoria Gold mine to the grid Base Case in late 2013 (based on current
4 information, forecast assumes on grid for about 7 years, i.e. until end of 2020).
- 5 • **Scenario B** – Adds the potential Carmacks Copper mine and Whitehorse Copper Tailings mine to
6 the grid Scenario A (based on current information, forecasts assume on grid until 2021).
- 7 • **DSM/SSE** – Projections with no DSM/SSE and also with DSM/SSE (DSM/SSE assumed to secure
8 a 67% reduction in annual non-industrial grid load growth each year starting in 2013)¹⁹⁶.

9 Over the 20-year planning period all existing Yukon Energy diesel generation capacity is forecast to be
10 replaced due to expected retirements. The forecast timing for new diesel capacity is affected by the
11 assumed capacity requirements during the 2013-2020 period related to different load scenarios¹⁹⁷.

12 Under all of the above grid scenarios, a robust and successful DSM/SSE program would see minimal
13 diesel generation (and consequently minimal diesel cost impacts and diesel displacement opportunities)
14 after shut down of connected mine loads (i.e., with assumed DSM/SSE and Scenario A or B assumed
15 mine closures after 2020), there is less than 10 GW.h of required diesel generation annually over the
16 period from 2021 to 2030. In contrast, no DSM/SSE program (or unsuccessful DSM/SSE programming
17 over the period) would see much greater rate impacts and diesel displacement opportunities after 2020
18 (i.e., between 40 GW.h to 80 GW.h per year under all “no DSM/SSE” scenarios that assume closure of
19 connected mines after 2020).

20 **Off-Grid Utility Diesel Generation Requirements**

21 Off-grid utility community diesel energy power generation requirements are forecast to grow very slowly
22 based on recent trends for the diesel rate zone communities served by Yukon Electrical (Watson Lake,

¹⁹⁶ This range of potential diesel generation requirements is used to test the sensitivity of new supply options to potential DSM/SSE program impacts (DSM/SSE costs and programs are being addressed later in 2011 after completion of current studies and program development). DSM is also being addressed with industrial customers and is anticipated to provide some loads reductions beyond those shown (potentially in the order of 10% of grid mine loads). Pending completion of current DSM/SSE studies, the 2011 Resource Plan assumes that DSM/SSE programs incur an average annual cost equal to 7.5 cents/ kW.h (2010\$) of assumed energy load reduction.

¹⁹⁷ During the 2013-2020 period connected mine loads are expected to be sufficient to affect capacity planning requirements, while in other years the N-1 requirement based on non-industrial loads is expected to determine new default diesel capacity requirements.

1 three small diesel communities, and Old Crow). Off-grid utility community diesel generation exceeds grid
2 diesel generation under the Base Case forecast with DSM/SSE. Off-grid utility community diesel capacity
3 requirements are not addressed at this time.

4 **Potential Off-grid Mine Diesel Requirements**

5 Potential off-grid mine diesel/LNG energy generation forecasts indicate that unprecedented potential off-
6 grid industrial power load growth before 2020 could easily dwarf current projected utility grid and off-grid
7 diesel generation (see Figure 7-1). Current forecasts indicate that industrial off-grid diesel and/or LNG
8 power generation could potentially exceed 330 GW.h/year by 2015 and 1,545 GW.h/year by 2020, and
9 remain above 1,300 GW.h per year beyond the planning period (2030); by comparison, total grid load
10 served by hydro, wind and diesel generation as projected in 2020 under Scenario B with no DSM/SSE is
11 614 GW.h/year, i.e., about 36% of the potential off-grid industrial generation by that date.

12 The larger potential off-grid longer-life mines which constitute most of the potential projected off-grid
13 industrial load over the planning period (e.g., Casino, Selwyn, Mactung and Northern Dancer) are not
14 currently considering connection to the Yukon grid in order to meet load requirements. The largest of
15 these potential industrial loads (Casino project) is planning to use LNG at costs well below the cost of
16 diesel and Northern Dancer is also looking at the LNG option.

17 **Flexibility Requirements Re: Connected Mine Loads**

18 The 2011 Resource Plan forecast diesel scenarios focus on the hydro-based grid that serves most Yukon
19 customers. Forecast Default Diesel Portfolio diesel energy requirements on the grid are driven by forecast
20 future load growth, and this load growth is subject to considerable variability related to connected mine
21 loads.

22 The 2011 Resource Plan recognizes that a wide range of possible variations in connected mine loads may
23 occur over the 20-year planning period, including delays in connection of specific loads, extensions in the
24 life of any connected loads, earlier-than-expected mine shutdowns, and expansions or contractions in
25 connected loads.

- 26 • Resource option sensitivity for displacing grid diesel generation is tested for different potential
27 extensions of connected mine loads beyond the 2020 date after which current forecasts show
28 shut down of connected mine loads (sensitivity is tested separately for extensions of related grid
29 diesel requirements to 2025 and 2030).

- 1 • The potential for connection to the grid of material new off-grid mine loads (beyond those
2 included in Scenario A and B) is currently forecast to be very limited:
- 3 ○ Off-grid industrial diesel or other fossil fuel power generation at the Wolverine mine (37
4 GW.h/year) already exceeds utility diesel generation (grid and off-grid). This load is over
5 270 km from the grid, and connection was never considered to be a practical option
6 given this distance and an expected 10-year mine life.
- 7 ○ There are currently only a limited number of potential new mine opportunities located
8 within 50-100 km of the 69-138 kV grid (e.g., potentially Rau Gold, Ketzka River and
9 Brewery Creek), and at this time none of these mine loads have been included in current
10 grid load forecasts.
- 11 • Opportunities exist in the longer-term (i.e., commitments prior to 2021) to connect to the grid
12 one or more of the major new off-grid mine loads that are driving potential off-grid diesel/LNG
13 generation on a multi-decade basis as shown in Figure 7-1. However, as noted, these mine loads
14 are not being planned on the basis of any grid connection and any potential grid connection in
15 future will be contingent on new larger-scale renewable resources being developed that can
16 supply a major share of the new off-grid power requirements on a timely and cost-effective
17 basis. Looking at the largest of these potential off-grid mine loads (Casino), this opportunity
18 translates into the challenge of developing new renewable resource options within the next
19 decade that are less costly than the LNG (or natural gas fuelled generation if pipeline or Eagle
20 Plains gas becomes available) that is currently planned to supply this load.

21 **Default Diesel Portfolio Costs & GHG Emissions**

22 The concerns raised by the Default Diesel Portfolio option are high costs and high GHG emissions, each of
23 which derives from the use of diesel fuel¹⁹⁸.

24 The cost challenge arising from the grid load forecasts is that grid Default Diesel Portfolio cost
25 requirements even with DSM/SSE would, if realized, constitute a major rate driver starting as soon as late
26 2013 and continuing over the period to 2020.

¹⁹⁸ Costs are also required to replace all existing diesel capacity (and to provide added capacity as needed) during the planning period. However, with regard to meeting these capacity planning requirements, diesel is a low cost option with minimal site-related environmental impact concerns.

1 While utility cost considerations and ratepayer impacts are focused on grid load default diesel generation
2 requirements, considerations related to GHG emissions reductions in the power generation sector
3 (whether utility generation or industrial on site generation) must consider the whole of Yukon.

4 Forecast grid generation accounts for a small portion of total GHG emissions forecast for the Yukon
5 power generation sector¹⁹⁹. This is the situation today (2011) and is forecast to remain the likely reality
6 throughout the 20-year forecast period. Over the next several years prior to 2020, off-grid industrial load
7 and related emissions are forecast to increase dramatically, effectively dwarfing on grid load and GHG
8 emissions. Addressing the GHG emission challenge related to off-grid loads also raises new power
9 planning considerations well beyond those addressed in the 2006 Resource Plan. The potential near-term
10 surge in off-grid mine development, however, also raises the opportunity to examine new renewable
11 resource development options for commitment prior to 2021 to expand the grid and help to supply power
12 requirements for major new industrial developments.

13 In summary, the major near-term challenge for the next five years in particular based on the 2011
14 Resource Plan grid load forecasts is to reduce costs and GHG emissions by displacing diesel energy
15 generation that would otherwise be required between 2014 and 2021. Assuming that the current Yukon
16 mining boom is sustained, the very large longer-term challenge highlighted by the 2011 Resource Plan
17 load forecasts is to secure long-term grid load growth beyond 2021 sufficient to achieve low cost and low
18 GHG emission legacy energy supply project development.

19 **7.3 PORTFOLIO OPTIONS TO DEFAULT DIESEL**

20 The 2011 Resource Plan identifies and assesses near-term (i.e., can be committed before 2015) as well
21 as longer-term (i.e., can start construction before 2021) non-diesel resource options in Yukon to cost-
22 effectively reduce reliance on diesel generation and thereby also reduce GHG emissions from the power
23 generation sector. Where relevant, non-diesel options are also examined to reduce reliance on diesel
24 generation for the forecast off-grid loads summarized in Table 7-1.

25 As noted in Section 7.2, diesel displacement opportunities for grid loads have been examined in the 2011
26 Resource Plan with and without DSM/SSE programming that is assumed to commence by the start of
27 2013. Ongoing studies are defining the economic potential for DSM and SSE as well as specific programs

¹⁹⁹ See Figure 4-4 shows total Yukon non-renewable generation (grid and off grid) GHG emissions during the planning period under each grid load scenario with DSM/SSE (the table below the figure includes load scenarios with no DSM/SSE); the figure includes off grid utility communities and existing plus potential off grid industrial (mines).

1 and costs. Pending completion of these studies, the 2011 Resource Plan assumes that DSM/SSE will be
2 implemented as a near-term major resource option, estimates potential limits as to how much diesel this
3 option alone can displace under each load scenario, and tests the sensitivity of all non-diesel supply
4 options to such potential DSM/SSE impacts. In summary, notwithstanding the materially higher diesel
5 displacement opportunities (see Table 7-1) and higher Default Diesel Portfolio costs with no DSM/SSE
6 (see Section 7.2), comparative assessments of the different resource portfolio options under load
7 scenarios with DSM/SSE were not generally changed by consideration of load scenarios with no
8 DSM/SSE²⁰⁰.

9 Accordingly, the following summary analysis of portfolio options focuses solely on review of load
10 scenarios with DSM/SSE.

11 Non-diesel resource options will be more effective in displacing diesel generation on the grid to the extent
12 that they can be focused in the priority diesel generation periods (winter/spring) and flexible to address
13 relatively wide variability in annual hydro generation capability. This reality reflects the lack of grid
14 connection in Yukon to external markets - and the resulting need to ensure where feasible that local
15 generation matches the local grid load requirements (as surplus generation cannot otherwise be usefully
16 used or sold)²⁰¹.

17 Overall, only a few non-diesel resource options that are currently or potentially feasible for consideration
18 (e.g., hydro, LNG or future pipeline natural gas and, to a much lesser degree, wood biomass) offer large
19 scale energy generation supply potential relative to forecast Yukon diesel generation loads. Portfolio
20 options examine the extent to which different approaches could effectively reduce grid diesel generation
21 under different forecast load scenarios. Diesel generation is assumed to be retained in each portfolio to
22 supply all generation requirements not supplied by other resources.

²⁰⁰ Higher loads assuming no DSM/SSE tend to improve cost savings for all non-diesel portfolio options when compared with the Default Diesel Portfolio, and reduce somewhat the comparative annual cost impact penalties faced by non-flexible Minimum GHG Portfolio options such as Wind when grid loads drop due to mine closures. Portfolios that include Gladstone Diversion tend in particular to show improved (lower) present value costs and annual cost impacts over the planning period. However, the overall cost and annual cost impact rankings of LNG Transition Portfolio Options relative to Minimum GHG Portfolio Options or the Default Diesel Portfolio is not materially changed.

²⁰¹ See Section 2.4 for more detailed review of these material constraints and how they affect the cost-effectiveness and ability to utilize different generation resource options. In the end, resource options for the grid in Yukon are valued based on ability to displace diesel generation (i.e., generation that is surplus to diesel displacement needs has little if any value to ratepayers).

1 **Near-term Portfolio Options to Default Diesel**

2 The 2011 Resource Plan identifies the following non-diesel resource options available for the grid that can
3 be committed before 2015:

- 4 • Generation resource options identified as potentially available for in service by late 2014 include
5 Marsh Lake Storage (6.4 GW.h/year potential), Wood Biomass Thermal (10 to 15 MW), Waste to
6 Energy (WTE) Thermal (2.2 MW), Wind (10.5 or 21 MW), and Liquid Natural Gas (LNG) (4 to 30
7 MW). In contrast, Gladstone Diversion (36.6 GW.h/year potential) likely cannot be committed
8 before 2016 at the earliest, but could potentially constitute a resource for in-service by late 2017.
9 Each of these options is assessed based on the information available at this time – recognizing
10 that further feasibility work is required in each case to determine whether or not the option is
11 feasible to be committed by the dates currently assumed.
- 12 ○ Wood Biomass and LNG are options where sourcing fuel supply remains an issue to be
13 addressed – further pre-feasibility analysis is required prior to relying on either of these
14 options for near-term supply²⁰².
- 15 ○ Feasibility information for Marsh Lake Storage and Gladstone Diversion confirms the
16 relatively low cost offered by each of these hydro enhancement options – however, each
17 of these hydro projects is subject to material timing uncertainties related to regulatory
18 and permitting processes, and further Yukon Energy planning work on Gladstone
19 Diversion is also subject to securing local First Nation support for the project. Gladstone
20 Diversion is examined as potentially being in-service by late 2017 (it is expected that this
21 option cannot be committed before 2015 – the assessment examines the potential
22 impact of securing this option by the end of 2017).
- 23 ○ Feasibility information is also available for Wind and WTE options; however, further
24 feasibility work is required on each of these projects before commitments could be made
25 to proceed with permitting activities.

26 Alternative portfolios including each of the above near-term resource options have been reviewed
27 considering grid economic impacts, Yukon greenhouse gas emissions impacts and long-term development

²⁰² It is assumed that LNG and wood biomass options could likely be committed before 2015 if selected for development, subject to sufficient studies and planning being carried out in a timely manner to resolve various feedstock supply issues. Section 6.1 reviews recent studies that YEC has participated in with the developer of the Casino mine project to confirm the feasibility of near-term LNG supply chain options to Yukon from Kitimat or Fort Nelson, BC.

1 considerations. Near-term cost and rate impacts vary significantly depending in large part on the capital
2 intensive nature of each resource option and its flexibility relative to major forecast load reductions after
3 2020 under all resource plan forecast scenarios.

4 Table 7-2 provides an overview of different resource portfolio near-term options indentified in the 2011
5 Resource Plan (Scenario A grid loads with DSM/SSE are assumed for this table²⁰³). In addition to the
6 Default Diesel Portfolio, the following Portfolio Options are identified (resource options assumed to be in
7 operation by start of 2015, except for Gladstone Diversion [assumed to be in operation by start of
8 2018]).

9 1. Minimum GHG Portfolio Options:

- 10 a. Marsh Lake Storage & 15 MW Wood Biomass²⁰⁴ (displaces 89-92% of grid diesel GHG for
11 2015-2019 period);
- 12 b. Marsh Lake Storage, Gladstone Diversion & 21 MW Wind²⁰⁵ (displaces 60-61% of grid
13 diesel GHG for 2015-17 period and 84-85% for 2018-19 period [after Gladstone]); and
- 14 c. Marsh Lake Storage, 21 MW Wind²⁰⁶ & 2.2 MW Waste-to-Energy (WTE)²⁰⁷ (displaces 70-
15 74% of grid diesel GHG for 2015-2019 period).

²⁰³ The same Resource Portfolio Options apply for Scenario B loads with DSM/SSE, and for Scenario A or B loads with no DSM/SSE, subject to the LNG plant being 30 MW capacity rather than 22 MW capacity. Base Case Portfolio Options are more limited due to smaller scale of the diesel displacement loads, e.g., with DSM/SSE the options are Marsh Lake Storage & 2.2 MW WTE for Minimum GHG Portfolio, and LNG 4 MW or Marsh Lake Storage & LNG 4 MW for LNG Transition Portfolio [if no DSM/SSE, LNG plant scale increased to 8 MW]; for Base Case loads, LNG options assume simple cycle power plant (40% energy efficiency) and reliance on LNG availability in Yukon to supply off grid mine loads.

²⁰⁴ Assumed to be located adjacent to grid in Minto burn area with wood biomass requirement of 0.7 ODT/MW.h at an average cost (2010\$) of \$104/ ODT. The plant is assumed to be shut down (no O&M cost) after connected mines are closed (after 2020).

²⁰⁵ The Wind resource option assumes that, in addition to a 21 MW wind farm at Ferry Hill, 5 MW diesel rotary uninterruptible power (DRUPS) is required at a capital cost of approximately \$10 million (2010\$) for reliability if this level of wind resource is developed on the grid under forecast grid loads.

²⁰⁶ Ibid.

²⁰⁷ Assumes use 25,000 ODT/year of MSW plus 3,800 ODT/year wood biomass at Whitehorse WTE plant, with district heat net revenues, tipping fees and other revenues of \$3.3 million per year (2010\$).

- 1 2. LNG Transition Portfolio Options²⁰⁸:
- 2 a. Marsh Lake Storage & LNG (22 MW) (displaces 52% of grid diesel GHG for 2015-2019
- 3 period); and
- 4 b. LNG (22 MW) (displaces 48% of grid diesel GHG for 2015-2019 period).

5 Table 7-2 compares the present value incremental generation costs of each Portfolio option over the 20-

6 year planning period as well as the Forecast LCOE (levelized cost of energy over project life)²⁰⁹. In

7 summary, the following are noted:

- 8 • LNG Transition Portfolio Options have a much lower PV cost and Forecast LCOE than Default
- 9 Diesel.
- 10 ○ LNG Portfolio PV costs at 54% of PV costs for Default Diesel Portfolio under Scenario A
- 11 with DSM/SSE.
- 12 ○ LNG Forecast LCOE at 51-55% of Default Diesel Portfolio Forecast LCOE (61-66% if
- 13 compare only with diesel fuel and O&M costs).
- 14 • LNG Transition Portfolio Options have a much lower PV cost and Forecast LCOE than any of the
- 15 Minimum GHG Portfolio Options.
- 16 ○ Minimum GHG Portfolio PV costs 119-147% of PV costs for Default Diesel Portfolio.
- 17 ○ Minimum GHG Portfolio Forecast LCOE at 87-118% of Default Diesel Portfolio Forecast
- 18 LCOE (104-141% if compare only with diesel fuel and O&M costs).

²⁰⁸ Assumes combined cycle generation units at Whitehorse with 50% energy efficiency (6.562 Mcf/MW.h) and that 22 MW capacity sufficient to displace all Scenario A forecast diesel generation (44% average annual plant capacity factor with 2015 grid load with DSM/SSE and average hydro generation). LNG supply assumed by truck from Kitimat LNG at cost of 2.7 cents/ kW.h (2010\$) for all LNG supply costs other than LNG fuel (fuel cost at assumed BC natural gas price plus \$3/MMBTU (2010\$) to reflect conversion costs and impact of export market pricing; assumed BC natural gas price (2010\$) at \$5.5 per MMBTU in 2015 [\$6.07 per MMBTU after inflation], \$6.60 per MMBTU in 2020 [\$8.05 MMBTU after inflation] and \$7.45 per MMBTU in 2030 [\$11.07 per MMBTU after inflation]). Although combined cycle will provide opportunity for waste heat sales in Whitehorse at least similar to those assumed for WTE option, no such sales revenues are currently included in the analysis (district heating sales equivalent to those assumed for 2.2 MW WTE would reduce 2 MW LNG costs by approximately 2 cents per kW.h); concerns about sustainability of district heat supplied from YEC LNG fuelled generation at forecast loads, i.e., LNG will be shut down when grid loads do not require LNG generation to displace diesel due to surplus hydro generation.

²⁰⁹ PV cost and LCOE assume discount rate of 6.56%/year based on YEC's 2009 GRA approved return on equity and cost of new long term debt. PV cost excludes assumed \$35.4 million PV cost for DSM/SSE over this period, which is common to all Portfolio options. Forecast LCOE for a specific resource option is cents/ kW.h of forecast diesel displaced [2010\$] over the assumed economic life of that resource option and assuming forecast diesel generation under Scenario A with DSM/SSE.

1
2

**Table 7-2: Overview of Resource Portfolio Near-Term
Options Scenario A with DSM/SSE: 2011-2030**

	PV Cost million ¹	Forecast LCOE ²	Capital Cost (2010\$)		O&M Cost (2010\$)		Reliable Capacity	Total Capacity	Energy Capability	Diesel Required/ Displaced	
	(2010\$)	c/kWh	\$/MW	\$million	\$/MW.h	\$mill./ year	MW	MW	GW.h/year	2015-19 av. GW.h/yr	
Default Diesel Portfolio											
Diesel Energy	133.9	28.0				280.3	-			292.0	85
Diesel Capacity	34.7	8.1	1.5	55.6			37.1	37.1			
Total Default Diesel	168.6	36.1									
Min GHG Portfolio Options											
Marsh & 15 MW Wood Biomass											
Marsh Lake Storage	7.0	34.8		10.5	-	0.1	1.0	1.0	6.7	6	
Wood Biomass (15 MW)*	121.8		5.7	85.5	72.8	4.0	15.0	15.0	120.0	72	
Diesel Energy	39.7				280.3				166.4	7	
Diesel Capacity	16.5		1.5	31.6			21.1	21.1			
Total	185.0			127.6			37.1	37.1			
*No O&M after 2020											
Marsh, Gladstone & 21 MW Wind											
Marsh Lake Storage	7.0	29.0		10.5		0.1	1.0	1.0	6.7	6	
Gladstone Diversion	20.8			40.0		0.2	-	-	36.6	NA	
Wind (21 MW)*	88.4		3.6	93.4		2.1	5.0	26.0	55.6	45	
Diesel Energy	57.1				280.3				245.3	NA	
Diesel Capacity	27.3		1.5	46.6			31.1	31.1			
Total	200.6			190.5			37.1	58.1			
*Includes 5MW DRUPS											
Marsh, 21 MW Wind, & 2.2 MW WTE											
Marsh Lake Storage	7.0	39.4		10.5		0.1	1.0	1.0	6.4	6	
Wind (21 MW)*	88.4		3.6	93.4		2.1	5.0	26.0	55.6	45	
2.2 MW Waste to Energy (WTE)	25.9		17.7	39.0		(0.3)	2.2	2.2	17.1	14	
Diesel Energy	56.7				280.3				228.0	20	
Diesel Capacity	24.6		1.5	43.3			28.9	28.9			
Total	202.6			186.2			37.1	58.1			
*Includes 5MW DRUPS											
LNG Transition Portfolio Options											
Marsh & 22 MW LNG											
Marsh Lake Storage	7.0	17.1		10.5		0.1	1.0	1.0	6.4	6	
LNG (22 MW)	65.4		1.8	40.3	95.6-107.9	0.1	22.0	22.0	173.4	79	
Diesel Energy	29.2				280.3				111.2	-	
Diesel Capacity	10.6		1.5	21.1			14.1	14.1			
Total	112.1			71.9			37.1	37.1			
LNG (22 MW)											
LNG (22 MW)	69.0	18.4	1.8	40.3	95.6-107.9	0.1	22.0	22.0	173.4	85	
Diesel Energy	29.2				280.3				119.1	-	
Diesel Capacity	11.4		1.5	22.6			15.1	15.1			
Total	109.6			62.9			37.1	37.1			

Notes: 1. PV = Present Value cost over 20-year planning period (2011-2030). Excludes \$35.4 million PV cost for DSM/SSE.
2. Forecast LCOE = Levelized Cost of Energy (cents/ kW.h of forecast diesel displaced [2010\$]) over project life.

3

1 The LNG resource option has much lower incremental capital costs than the wood biomass or wind
2 resource options examined, and much lower capital costs per MW than all of the Minimum GHG resource
3 options²¹⁰. LNG, WTE and Wood Biomass resource options each provide reliable capacity equal to their
4 plant capacity – in contrast, Wind and Gladstone each provide little if any reliable capacity benefits.

5 Among the near-term non-diesel resource options, LNG can provide flexible amounts of supply up to any
6 load levels likely to be required and Wood Biomass can also provide relatively large amounts of annual
7 generation (119.6 GW.h/year for a 15 MW plant)²¹¹. In contrast, maximum potential levels of annual
8 generation are limited from Marsh Lake (6.4 GW.h/year), 2.2 MW WTE (17.1 GW.h/year), Gladstone
9 Diversion (36.6 GW.h/year), and Wind (55.6 GW.h/year).


10 LNG is the only non-diesel portfolio option examined for the near-term that can be used off-grid to
11 reduce reliance on diesel (i.e., either off-grid communities or industrial customers). Figure 7-2
12 demonstrates that when off-grid industrial and utility diesel community load opportunities are fully
13 considered, near-term LNG supply development in Yukon as part of the LNG Transition approach has the
14 potential to achieve far lower overall GHG emission levels from power generation in Yukon during the
15 next 5-10 years than can be secured by grid-focused Minimum GHG emissions portfolio options. Unlike
16 other resource options, the LNG option can also be used to reduce GHG emissions in non-power
17 generation sectors where GHG emissions impacts are more significant in Yukon (e.g., transportation).

²¹⁰ The Wood Biomass resource option is typically assumed to operate year round – however, this option is assumed to be flexible enough to shut down when the grid annual load drops to very low levels after 2020 (as a result, the material O&M cost of \$72.8/MW.h (2010\$) is saved, providing this option with PV cost savings relative to other Minimum GHG resource options which do not have this flexibility).

²¹¹ Studies suggest that a 25 MW plant scale might also be feasible, with annual generation approaching 200 GW.h/year).

1
2

Figure 7-2: Portfolio Option Yukon GHG (tonnes/year) – 2015-2030
Grid Scenario A with DSM/SSE, Off-Grid Diesel Community, & Off-Grid Mines



3

Total Yukon GHG Emissions (Tonnes/Year)¹

	2015	2020	2025	2030
Marsh & Biomass	252,384	767,010	661,267	625,287
Marsh, Wind & WTE	263,266	775,226	661,267	625,287
Marsh, Gladstone, Wind	270,569	769,132	661,267	625,287
Marsh, LNG Transition ²	158,844	582,266	505,355	488,089
Default Diesel (Casino with LNG)	306,067	815,235	662,522	630,560

1. Grid Scenario A with DSM/SSE, Off Grid Diesel Communities, & Off Grid Mines

2. Assumes LNG simple cycle at Watson Lake, LNG combined cycle at all mines.

4

5 Longer-Term Resource Options to Default Diesel

6 Available long-term renewable resource options to reduce costs and GHG emissions consist primarily of
7 greenfield hydro resource options potentially available to start construction before 2021 (some could
8 potentially be in service before 2021), provided that sufficient site specific planning processes are

1 sustained as required by Yukon Energy throughout the next five year period through 2015.²¹² In contrast,
2 longer-term direct access in Yukon to lower cost natural gas supplies for power generation is dependent
3 upon development by others of the Alaska Highway Pipeline Project (in-service currently planned for
4 2020/21) and/or the Eagle Plains gas reserves – and the emergence of such supplies during the planning
5 period would materially change the competitive context for a wide range of other resource options.

6 The potential extent of new off-grid generation requirements in Yukon over the next decade highlights
7 resource planning opportunities to address extensive rather than marginal new legacy generation
8 resource developments. Low cost (i.e., competitive with LNG or even natural gas, rather than only with
9 diesel) and larger volume (hundreds of GW.h/year rather than tens of GW.h/ year) renewable resource
10 options are required that can be developed within the next decade in response to these planning
11 opportunities.

12 The greenfield hydro resource options identified as longer-term options are potential legacy projects that,
13 subject to having adequate loads to fully utilize this generation, could provide relatively large amounts of
14 lower cost power, e.g., total potential supply exceeding 6,800 GW.h/year at full utilization levelized cost
15 (including transmission) below 15 cents/ kW.h²¹³.

- 16 • **Hydro Options at less than 10 cents/kW.h:** Nine sites or schemes are identified with
17 estimated Full Utilization LCOE's (2009\$) below 10 cents/kW.h and over 4,390 GW.h per year of
18 average annual sustainable energy (net of duplication among sites); four of these sites are
19 Medium scale (11-60 MW) that could together provide over 850 GW.h/year; the other sites are
20 Large scale (>60 MW).
- 21 • **Hydro Options at 10-15 cents/kW.h:** A further eight sites or schemes are identified with Full
22 Utilization LCOE's between 10 and 15 cents/ kW.h and over 2,000 GW.h of additional average
23 annual sustainable energy; five of these sites are Medium scale (over 850 GW.h/year); the other
24 sites are Large scale (>60 MW).

²¹² As reviewed in Section 3.1 and Section 5.1.2, geothermal and clean coal resource options are identified as other long-term options in Yukon that might provide both low cost and low GHG emissions at some point during the planning period – however, beyond monitoring of related activities (e.g., geothermal exploration and confirmation drilling, indigenous Yukon coal resource development and evolving clean and small scale coal technology in other jurisdictions), the 2011 Resource Plan does not consider specific planning activities for these options during the next five years. Similarly, monitoring of ongoing activities is all that is considered today with regard to potential development in the future of a natural gas pipeline, Eagle Plains gas, or transmission connection to the BC grid and/or Alaska.

²¹³ See Section 5.1 and 5.4 for review of these longer term resource options and related planning requirements for the noted hydro project options. See Figure 1-2 and Figure 3-1 for maps showing the location of identified load and resource supply options. Other smaller hydro opportunities are also identified in these sections.

- 1 • **Other Medium Scale Hydro Options:** A further two Medium scale sites located north of the
2 Watson Lake area are identified with Full Utilization LCOE's under 15 cents/ kW.h if exceptionally
3 high transmission cost estimates to connect to the existing grid are excluded from consideration.
4 Together, these sites could provide over 375 GW.h per year of additional average annual
5 sustainable energy.

6 Development of the lower cost and lower emission greenfield hydro generation options during the
7 planning period is subject to connecting new grid loads that could fully utilize the specific resource
8 options over 20-30 or more years.

- 9 • Potential off-grid mine developments prior to 2021 relying on fossil fuel generation are identified
10 that could potentially exceed 1,500 GW.h/year and remain above 1,300 GW.h/year through 2045
11 in the event that three of these multi-decade off-grid mines are developed (i.e., the Casino
12 Property west of the CSTP grid (940 GW.h/year), the Selwyn project located to the east of the
13 WAF grid in the passes close to the border with NWT (147 GW.h/year), and the Northern Dancer
14 project located near the Alaska Highway east of Teslin (200-300 GW.h/year)).
- 15 • If the Alaska Highway Pipeline project proceeds, gas compressors for this project could
16 potentially add 1,470 GW.h/year of additional equivalent energy requirements (six compressor
17 stations) by approximately 2020/21 that would also be sustained over 25 years in the event that
18 GHG emissions concerns support electrification initiatives.

19 The above off-grid mine and/or pipeline compressor loads are not being planned today on the basis of
20 any grid connection – and any potential grid connection in future will be contingent on new larger-scale
21 renewable resources being developed that can supply a major share of such new power requirements on
22 a timely and cost-effective basis. Looking at the largest of these potential off-grid mine loads (Casino),
23 this opportunity translates into the challenge of developing new renewable resource options within the
24 next decade that are less costly than the LNG (or natural gas fuelled generation if pipeline or Eagle Plains
25 gas becomes available) that is currently planned to supply this load.

26 The LNG Transition portfolio option is designed as a potential transition response to current grid load
27 forecasts and the impacts expected to be associated with the Default Diesel portfolio as well as various
28 Minimum GHG emissions portfolio options relying on renewable resource development. LNG is not
29 considered as a long-term legacy resource option for Yukon. The intent would remain to displace LNG use
30 with appropriate renewable resource options when it is cost effective to do so (i.e., when sustained high
31 utilization can be effectively achieved for renewable electricity generation options over most of their
32 economic life so as to secure Forecast Utilization LCOEs that are equivalent to or less than LNG costs).

1 More specifically, LNG Transition portfolio options are expected to show escalating costs through future
2 years as natural gas prices are expected to increase at a rate faster than general inflation. Although the
3 precise timing and extent of such price increases is uncertain today, by 2020 the initial year costs for a
4 new hydro development with a levelized cost (2010\$) of 10 cents/kW.h might correspond to the then
5 current costs for LNG-supplied generation - in which case, the transition from LNG to new hydro could
6 occur relatively smoothly, subject to the overriding need for sustained long-term load to appropriately
7 utilize the new hydro on a sustainable basis²¹⁴.


8 At such time as new hydro develops, LNG grid generating unit capacity no longer needed for baseload
9 energy generation can be retained for peaking, low water and emergency/grid reliability use. These units
10 are flexible as to the range of such uses and will likely be dual fuel in nature such that they can also use
11 diesel fuel if so required. Furthermore, when new hydro is developed LNG supplies are expected to
12 continue to be provided in Yukon to meet remaining off-grid power loads as well as other sector loads
13 such as transportation²¹⁵.

14 If Yukon Energy is to protect opportunities to start construction before 2021 on any of the above hydro
15 projects, considerable planning will be required through the next five years (2011-2015). Figure 7-3
16 provides an overview of the potential timing and key planning stages required to develop greenfield
17 hydro project options during this period, highlighting actions needed during 2011-2015 to protect the
18 ability to bring any such hydro option into service within the next decade and identifying currently
19 identified potential off-grid load and development opportunities that are likely to affect hydro option
20 planning.

²¹⁴ Section 6, Figure 6-5 shows annual costs per kW.h during the period of forecast connected mine loads (2015-2020) for LNG fuel & O&M, LNG total cost with capital, Wood Biomass 15 MW option, 21 MW Wind, 2.2 MW WTE. Marsh & Gladstone. Overall, LNG annual costs (with capital) during this period remain well below annual costs for all renewable options other than the hydro enhancement options (Marsh Lake Storage and Gladstone Diversion) -by 2020, LNG costs in escalated dollars approximate 19 cents/kW.h (13 cents for fuel & O&M only).

²¹⁵ These same considerations apply in the event that natural gas supplies come to be available directly in Yukon through the Alaska Highway Pipeline Project and/or Eagle Plains gas development. LNG liquefaction facilities may need to be moved to (or developed in) Yukon - but ongoing LNG requirements are anticipated to remain for off grid power uses and other sectors.

1 **Figure 7-3: Overview of Planning Activities for Greenfield Hydro Supply Option Development - 2011-2021**



2

1 **7.4 SUMMARY CONCLUSIONS & NEXT STEPS**

2 Looking beyond the next few years, the 2011 Resource Plan identifies a range of greenfield hydro
3 resource project opportunities potentially available to start construction before 2021, subject to
4 appropriate planning and development of loads sufficient to fully utilize these resources. These
5 opportunities offer potential to establish sustainable lower cost electricity as well as low GHG emissions in
6 a way similar to that secured by earlier legacy hydro developed in response to earlier major Yukon
7 industrial mine developments. Near-term cost savings provided by an LNG Transition Portfolio could
8 facilitate ability to proceed with such planning for the next major legacy renewable resource
9 developments.

10 The LNG Transition portfolio option as described in the 2011 Resource Plan, if adopted for the near-term,
11 is designed as a potential transition response to current grid load forecasts and the impacts expected to
12 be associated with the Default Diesel Portfolio as well as various Minimum GHG emissions portfolio
13 options relying on renewable resource development. LNG is not considered as a long-term legacy
14 resource option for Yukon. The intent would remain to displace LNG use with appropriate renewable
15 resource options when it is cost effective to do so (i.e., when sustained high utilization can be effectively
16 achieved for renewable electricity generation options over most of their economic life so as to secure
17 Forecast Utilization LCOEs that are equivalent to or less than LNG costs).

18 Development of such longer-term renewable resource options is subject to connecting new grid loads
19 that could fully utilize the specific renewable resource options over 20-30 or more years. Protecting the
20 option to start construction for such projects before 2021 is contingent upon sustaining sufficient site
21 specific planning processes as required throughout the next five year period through 2015 (see Section
22 7.3). The 2011 Resource Plan identifies potential off-grid mine loads and/or pipeline compressor loads
23 that could radically change the electricity generation sector in Yukon during the next 5- 10 years. These
24 potential new loads offer the opportunity to plan on a coordinated basis for new legacy hydro
25 development opportunities concurrent with actual development of new major mines or other major new
26 loads. To protect the ability to proceed with such opportunities prior to 2021, the 2011 Resource Plan
27 sets out proposed planning activities to be pursued during the next five to ten years (see Figure 7-5).

28 Focusing on the near-term regarding resource projects for potential commitment before 2015, the 2011
29 Resource Plan indicates that the LNG Transition Portfolio option provides a range of potential benefits
30 relative to the other available near-term grid generation options:

- 31 • Where established, LNG would displace diesel as the default option in Yukon (although dual fuel
32 units could also cost effectively retain flexibility to use diesel if and when that would be
33 advantageous). Lower cost LNG fuel would affect the assessment of future resource choices and

1 also incremental pricing and rate setting in the rate zones where it is utilized (i.e., run out rates
2 for higher use levels could be set based on LNG costs rather than diesel fuel costs).

3 • Other potential development benefits include:

- 4 ○ LNG is the only option to offer material reductions in near-term rate increase impacts
5 under Scenario A or B loads, as well as the non-diesel option with the lowest rate
6 impacts in the event that currently assumed mine closures reduce grid loads after 2020.
- 7 ○ LNG provides a cost effective contribution to grid capacity planning requirements, and
8 the planned retirements of all of YEC's diesel plant over the 20-year planning period.
- 9 ○ As a result of the above impacts, LNG is the only option to offer opportunity to reduce
10 present value diesel costs during the planning period under Scenarios A and B (projected
11 reductions at 23% under Scenario A and 29% under Scenario B).
- 12 ○ Overall, this option offers high flexibility, and ability to accommodate load changes; it can
13 also be cost effectively developed concurrently with hydro enhancements such as Marsh
14 Lake Storage and Gladstone Diversion.
- 15 ○ The LNG Transition Option can accommodate optimum timing for Gladstone diversion,
16 other potential hydro enhancements or greenfield developments, and wind development
17 in response to confirmation of longer-term grid loads needed to secure reduced Forecast
18 LCOE for these various renewable resource options.
- 19 ○ LNG is the only portfolio option that can be used off-grid to reduce reliance on diesel
20 (i.e., off-grid communities such as Watson Lake and mines at various off-grid locations).
21 This option can also be used to reduce GHG emissions in other sectors where GHG
22 emissions impacts are more significant (e.g., transportation).

23 In order to pursue the LNG option for near-term development for power generation in Yukon by late
24 2014, immediate further feasibility work is required to determine the optimum way to secure the LNG,
25 the required timing and all related costs (including assessment of potential options for LNG supply chain
26 development jointly with other interests to meet broader near and longer term Yukon opportunities).
27 Feasibility work is also required to optimize the specific Yukon Energy generation capacity and technology
28 for power generation using LNG (including assessment of the optimum combination of combined cycle
29 and simple cycle units in response to different potential load scenarios).

1 If fuel supply feasibility analysis determines that LNG cannot be available as a near-term option, the
2 following are relevant to near-term resource planning:

3 • Default Diesel portfolio option is the least cost option under Base Case loads with DSM/SSE in the
4 near-term, with lower percentage incremental annual cost increases over 2009 rates in almost all
5 years compared to all Minimum GHG portfolio options considered.

6 • If diesel is not considered an option that can be relied upon under Base Case load scenarios due
7 to environmental responsibility considerations, considerable caution would be appropriate in
8 selecting a specific near-term alternative resource portfolio.

9 ○ Marsh Lake Storage is a cost effective option under all load scenarios; however it is a
10 relatively small project.

11 ○ Going beyond Marsh Lake Storage and DSM/SSE, the remaining near-term renewable
12 resource supply options each present challenges related to capital intensity and poor
13 flexibility to deal with major drops in loads as is likely to occur after 2020 based on the
14 best available current information. Gladstone Diversion is attractive if available in
15 sufficient time to secure at least a few years of material cost savings; however, the
16 appropriate timing for even this project option is clearly affected by the sustainability of
17 mine-related loads connected to the grid.